

November 20, 2001

Mr. J. A. Scalice
Chief Nuclear Officer and
Executive Vice President
Tennessee Valley Authority
6A Lookout Place
1101 Market Street
Chattanooga, TN 37402-2801

SUBJECT: SEQUOYAH NUCLEAR PLANT, UNITS 1 AND 2, AND WATTS BAR
NUCLEAR PLANT, UNIT 1 - RESPONSES TO NRC BULLETIN 2001-01,
"CIRCUMFERENTIAL CRACKING OF REACTOR PRESSURE VESSEL HEAD
PENETRATION NOZZLES" (TAC NOS. MB2660, MB2661, AND MB2675)

Dear Mr. Scalice:

On August 3, 2001, the U.S. Nuclear Regulatory Commission (NRC) issued Bulletin 2001-01, "Circumferential Cracking of Reactor Pressure Vessel Head Penetration Nozzles," to the industry. The Bulletin requested that addressees provide information related to the structural integrity of the reactor pressure vessel head penetration (VHP) nozzles for their respective facilities. Requested information included the extent of VHP nozzle leakage and cracking that has been found to date, the inspections and repairs that have been undertaken to satisfy applicable regulatory requirements, and the basis for concluding that their plans for future inspections will ensure compliance with applicable regulatory requirements at their respective pressurized water reactor plants. You were requested to provide your response to Item 1 of the Bulletin within 30 days of its issuance.

You provided your response by letter dated August 31, 2001. The NRC staff finds that you have provided the requested information and that, based on this information, there is reasonable assurance that the public health and safety will be maintained.

Addressees are reminded that Item 5 of the bulletin requested the following information within 30 days after plant restart following the next refueling outage:

- a. a description of the extent of VHP nozzle leakage and cracking detected at your plant, including the number, location, size, and nature of each crack detected;
- b. if cracking is identified, a description of the inspections (type, scope, qualification requirements, and acceptance criteria), repairs, and other corrective actions you have taken to satisfy applicable regulatory requirements. This information is requested only if there are any changes from prior information submitted in accordance with this bulletin.

Sincerely,

/RA by Ronald W. Hernan for/
Richard P. Correia, Chief, Section 2
Project Directorate II
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos: 50-327, 50-328 and 50-390

cc: See next page

Mr. J. A. Scalice
Chief Nuclear Officer and
Executive Vice President
Tennessee Valley Authority
6A Lookout Place
1101 Market Street
Chattanooga, TN 37402-2801

November 20, 2001

SUBJECT: SEQUOYAH NUCLEAR PLANT, UNITS 1 AND 2, AND WATTS BAR
NUCLEAR PLANT, UNIT 1 - RESPONSES TO NRC BULLETIN 2001-01,
"CIRCUMFERENTIAL CRACKING OF REACTOR PRESSURE VESSEL HEAD
PENETRATION NOZZLES" (TAC NOS. MB2660, MB2661, AND MB2675)

Dear Mr. Scalice:

On August 3, 2001, the U.S. Nuclear Regulatory Commission (NRC) issued Bulletin 2001-01, "Circumferential Cracking of Reactor Pressure Vessel Head Penetration Nozzles," to the industry. The Bulletin requested that addressees provide information related to the structural integrity of the reactor pressure vessel head penetration (VHP) nozzles for their respective facilities. Requested information included the extent of VHP nozzle leakage and cracking that has been found to date, the inspections and repairs that have been undertaken to satisfy applicable regulatory requirements, and the basis for concluding that their plans for future inspections will ensure compliance with applicable regulatory requirements at their respective pressurized water reactor plants. You were requested to provide your response to Item 1 of the Bulletin within 30 days of its issuance.

You provided your response by letter dated August 31, 2001. The NRC staff finds that you have provided the requested information and that, based on this information, there is reasonable assurance that the public health and safety will be maintained.

Addressees are reminded that Item 5 of the bulletin requested the following information within 30 days after plant restart following the next refueling outage:

- a. a description of the extent of VHP nozzle leakage and cracking detected at your plant, including the number, location, size, and nature of each crack detected;
- b. if cracking is identified, a description of the inspections (type, scope, qualification requirements, and acceptance criteria), repairs, and other corrective actions you have taken to satisfy applicable regulatory requirements. This information is requested only if there are any changes from prior information submitted in accordance with this bulletin.

Sincerely,

/RA by Ronald W. Hernan for/
Richard P. Correia, Chief, Section 2
Project Directorate II
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos: 50-327, 50-328 and 50-390

cc: See next page

Distribution: See attached

ADAMS ACCESSION No. ML013240662

**DOCUMENT NAME: C:\Program Files\Adobe\Acrobat 4.0\PDF Output\Bulletin 2001-01
Closeout.wpd**

OFFICE	PDII/PM	PDII/LA	PDII-2/PM	PDII/SC
NAME	RHernan	BClayton	MPadovan	RHernan for RCorreia
DATE	11/15/01	11/15/01	11/15/01	11/19/01

OFFICIAL RECORD COPY

DATE: November 20, 2001

Accession Number: ML013240662

DISTRIBUTION:

PUBLIC

PDII-2 Reading (Hardcopy)

EMCB Reading (Hardcopy)

H. Berkow (RidsNrrDlpmLpdii)

B. Clayton (Hardcopy)

R. Hernan (Hardcopy)

K. Jabbour (RidsNrrPMKJabbour)

R. Correia (RidsNrrDlpmLpdii2)

M. Padovan (RidsNrrPMMPadovan)

P. Fredrickson (RidsRgn2MailCenter)

S. Rosenberg, EDO (e-mail)

J. Zimmerman

W. Bateman

A. Hiser

ACRS (RidsAcrcAcnwMailCenter)

OGC (RidsOgcRp)

Mr. J. A. Scalice
Tennessee Valley Authority

**SEQUOYAH NUCLEAR PLANT
WATTS BAR NUCLEAR PLANT**

cc:

Mr. Karl W. Singer, Senior Vice President
Nuclear Operations
Tennessee Valley Authority
6A Lookout Place
1101 Market Street
Chattanooga, TN 37402-2801

Mr. D. L. Koehl, Plant Manager
Sequoyah Nuclear Plant
Tennessee Valley Authority
P.O. Box 2000
Soddy Daisy, TN 37379

Mr. Jon R. Rupert, Vice President (Acting)
Engineering & Technical Services
Tennessee Valley Authority
6A Lookout Place
1101 Market Street
Chattanooga, TN 37402-2801

Senior Resident Inspector
Sequoyah Nuclear Plant
U.S. Nuclear Regulatory Commission
2600 Igou Ferry Road
Soddy Daisy, TN 37379

Mr. William R. Lagergren, Site Vice President
Watts Bar Nuclear Plant
Tennessee Valley Authority
P.O. Box 2000
Spring City, TN 37381

County Executive
Hamilton County Courthouse
Chattanooga, TN 37402-2801

Mr. Richard T. Purcell
Site Vice President
Sequoyah Nuclear Plant
Tennessee Valley Authority
P.O. Box 2000
Soddy Daisy, TN 37379

Mr. Paul L. Pace, Manager
Licensing and Industry Affairs
Watts Bar Nuclear Plant
Tennessee Valley Authority
P.O. Box 2000
Spring City, TN 37381

General Counsel
Tennessee Valley Authority
ET 11A
400 West Summit Hill Drive
Knoxville, TN 37902

Larry S. Bryant, Plant Manager
Watts Bar Nuclear Plant
Tennessee Valley Authority
P.O. Box 2000
Spring City, TN 37381

Mr. Robert J. Adney, General Manager
Nuclear Assurance
Tennessee Valley Authority
6A Lookout Place
1101 Market Street
Chattanooga, TN 37402-2801

Senior Resident Inspector
Watts Bar Nuclear Plant
U.S. Nuclear Regulatory Commission
1260 Nuclear Plant Road
Spring City, TN 37381

Mr. Mark J. Burzynski, Manager
Nuclear Licensing
Tennessee Valley Authority
4X Blue Ridge
1101 Market Street
Chattanooga, TN 37402-2801

Rhea County Executive
375 Church Street
Suite 215
Dayton, TN 37321

Mr. Pedro Salas, Manager
Licensing and Industry Affairs
Sequoyah Nuclear Plant
Tennessee Valley Authority
P.O. Box 2000
Soddy Daisy, TN 37379

County Executive
Meigs County Courthouse
Decatur, TN 37322

Mr. Lawrence E. Nanney, Director
Division of Radiological Health
Dept. of Environment & Conservation
Third Floor, L and C Annex
401 Church Street
Nashville, TN 37243-1532

Ms. Ann P. Harris
341 Swing Loop Road
Rockwood, Tennessee 37854