

December 14, 2001

MEMORANDUM TO: L. Raghavan, Acting Chief, Section 1
Project Directorate 1
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

FROM: Helen N. Pastis, Senior Project Manager, Section 1 */RA/*
Project Directorate 1
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

SUBJECT: POTENTIAL CONTROL ROD DRIVE REPAIR - OYSTER CREEK
NUCLEAR GENERATING STATION - (TAC NO. MB1933)

On May 11, 2001, AmerGen Energy Company, LLC (AmerGen or the licensee) called to state that the Oyster Creek Nuclear Generating Station (Oyster Creek) was going to shutdown on Monday, May 14, 2001, to repair the reactor coolant pump seals. AmerGen was anticipating an outage of about a week. During the outage, AmerGen would be entering the drywell. In entering the drywell, AmerGen stated that it would be inspecting the repairs that were performed in November 2000 on the control rod drive mechanisms. On November 16, 2000, the U.S. Nuclear Regulatory Commission (NRC) staff had issued an emergency approval of an alternative method to perform repairs to the control rod drive housing. Depending on the results of the inspection, AmerGen stated that Oyster Creek may have the need to request approval for another alternative repair. AmerGen was calling to inform the staff of the potential need for an expedited action in an effort to improve communications with the NRC staff. The results of the inspection showed no need for AmerGen to request an alternative repair approval of the NRC. There was no need for any expedited action.

No further action was required of the NRC staff and, therefore, TAC No. MB1933 is considered closed.

Docket No. 50-219

December 14, 2001

MEMORANDUM TO: L. Raghavan, Acting Chief, Section 1
Project Directorate 1
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

FROM: Helen N. Pastis, Senior Project Manager, Section 1 /RA/
Project Directorate 1
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

SUBJECT: POTENTIAL CONTROL ROD DRIVE REPAIR - OYSTER CREEK
NUCLEAR GENERATING STATION - (TAC NO. MB1933)

On May 11, 2001, AmerGen Energy Company, LLC (AmerGen or the licensee) called to state that the Oyster Creek Nuclear Generating Station (Oyster Creek) was going to shutdown on Monday, May 14, 2001, to repair the reactor coolant pump seals. AmerGen was anticipating an outage of about a week. During the outage, AmerGen would be entering the drywell. In entering the drywell, AmerGen stated that it would be inspecting the repairs that were performed in November 2000 on the control rod drive mechanisms. On November 16, 2000, the U.S. Nuclear Regulatory Commission (NRC) staff had issued an emergency approval of an alternative method to perform repairs to the control rod drive housing. Depending on the results of the inspection, AmerGen stated that Oyster Creek may have the need to request approval for another alternative repair. AmerGen was calling to inform the staff of the potential need for an expedited action in an effort to improve communications with the NRC staff. The results of the inspection showed no need for AmerGen to request an alternative repair approval of the NRC. There was no need for any expedited action.

No further action was required of the NRC staff and, therefore, TAC No. MB1933 is considered closed.

Docket No. 50-219

DISTRIBUTION:

PUBLIC
PDI-1 R/F
HPastis
LRaghavan
SLittle

ACCESSION NO.: ML13240683

OFFICE	PDI-1/PM	PDI-1/LA	PDI-1/SC
NAME	HPastis	SLittle	TColburn for LRaghavan (Acting)
DATE	12/13/01	12/13/01	12/14/01

OFFICIAL RECORD COPY