



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

Docket

Docket Nos. 50-327
and 50-328

28 JAN 1987

MEMORANDUM FOR: Sholly Coordinator

FROM: B.J. Youngblood, Director
PWR Project Directorate #4
Division of PWR Licensing-A, NRR

SUBJECT: REQUEST FOR PUBLICATION IN BI-WEEKLY FR NOTICE -
NOTICE OF CONSIDERATION OF ISSUANCE OF AMENDMENT
TO FACILITY OPERATING LICENSE AND PROPOSED NO
SIGNIFICANT HAZARDS CONSIDERATION DETERMINATION
AND OPPORTUNITY FOR A HEARING

Tennessee Valley Authority, Docket Nos. 50-327 and 50-328, Sequoyah Nuclear
Plant, Units 1 and 2, Hamilton County, Tennessee

Date of amendment request: January 20, 1987

Description of amendment request: The proposed change would add a requirement to limiting condition for operation (LCO) 3.3.1.1 for Unit 1 and 3.3.1 for Unit 2. This additional requirement in the LCOs would demonstrate the operability of the shunt trip attachment to the reactor trip breaker. Also, the amendment request would incorporate testing requirements in surveillance requirement 4.3.1.1 for both units for the reactor trip bypass breakers. This request was previously published on July 2, 1986 (FR 51 FR 24264).

Basis for proposed no significant hazards consideration determination: The Commission has provided guidance in the form of examples of amendments that are not considered likely to involve a significant hazards determination (FR 51 7744). Example (ii) states "a change that constitutes an additional limitation, restriction, or control not presently included in the technical specifications: for example, a more stringent surveillance requirement."

8702040097 870128
PDR ADDCK 05000327
PDR

As discussed above, the licensee's request to add a requirement for the operability of the new shunt trip attachment to the reactor trip breakers to LCO 3.3.1.1 for Unit 1 and LCO 3.3.1 for Unit 2 would be based on NRC Generic Letters 83-28 and 85-09. Therefore, this proposed change is similar to example (ii) and does not involve a significant hazard consideration.

Local Public Document Room location: Chattanooga-Hamilton County Bicentennial Library, 1001 Broad Street, Chattanooga, Tennessee 37401

Attorney for licensee: Lewis E. Wallace, Esquire, Acting General Counsel
Tennessee Valley Authority, 400 Commerce Avenue, E11B33, Knoxville, Tennessee 37902

NRC Project Director: B.J. Youngblood

B.J. Youngblood, Director
PWR Project Directorate #4
Division of PWR Licensing-A, NRR

DISTRIBUTION:

Docket File
Local PDR
NRC PDR
PWR#4 Reading
BJYoungblood Reading
JHolonich
MDuncan
OGC-Bethesda

PWR#4/DPWR-A
JHolonich/rad
01/27/87

PWR#4/DPWR-A
MDuncan
01/27/87

PWR#4/DPWR-A
BJYoungblood
01/28/87