May 5, 1983

Docket Nos: 50-327 and 50-328

Mr. H. G. Parris Manager of Power Tennessee Valley Authority 500A Chestnut Street, Tower II Chattanooga, Tennessee 37401

Dear Mr. Parris:

Subject: Issuance of Amendment No. 29 to Facility Operating License No. DPR-77 and Amendment No. 18 to Facility Operating License No. DPR-79 - Sequoyah Nuclear Plant, Units 1 and 2

The Nuclear Regulatory Commission has issued the enclosed Amendment No.29 to Facility Operating License No. DPR-77 and Amendment No.18 to Facility Operating License No. DPR-79.

The amendments change the Technical Specifications to reflect installation of the second level of undervoltage protection for the Class 1E buses. The amendments are in response to your letters dated September 17 and December 1, 1982, and April 7, 1983.

A copy of the related safety evaluation supporting Amendment No. 29 to Facility Operating License DPR-77 and Amendment No. 18 to Facility Operating License DPR-79 is enclosed. Also enclosed is a copy of the Federal Register Notice which has been forwarded to the Office of the Federal Register for publication.

						••••••			
				Sincerely,					
				Elinor G. A Licensing B Division of	densam, Chief Franch No. 4 'Licensing				
E 1 2 3 4 0 S	Enclosures: 1. Amendment No. ²⁹ to DPR-77 2. Amendment No. ¹⁸ to DPR-79 3. Safety Evaluation 4. Federal Register Notice cc w/enclosures: See next page B305160362 830505 PDR ADOCK 05000327 PDR								
OFFICE	LA:DL:DB.#4.	DL: LB.#4							
SURNAME 🕽	MDuncan/hmc.	MMiJITer	CStahle	EAdensaw			•••••		
DATE	4/2/6/83	4/ 1983	4/1/1/83	B / 9/83					

OFFICIAL RECORD COPY

USGPO: 1981-335-960

SEQUOYAH

Mr. H. G. Parris Manager of Power Tennessee Valley Authority 500A Chestnut Street, Tower II Chattanooga, Tennessee 37401 cc: Herbert S. Sanger, Jr., Esq. General Counsel Tennessee Valley Authority 400 Commerce Avenue E 11B 33 Knoxville, Tennessee 37902 Mr. H. N. Culver Tennessee Valley Authority 400 Commerce Avenue, 249A HBB Knoxville, Tennessee 37902 Mr. Bob Faas Westinghouse Electric Corp. P.O. Box 355 Pittsburgh, Pennsylvania 15230 Mr. Jerry Wills Tennessee Valley Authority 400 Chestnut Street, Tower II Chattanooga, Tennessee 37401 Mr. Donald L. Williams, Jr. Tennessee Valley Authority 400 Commerce Avenue, W10C131C Knoxville, Tennessee 37902 Resident Inspector/Sequoyah NPS c/o U.S. Nuclear Regulatory Commission 2600 Igou Ferry Road Soddy Daisy, Tennessee 37379

> Director, Office of Urban & Federal Affairs 108 Parkway Towers 404 James Robertson Way Nashville, Tennessee 37219

Attorney General Supreme Court Building Nashville, Tennessee 37219

U.S. Environmental Protection Agency ATTN: EIS Coordinator 345 Courtland Street Atlanta, Georgia 30308

Honorable Don Noore, Jr. County Judge Hamilton County Courthouse Chattanooga, Tennessee 37402

Regional Administrator Nuclear Regulatory Commission, Region II 101 Marietta Street, Suite 3100 Atlanta, Georgia 30303

	(10.90) NRCM 0240	<u> </u>	OFFICIAL	RECORD C	OPY	· · · · · · · · · · · · · · · · · · ·	USGPO: 1981-335-960
DATE 🖢							•••••
SUNNAME #			*****				
CHONIAME							
OFFICE							••••••

TENNESSEE VALLEY AUTHORITY

DOCKET NO. 50-327

SEQUOYAH NUCLEAR PLANT, UNIT 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 29 License No. DPR-77

- 1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment to the Sequoyah Nuclear Plant, Unit 1 (the facility) Facility Operating License No. DPR-77 filed by the Tennessee Valley Authority (licensee), dated September 17, 1982, as revised December 1, 1982, and April 7, 1983, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's regulations as set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the license, as amended, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
- 2. Accordingly, the license is hereby amended by page changes to the Appendix A Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C.(2) of Facility Operating License No. DPR-77 is hereby amended to read as follows:
 - (2) Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment $No_{.29}$, are hereby incorporated into the license.

8: P) P	305160366 8 DR ADOCK 05	30505 000327 PDR				-	
OFFICE							
SURNAME	•••••				••••••	•••••	····
DATE 🖢						• • • • • • • • • • • • • • • • • • • •	· · · · · · · · · · · · · · · · · · ·
IRC FORM 318	(10-80) NRCM 0240		OFFICIAL	RECORD C	OPY		USGPO: 1981335-960

The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

2

USGPO: 1981-335-960

5 Elinor G. Adensam, Chief Licensing Branch No. 4 Division of Licensing

Attachment: Appendix A Technical Specification Change

· · · ·

Date of Issuance: May 5, 1983

OFFICE	LA:DL:LB.#4	.DL:LB.#4		OELD	BL 1/18 #4	AD:L:LB	
SURNAME	MDuncan/hmc	MMilleram	CStahle	White Jan	EAdensam	INovak	
DATE N	4/24/83	4/24/83	4/2 /83	4/2/83	A14183	A97 183	
						[J]	
NRC FORM 318	(10-80) NRCM 0240		OFFICIAL	RECORD C	OPY		USGPO: 1981-335-960

ATTACHMENT TO LICENSE AMENDMENT NO. 29

FACILITY OPERATING LICENSE NO. DPR-77

DOCKET NO. 50-327

Replace the following pages of the Appendix "A" Technical Specifications with the enclosed pages. The revised pages are identified by Amendment number and contain vertical lines indicating the area of change.

Amended Page								
3/4	3-21							
3/4	3-21a							
3/4	3-27							
3/4	3 - 27a							
3/4	3-32							
3/4	3 - 33a							
3/4	3-37							
3/4	3 - 37a							
3/4	8-13							

TABLE	3.	3-	3 (Continued)
-------	----	----	-----	------------

SEQUOY				ENGINEER	ENGINEERED SAFFTY FEATURE ACTUATION SYSTEM INSTRUMENTATION							
AE - UNIT	FUNC	TIONA	L UNI	<u>T</u>	TOTAL NO. OF CHANNELS	CHANNELS TO_IRIP	MINIMUM CHANNELS OPERABLE	APPLICABLE MODES	ACTION			
سر	**7.	LOSS	OF P	OWER								
		a.	6.9	kv Shutdown Board -Loss of Voltage								
			1.	Start Diesel Generators	2/shutdown board	l loss of voltage on any shutdown board	2/shutdown board	1, 2, 3, 4	20*			
3/4			2.	Load Shedding	2/shutdown board	1/shutdown board	2/shutdown board	1, 2, 3, 4	20*			
1 3-21		b.	6.9 Degr	kv Shutdown Board aded Voltage					·			
			1.	Voltage Sensors	3/shutdown board	2/shutdown board	2/shutdown board	1, 2, 3, 4	20*			
			2.	Diesel Generator Start and Load Shedding Timer	2/shutdown board	l/shutdown board	1/shutdown board	1, 2, 3, 4	20*			
Amendme			3.	SI/Degraded Voltage Enable Timer	2/shutdown board	1/shutdown board	1/shutdown board	1, 2, 3, 4	20*			

**NOTE: This technical specification is to be implemented during the startup following the 2nd refueling outage or following completion of the modification, whichever is earlier.

Amendment No.

. 29

TABLE 3.3-3 (Continued)

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION

SEQUO	ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION										
INN - HAAG	FUNC	TIONA	<u>L UNIT</u>	TOTAL NO. OF CHANNELS	CHANNELS TO TRIP	MINIMUM CHANNELS OPERABLE	APPLICABLE MODES	ACTION			
	8.	ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INTERLOCKS									
		a.	Pressurizer Pressure - Not P-11	3	2	2	1, 2, 3	22a			
		b.	T _{avg} - P-12	4	2	3	1, 2, 3	22b			
		c.	Steam Generator Level P-14	3/1oop	2/loop any loop	3/1oop	1, 2	22c			
3/4 3-2	9.	AUTOMATIC SWITCHOVER TO CONTAINMENT SUMP									
21a		Α.	RWST Level - Low COINCIDENT WITH	4	2	3	1, 2, 3, 4	18			
			Level - High AND	4	2	3	1, 2, 3, 4	18			
			Safety Injection	(See 1 above	for Safety In	jection Require	ments)				

		TABLE 3.3-4 (Continued)								
SEQUO			. <u>E</u>	ENGINEERED SAFETY FEATURE ACT	UATION SYSTEM INSTRUMENTATION TR	IP SETPOINTS				
· HAYC	FUNC	TIONA	UNIT		TRIP SETPOINT	ALLOWABLE VALUES				
Ļ	6. AUXILIARY FEEDWATER									
Ē		a.	Manual		Not Applicable	Not Applicable				
ىم		b.	Automatic	c Actuation Logic	Not Applicable	Not Applicable				
		c.	Main Stea Water Lev	am Generator vel-low-low	> 18% of narrow range instrument span each steam generator	> 17% of narrow range instrument span each steam generator				
		d.	S.I.	· · ·	See 1 above (all SI Setpoints	;)				
(.)		e.	Station	Blackout	0 volts with a 5.0 second time delay	0 volts with a 5.0 ± 1.0 second time delay				
3/4 3-		f.	Trip of I Pumps	Main Feedwater	N.A.	N.A.				
-27		g.	Auxiliar Pressure	y Feedwater Suction -Low	≥ 2 psig (motor driven pump) ≥ 6.5 psig (turbine driven pump)	≥ 1 psig (motor driven pump) ≥ 5.5 psig (turbine driven pump)				
	*7.	LOSS	OF POWER							
		a.	6.9 kv S	hutdown Board Undervoltage		(
			Loss of	Voltage						
Amend			1. Sta a. b.	rt of Diesel Generators Nominal Voltage Setpoint Relay Response Time for Loss of Voltage	4860 volts O volts with a 1.5 second time delay	4860 volts <u>+</u> 97.2 volts 0 volts with a 1.5 <u>+</u> 0.5 second time delay				
nent No. 29			2. Loa a. b.	d Shedding Nominal Voltage Setpoint Relay Response Time for Loss of Voltage	4860 volts O volts with a 5.0 second time delay	4860 volts <u>+</u> 97.2 volts O volts with a 5.0 <u>+</u> 1.0 second time delay				
~			 • 			1				

.

.

This technical specification is to be implemented at the startup following the 2nd refueling outage or following completion of the modification, whichever is earlier. *NOTE:

TABLE 3.3-4 (Continued)

SEQUI				ENGINEERED SAFETY FEATURE ACTU	ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION TRIP SETPOINTS					
- HAYO	FUNCTIONAL UNIT			<u>T</u>	TRIP SETPOINT	ALLOWABLE VALUES				
UNIT		*b.	6.9 Volt	kv Shutdown Board-Degraded age						
Ч			1.	Voltage Sensors	6560 volts .	6560 volts <u>+</u> 33 volts ,				
			2.	Diesel Generator Start and Load Shed Timer	300 seconds	300 seconds <u>+</u> 15 seconds				
			3.	SI/Degraded Voltage Logic Enable Timer	10 seconds	10 seconds <u>+</u> 0.5 seconds				
3/4	8. ENGINEERED ACTUATION S			D SAFETY FEATURE SYSTEM INTERLOCKS	AFETY FEATURE STEM INTERLOCKS					
3-27a		a.	Pres Ma	ssurizer Pressure anual Block of Safety Injection P-	11 <u><</u> 1970 psig	<u><</u> 1980 psig				

Amendment No.29

This technical specification is to be implemented at the startup following the 2nd refueling outage or following completion of the modification, whichever is earlier. *NOTE:

TABLE 3.3-5 (Continued)

ENGINEERED SAFETY FEATURES RESPONSE TIMES

<u>INIT</u> 10.	IATIN Stat	G SIGNAL AND FUNCTION	RESPONSE	TIME IN SECONDS
	a.	Auxiliary Feedwater Pumps		<u><</u> 60
11.	Trip	of Main Feedwater Pumps		
	a.	Auxiliary Feedwater Pumps		<u><</u> 60 .
*12.	Loss	of Power		
	a.	6.9 kv Shutdown Board - Degr Voltage or Loss of Voltage	aded	≤ 10 ⁽¹⁰⁾
13.	RWST	Level-Low Coincident with Co	ntainment Sump	
	Leve	1-High and Safety Injection		
	a.	Automatic Switchover to Containment Sump		<u><</u> 250
14.	Cont	ainment Purge Air Exhaust	· · · ·	
	Radi	oactivity - High		
	a.	Containment Ventilation Isol	ation	$\leq 10^{(6)}$
15.	<u>Cont</u> Radi	ainment Gas Monitor		
	a.	Containment Ventilation Isol	ation	< 10 ⁽⁶⁾
16.	Cont	ainment Particulate Activity	High	-
	a.	Containment Ventilation Isol	ation	$\leq 10^{(6)}$
*иот	E: T t w	his technical specification t he second refueling outage or hichever is earlier.	o be implemented at t following completion	he startup following of the modification
SEQU	OYAH ·	- UNIT 1 3	/4 3-32	Amendment No.29

INSTRUMENTATION

TABLE 3.3-5 (Continued)

TABLE NOTATION

* (10) The response time for loss of voltage is measured from the time voltage is lost until the time full voltage is restored by the diesel. The response time for degraded voltage is measured from the time the load shedding signal is generated, either from the degraded voltage or the SI enable timer, to the time full voltage is restored by the diesel. The response time of the timers is covered by the requirements on their setpoints.

*NOTE: This technical specification to be implemented at the startup following the second refueling outage or following completion of the modification, whichever is earlier.

SEQUOYAH - UNIT 1

Amendment No. 29

TABLE 4.3-2 (Continued)

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION SURVEILLANCE REQUIREMENTS

FUNC	TIONA	<u>L UNIT</u>	CHANNEL _CHECK_	CHANNEL CALIBRATION	CHANNEL FUNCTIONAL TEST	MODES IN WHICH SURVEILLANCE REQUIRED
	c.	Main Steam Generator Water Level-Low-Low	S	- R	Q	1, 2, 3
	d.	S.I.	See 1 ab	ove (all SI surv	eillance require	ements)
	e.	Station Blackout	N.A.	R	N.A.	1, 2, 3
	f.	Trip of Main Feedwater Pumps	N.A.	N.A.	R	1, 2
	g.	Auxiliary Feedwater Suction	N.A.	R	М	1, 2, 3
*7.	LOSS	OF POWER				
	a.	6.9 kv Shutdown Board - Loss of Voltage				
		 Start Diesel Generators Load Shedding 	S S	R R	M N.A.	1, 2, 3, 4 1, 2, 3, 4
	b.	6.9 kv Shutdown Board - Degraded Voltage				
		1. Voltage sensors	S	R	М	1, 2, 3, 4
		2. Diesel Generators Start and Load Shedding Timer	N.A.	R	N.A.	1, 2, 3, 4
		3. ŚI/Degraded Voltage Logic Timer	N.A.	R	N.A.	1, 2, 3, 4

* NOTE: This technical specification to be implemented at the startup following the 2nd refueling outage or following completion of the modification, whichever is earlier.

SEQUOYAH - UNIT

لبيز

3/4 3-37

Amendment No.29

•

TABLE 4.3-2 (Continued)									
EQUOYA			ENGINEERED SAF	ETY FEATURE SURVEILL	ACTUATION SYSTEM	INSTRUMENTAT	ION		
H - UNIT	FUNC	CTIONA	<u>NL UNIT</u>	CHANNEL CHECK	CHANNEL CALIBRATION	CHANNEL FUNCTIONAL TEST	MODES IN WHICH SURVEILLANCE REQUIRED		
} ⊶4	8.	ENG1 ACTU	INEERED SAFETY FEATURE JATION SYSTEM INTERLOCKS						
		a.	Pressurizer Pressure, P-11	N.A.	R (4)	N.A.	1, 2, 3		
		b.	T _{avg} , P-12	N.A.	R (4)	N.A.	1, 2, 3		
		c.	Steam Generator Level, P-14	N.A.	R (4)	N.A.	1, 2		
3/4 3-	9.	AUT(CONT	DMATIC SWITCHOVER TO FAINMENT SUMP						
.37a		a.	RSWT Level - Low COINCIDENT WITH	S	R	M	1, 2, 3, 4		
			Containment Sump Level - High AND	ı S	R	М	1, 2, 3, 4		
			Safety Injection	(See 1 a	bove for all Safe	ty Injection	Surveillance Requirements)		

Amendment No. 29

ELECTRICAL POWER SYSTEMS

SURVEILLANCE REQUIREMENTS (Continued)

- d. At least once per 18 months by verifying that the battery capacity is adequate to supply and maintain in OPERABLE status all of the actual or simulated emergency loads for 2 hours when the battery is subjected to a battery service test.
- At least once per 60 months by verifying that the battery capacity is at least 82% of the manufacturer's rating when subjected to a performance discharge test. Once per 60 month interval, this performance discharge test may be performed in lieu of the battery service test.
- f. Annual performance discharge tests of battery capacity shall be given to any battery that shows signs of degradation or has reached 85% of the service life expected for the application. Degradation is indicated when the battery capacity drops more than 10% of rated capacity from its average on previous performance tests, or is below 90% of the manufacturer's rating.
- *NOTE: This technical specification is to be implemented during the startup following the 2nd refueling outage or following completion of the modification, whichever is earlier.

TENNESSEE VALLEY AUTHORITY

DOCKET NO. 50-328

SEQUOYAH NUCLEAR PLANT, UNIT 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 18 License No. DPR-79

- 1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment to the Sequoyah Nuclear Plant, Unit 2 (the facility) Facility Operating License No. DPR-79 filed by the Tennessee Valley Authority (licensee), dated September 17, 1982, as revised December 1, 1982, and April 7, 1983, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's regulations as set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the license, as amended, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
- Accordingly, the license is hereby amended by page changes to the Appendix A Technical Specifications as indicated in the attachments to this license amendment and paragraph 2.C.(2) of Facility Operating License No. DPR-79 is hereby amended to read as follows:
 - (2) Technical Specifications

• •

The Technical Specifications contained in Appendix A, as revised through Amendment No. , are hereby incorporated into the license.

07					
OFFICE		 			 *****
SURNAME		 			
DATEN					
DATE		 			
NRC FORM 318	(10-80) NRCM 0240	OFFICIAL	RECORD C	OPY	USGPO: 1981-335-960

The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

Elinor G. Adensam, Chief Licensing Branch No. 4 Division of Licensing

Attachment: Appendix A Technical Specification Change

Date of Issuance: May 5, 1983

	LA:DL:LB#4 MDuncan/hmc		DL:LB.#4 CStahle	DELD	DC:1/By#4 EAdensam	AD: S: BI	
DATE .	4/26/83	4/1 ¹ /83	4/ /83	4/12/83	9/4/83	5/2/83	

OFFICIAL RECORD COPY

ATTACHMENT TO LICENSE AMENDMENT NO. 18

FACILITY OPERATING LICENSE NO. DPR-79

DOCKET NO. 50-328

Replace the following pages of the Appendix "A" Technical Specifications with the enclosed pages. The revised pages are identified by Amendment number and contain vertical lines indicating the area of change.

Amended Page								
3/4	3-21							
3/4	3-21a							
3/4	3-27							
3/4	3 - 27a							
3/4	3-32							
3/4	3-33a							
3/4	3-37							
3/4	3-37a							
3/4	8-13							

SE	ENCINEEDED CAEETY FEATURE ACTUATION SYSTEM INSTRUMENTATION										
YOUC				ENGINEE	KED SAFETY FEATU	JRE ACTUATION SY:	STEM INSTRUMEN	TATION			
YAH - UNIT 2	<u>FUNCTI(</u> **7. L(<u>ONAL</u> OSS	UNI OF P	<u>T</u> DWER	TOTAL NO. <u>OF CHANNELS</u>	CHANNELS TO TRIP	MINIMUM CHANNELS OPERABLE	APPLICABLE MODES	ACTION		
	а	•	6.9	kv Shutdown Board -Loss of Voltage							
			1.	Start Diesel Generators	2/shutdown board	l loss of voltage on any shutdown board	2/shutdown board	1, 2, 3, 4	20*		
3/4			2.	Load Shedding	2/shutdown board	l/shutdown board	2/shutdown board	1, 2, 3, 4	20*		
4 3-21	b	•	6.9 Degr	kv Shutdown Board aded Voltage							
			1.	Voltage Sensors	3/shutdown board	2/shutdown board	2/shutdown board	1, 2, 3, 4	20*		
			2.	Diesel Generator Start and Load Shedding Timer	2/shutdown board	l/shutdown board	1/shutdown board	1, 2, 3, 4	20*		
Amendm			3.	SI/Degraded Voltage Enable Timer	2/shutdown board	1/shutdown board	l/shutdown board	1, 2, 3, 4	20*		
еn		.				- · · · ·					

**NOTE: This technical specification is to be implemented during the startup following the 1st refueling outage.

nt No.

18

TABLE 3.3-3 (Continued)

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION

SEQUOY	ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION										
AH - UNIT	FUNC	TION	<u>AL UNIT</u>	TOTAL NO. <u>OF CHANNELS</u>	CHANNELS TO TRIP	MINIMUM CHANNELS OPERABLE	APPLICABLE MODES	ACTION			
, N	8.	ENG] ACTU	INEERED SAFETY FEATURE JATION SYSTEM INTERLOCKS								
		a.	Pressurizer Pressure - Not P-11	3	2	2	1, 2, 3	22a			
		b.	T _{avg} - P-12	4	2	3	1, 2, 3	22b			
		c.	Steam Generator Level P-14	3/1oop	2/loop any loop	3/loop	1, 2 _.	22c			
3/4 3-2	9.	AUTOMATIC SWITCHOVER TO CONTAINMENT SUMP									
21a		Α.	RWST Level - Low COINCIDENT WITH	4	2	3	1, 2, 3, 4	18			
			Level - High AND	4	2	3	1, 2, 3, 4	18			
			Safety Injection	(See 1 above	for Safety In	jection Require	ments)				

				TABLE	3.3-4 (Continued)		
			- <u>El</u>	NGINEERED SAFETY FEATURE ACTUA	VTION SYSTEM INSTRUMENTATION TR	IP SETPOINTS	
	FUNC	TIONAL	UNIT		TRIP SETPOINT	ALLOWABLE VALUES	
ļ	6.	AUXIL	IARY FEED	WATER			
-		a.	Manual		Not Applicable	Not Applicable	
ა		b.	Automatic	Actuation Logic	Not Applicable	Not Applicable	
		c.	Main Stea Water Lev	m Generator el-low-low	> 18% of narrow range instrument span each steam generator	> 17% of narrow range instrument span each steam generator	
		d.	S.I.		See 1 above (all SI Setpoints		
ა		e.	Station B	lackout	0 volts with a 5.0 second time delay	O volts with a 5.0 \pm 1.0 second time delay	
		f.	Trip of M Pumps	lain Feedwater	N.A.	N.A.	
5		g.	Auxiliary Pressure-	Feedwater Suction Low	≥ 2 psig (motor driven pump) ≥ 6.5 psig (turbine driven pump)	> 1 psig (motor driven pump) > 5.5 psig (turbine driven pump)	
	*7.	LOSS	OF POWER				
		a.	6.9 kv Sh	utdown Board		(
			Loss of V	/oltage			
Amond			1. Star a. b.	t of Diesel Generators Nominal Voltage Setpoint Relay Response Time for Loss of Voltage	4860 volts O volts with a 1.5 second time delay	4860 volts ±97.2 volts 0 volts with a 1.5 ±0.5 second time delay	
ant No 18			2. Load a. b.	l Shedding Nominal Voltage Setpoint Relay Response Time for Loss of Voltage	4860 volts O volts with a 5.0 second time delay	4860 volts <u>+</u> 97.2 volts 0 volts with a 5.0 <u>+</u> 1.0 second time delay	

*NOTE: This technical specification is to be implemented during the startup following the 1st refueling outage.

3/4 U r

SEQUOYAH - UNIT

≝ <u>FU</u> ι.	NCTIONA	AL UNIT	TRIP SETPOINT	ALLOWABLE VALUES
UNIT	*b.	6.9 kv Shutdown Board-Degraded Voltage		
N		1. Voltage Sensors	6560 volts	6560 volts \pm 33 volts ,
		2. Diesel Generator Start and Load Shed Timer	300 seconds	300 seconds <u>+</u> 15 seconds
		3. SI/Degraded Voltage Logic Enable Timer	10 seconds	10 seconds <u>+</u> 0.5 seconds
8. 3/4	ENGI ACTU	INEERED SAFETY FEATURE UATION SYSTEM INTERLOCKS		
3 - 27a	a.	Pressurizer Pressure Manual Block of Safety Injectio	on P-11 <u><</u> 1970 psig	<u><</u> 1980 psig
		•		
				•
Amendmen				
it No. *1	NOTE: 1	This technical specification is to outage.	be implemented during the st	tartup following the 1st refueling

TABLE 3.3-5 (Continued)

ENGINEERED SAFETY FEATURES RESPONSE TIMES

INITI	<u>EATINO</u>	S SIGNAL AND FUNCTION	RESPONSE TIME IN SECONDS	
10.	<u>Stat</u>	ion Blackout		
	a.	Auxiliary Feedwater Pumps	. <u><</u> 60	
11.	<u>Trip</u>	of Main Feedwater Pumps		
	a.	Auxiliary Feedwater Pumps	<u><</u> 60	
*12.	Loss	of Power		
	a.	6.9 kv Shutdown Board - Degraded Voltage or Loss of Voltage	< 10 ⁽¹⁰⁾	
13.	<u>RWST</u>	Level-Low Coincident with Containme	ent Sump	
	Leve	1-High and Safety Injection		
	a.	Automatic Switchover to Containment Sump	<u><</u> 250	
14.	<u>Conta</u> Radi	ainment Purge Air Exhaust	· · ·	
	a.	Containment Ventilation Isolation	< 10 ⁽⁶⁾	
15.	<u>Cont</u> Radi	ainment Gas Monitor oactivity High		
	a.	Containment Ventilation Isolation	$\leq 10^{(6)}$	
16.	<u>Cont</u>	ainment Particulate Activity High		
	a.	Containment Ventilation Isolation	< 10 ⁽⁶⁾	
*NOT	E: T f	his technical specification is to be ollowing the first refueling outage.	e implemented during the startu	ıp
SEOU	ОҮАН	- UNIT 2 3/4 3-32	2 Amendment No. 1	ا 18

INSTRUMENTATION

TABLE 3.3-5 (Continued)

TABLE NOTATION

* (10) The response time for loss of voltage is measured from the time voltage is lost until the time full voltage is restored by the diesel. The response time for degraded voltage is measured from the time the load shedding signal is generated, either from the degraded voltage or the SI enable timer, to the time full voltage is restored by the diesel. The response time of the timers is covered by the requirements on their setpoints.

*NOTE: This technical specification is to be implemented during the startup following the first refueling outage.

SEQUOYAH - UNIT 2

Amendment No. 18

TABLE 4.3-2 (Continued)

ENGINEERED	SAFETY	FEATURE	ACTUATION	SYSTEM	INSTRUMENTATION	
	(SURVEILL	ANCE REOUI	REMENTS		

- UNIT	FUNC	TIONA	L UNI	<u>T</u>	CHANNEL _CHECK_	CHANNEL CALIBRATION	CHANNEL FUNCTIONAL TEST	MODES IN WHICH SURVEILLANCE REQUIRED
N		c.	Main Leve	Steam Generator Water 1-Low-Low	S	R	Q	1, 2, 3
		d.	S.I.		See 1 ab	ove (all SI surv	eillance requir	ements)
3/4		e.	Stat	ion Blackout	N.A.	R	N.A.	1, 2, 3
		f.	Trip Pump	of Main Feedwater s	N.A.	N.A.	R	1, 2
		g.	Auxi	liary Feedwater Suction	N.A.	R	Μ	1, 2, 3
	*7.	LOSS	OF P	OWER				
3-37		a.	6.9 Loss	kv Shutdown Board - of Voltage				
			1. 2.	Start Diesel Generators Load Shedding	S S	R R	M N.A.	1, 2, 3, 4 1, 2, 3, 4
		b.	6.9 Degr	kv Shutdown Board - aded Voltage				
			1.	Voltage sensors	S	R	Μ	1, 2, 3, 4
Amer			2.	Diesel Generators Start and Load Shedding Timer	N.A.	R	N.A.	1, 2, 3, 4
dment			3.	SI/Degraded Voltage Logic Timer	N.A.	R	N.A.	1, 2, 3, 4

Amendment No.

*NOTE: This technical specification is to be implemented during the startup following the 1st refueling outage.

SEQUOYAH - UNIT

18

SEQUOYAH - UNIT :	ENGINEERED SAFE			ETY FEATURE SURVEILL	ACTUATION SYSTEM	1 INSTRUMENTAT	ION
	FUNC	CTION	<u>AL UNIT</u>	CHANNEL _CHECK	CHANNEL CALIBRATION	CHANNEL FUNCTIONAL TEST	MODES IN WHICH SURVEILLANCE REQUIRED
N	8.	ENGI ACTI	INEERED SAFETY FEATURE JATION SYSTEM INTERLOCKS				,
		a.	Pressurizer Pressure, P-11	N.A.	R (4)	N.A.	1, 2, 3
		b.	T _{avg} , P-12	N.A.	R (4)	N.A.	1, 2, 3
		c.	Steam Generator Level, P-14	N.A.	R (4)	N.A.	1, 2
3/4 3-	9.	AUTOMATIC SWITCHOVER TO CONTAINMENT SUMP					
.37a		a.	RSWT Level - Low COINCIDENT WITH	S	R	М	1, 2, 3, 4
			Containment Sump Level - High AND	S	R	М	1, 2, 3, 4
			Safety Injection	(See 1 a	bove for all Safe	ety Injection	Surveillance Requirements)

Amendment No. 18

.

ELECTRICAL POWER SYSTEMS

SURVEILLANCE REQUIREMENTS

- 2. Verifying total battery terminal voltage is greater than or equal to 129-volts on float charge.
- At least once per 92 days and within 7 days after a battery discharge (battery terminal voltage below 110-volts), or battery overcharge (battery terminal voltage above 150-volts), by:
 - 1. Verifying that the parameters in Table 4.8-2 meet the Category B limits,
 - 2. Verifying there is no visible corrosion at either terminals or connectors, or the connection resistance of these items is less than 150×10^{-6} ohms, and
 - 3. Verifying that the average electrolyte temperature of 6 connected cells is above 60 F.
- c. At least once per 18 months by verifying that:
 - 1. The cells, cell plates, and battery racks show no visual indication of physical damage or abnormal deterioration,
 - 2. The cell-to-cell and terminal connections are clean, tight, and coated with anti-corrosion material,
 - 3. The resistance of each cell-to-terminal connection is less than or equal to 150×10^{-6} ohms, and
 - 4. The battery charger will supply at least 150 amperes at 125-volts for at least 4 hours.
- d. At least once per 18 months by verifying that the battery capacity is adequate to supply and maintain in OPERABLE status all of the actual or simulated emergency loads for 2 hours when the battery is subjected to a battery service test.
- e. At least once per 60 months by verifying that the battery capacity is at least 82% of the manufacturer's rating when subjected to a performance discharge test. Once per 60 month interval, this performance discharge test may be performed in lieu of the battery service test.
- f. Annual performance discharge tests of battery capacity shall be given to any battery that shows signs of degradation or has reached 85% of the service life expected for the application. Degradation is indicated when the battery capacity drops more than 10% of rated capacity from its average on previous performance tests, or is below 90% of the manufacturer's rating.
- * NOTE: This technical specification is to be implemented during the startup following the 1st refueling outage.

Amendment No. 18

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION

RELATED TO AMENDMENT NO. 29 TO FACILITY OPERATING LICENSE DPR-77

AND AMENDMENT NO. 18 TO FACILITY OPERATING LICENSE DPR-79

TENNESSEE VALLEY AUTHORITY

INTRODUCTION

In a letter dated September 17, 1982, Tennessee Valley Authority (TVA) requested a change in the Sequoyah Units 1 and 2 Technical Specifications Tables 3.3-3, 3.3-4, 3.3-5, and 4.3-2 because of the installation of the second level of undervoltage protection for the Class IE buses. These changes are intended to meet the requirements of license conditions 2.C(18)c. of Unit 1 and 2.C(11)b. of Unit 2. In a submittal dated December 1, 1982, the licensee provided additional information needed to clarify the initial submittal. TVA resubmitted the proposed Technical Specifications on April 7, 1983, with the only change being the addition of implemented at the startup following the second or first refueling outage, respectively, or at the modification completion for Unit 1, whichever is earlier for that unit.

EVALUATION

In the submittals of September 17 and December 1, 1982, TVA provided design details and technical specifications for the replacement of first level undervoltage relays and the installation of a second level of undervoltage protection (degraded voltage relays) for the Class 1E buses. The proposed replacement of the first level relays will replace the CV-7 (inverse time) loss of voltage relay on the normal feeder to the 6.9 Kv Class 1E buses with three instantaneous (ITE-27H) relays arranged in a two-out-of-three coincidence logic with a setpoint of 80% of nominal voltage and a time delay of four seconds. The logic will energize two timers, either of which will initiate transfer of the Class 1E buses to the alternate power source provided the alternate source has a voltage greater than 95% nominal voltage.

Installation of the second level of undervoltage relays will protect the Class 1E buses from sustained degraded undervoltage. Each of the two 6.9 Kv Class 1E buses per unit will be provided with three instantaneous (ITE 27/59H) undervoltage relays. These relays will have a nominal setpoint of 6560V + 1/2% (95% of nominal). The relays will be arranged in a two-out-of-three coincidence logic to initiate three time delay sequences. The first sequence of 30 seconds will provide annunciation in the control room without spurious actuation due to motor starting transients. The second sequence of 10 seconds is short enough to allow safety-related equipment

83 PD P	05160368 830 R Adock 050	0505 00327 PDR					
OFFICE		*****		••••••		*********	
					*** *****************	******	
•							
DATE 🕨			·····		********************		
NBC FORM 318	(10-80) NRCM 0240	I	OFFICIAL	RECORD C	OPY		USGPO: 1981-335-960

ुः

to be powered within the time required by the accident analysis. At the end of 10 seconds if a safety injection signal (SIS) has been initiated, or is subsequently initiated, the Class 1E shutdown board degraded voltage relays will initiate load shedding and transfer the affected shutdown board to the onsite emergency diesel generator. The third time delay of 5 minutes under non-accident conditions is long enough to allow operator action to attempt to restore bus voltage to normal without resulting in damage to the safety-related equipment. If the operator is unable to restore bus voltage to above 95% within 5 minutes, the degraded voltage relays will automatically transfer the affected Class 1E buses to the onsite emergency diesel generator.

In the proposed change to Technical Specification 4.8.2.3.2 the minimum battery capacity has been raised from 80% to 82% to allow for possible discharge during the 5 minute delay which assures that the batteries meet the 2 hour accident requirements in all cases. Technical Specification Tables 3.3-3, 3.3-4, 3.3-5 and 4.3-2 have been modified to include the degraded voltage instrumentation. Table 3.3-4 lists the trip setpoint and allowable values for the degraded voltage setpoints. At the request of the NRC staff in an October 29, 1982, telephone conversation, TVA committed to include the trip setpoint and allowable values for the first level of undervoltage protection (loss of voltage) also found in Table 3.3-4. The proposed change to Table 3.3-5 adds a footnote to clarify the time period measured by the degraded voltage channels. Table 4.3-2 deals specifically with surveillance of the instrumentation.

To protect the Class 1E bus from a sustained overvoltage, each 6.9 Kv Class 1E bus will be provided with a set of three instantaneous (ITE-59H) overvoltage relays. These relays will be arranged in a one-out-of-three logic to annunciate in the control room. Upon receipt of this alarm, the operator will take the necessary action required to reduce the voltage to normal.

The load shedding feature provided by the degraded voltage relays (second level) will be bypassed when the diesel generator is supplying the Class 1E buses. The load shedding feature provided by the loss of voltage relays (first level) will be retained when the diesel generator is supplying the Class 1E buses. The licensee has demonstrated that the setpoint (70% of nominal) will preclude actuation of load shedding while the safety-related equipment is being sequenced on the onsite emergency diesel generator.

The proposed second level protective relay setpoints and time delays have been substantiated by a verified voltage analysis which determined the voltage requirements of the safety-related equipment. The staff has reviewed the licensee submittals and concludes that upon completion of the proposed modifications and implementation of the associated Technical Specifications, the Sequoyah Nuclear Plant, Units 1 and 2, design will provide adequate assurance that no damage to the safety-related electrical equipment will occur as a result of degraded grid voltage and is therefore acceptable.

				1			
OFFICE						••••••	
SURNAME	•••••	,			·····	·····	••••••
DATE			•••••			.,	
C FORM 318	(10-80) NRCM 0240		OFFICIAL	RECORD C	OPY		USGPO: 1981-335-960

ENVIRONMENTAL CONSIDERATION

We have determined that the amendments do not authorize a change in effluent types or total amounts nor an increase in power level and will not result in any significant environmental impact. Having made this determination, we have further concluded that the amendments involve an action which is insignificant from the standpoint of environmental impact and, pursuant to 10 CFR 51.5(d)(4), that an environmental impact statement or negative declaration and environmental impact appraisal need not be prepared in connection with the issuance of these amendments.

CONCLUSION

We have concluded, based on the considerations discussed above, that: (1) because the amendments do not involve a significant increase in the probability or consequences of accidents previously considered, do not create the possibility of an accident of a type different from any evaluated previously, and do not involve a significant decrease in a safety margin, the amendments do not involve a significant hazards consideration, (2) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and (3) such activities will be conducted in compliance with the Commission's regulations and the issuance of these amendments will not be inimical to the common defense and security or to the health and safety of the public.

Date: May 5, 1983

Principal	Contributors:	Melanie Miller, Licensing Branch No. 4,	DL
		Carl Stahle, Licensing Branch No. 4, DL	
		John Emami, Power Systems Branch, DSI	

OFFICE	DL:LB #4	DL:LB #4	DL;LB #4	ESI:PSI	DL. LB #A	AD:L:DL	
SURNAME	Mi Men7mmc	MDuncan	CStahle	MSrinivasan	EAderisam	Thovak	
DATE 🌢	4/267.83	.4/2ld/83		4/3./83	A. 1. 1. 183	A12.183	
IDC FORM 318	(10-80) NRCM 0240		OFFICIAL	RECORD C	OPY	J	USGPO: 1991-335-960

- 3 -

5 1 12

UNITED STATES NUCLEAR REGULATORY COMMISSION

an.

DOCKET NOS. 50-327 AND 50-328

TENNESSEE VALLEY AUTHORITY

NOTICE OF ISSUANCE OF AMENDMENTS

FACILITY OPERATING LICENSE NOS. DPR-77 AND DPR-79

The U. S. Nuclear Regulatory Commission (the Commission) has issued Amendment No. 29 to Facility Operating License No. DPR-77 and Amendment No. 18 to Facility Operating License No. DPR-79, issued to Tennessee Valley Authority (licensee) for the Sequoyah Nuclear Plant, Units L, and 2 (the facilities) located in Hamilton County, Tennessee. These amendments change the Technical Specifications to reflect installation of the second level of undervoltage protection for the Class 1E buses. The amendments are effective as of their dates of issuance.

The application for the amendments complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations. The Commission has made appropriate findings as required by the Act and the Commission's regulations in 10 CFR Chapter I, which are set forth in the license amendments. Prior public notice of these amendments was not required since the amendments do not involve a significant hazards consideration.

The Commission has determined that the issuance of these amendments will not result in any significant environmental impact and that pursuant to 10 CFR §51.5(d)(4) an environmental impact statement, or negative declaration and environmental impact appraisal need not be prepared in connection with issuance of these amendments.

830 PDF P	5160369 830 ADOCK 050	0505 00327 PDR				
DATE						
NRC FORM 318	(10-80) NRCM 0240		OFFICIAL	RECORD C	OPY	USGPO: 1981-335-960

For further details with respect to this action, see (1) Tennessee Valley Authority letters dated September 17 and December 1, 1982, and April 7, 1983 (2) Amendment No. ²⁹ to Facility Operating License No. DPR-77 with Appendix A Technical Specification page changes; (3) Amendment No. ¹⁸ to Facility Operating License No. DPR-79 with Appendix A Technical Specification page changes; and (4) the Commission's related Safety Evaluation.

- 2 -

All of these items are available for public inspection at the Commission's Public Document Room, 1717 H Street, N.W., Washington, D. C., and the Chattanooga Hamilton County Bicentennial Library, 1001 Broad Street, Chattanooga, Tennessee 37402. A copy of Amendment No. ²⁹ and Amendment No. ¹⁸ may be obtained upon request addressed to the U. S. Nuclear Regulatory Commission, Washington, D. C. 20555, Attention: Director, Division of Licensing.

Dated at Bethesda, Maryland, this 5th day of May 1983.

FOR THE NUCLEAR REGULATORY COMMISSION

Elinor G. Adensam, Chief Licensing Branch No. 4 Division of Licensing

OFFICE	LA:DL:LB.#4.	DL:LB.#4	DLabb #4	OELD	DL TB #4		
	4/26/83	4/26/83	4/1/83	4/22 /83	3 / / /83		
AC FORM 318 (10-80) NRCM 0240 OFFICIAL RECORD COPY						USGPO: 1981-335-960	



UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D.C. 20555 DISTRIBUTION: Docket File LB#4 Reading CStahle MDuncan

May 11, 1983

Docket Nos. 50-327 50-328

Docketing and Service Section Office of the Secretary of the Commission

SUBJECT: Sequoyah Nuclear Plant, Units 1 and 2 (TENNESSEE VALLEY AUTHORITY)

One

15

Two signed originals of the <u>Federal Register</u> Notice identified below **ava** enclosed for your transmittal to the Office of the Federal Register for publication. Additional conformed copies (**12**) of the Notice are enclosed for your use.

- □ Notice of Receipt of Application for Construction Permit(s) and Operating License(s).
- Notice of Receipt of Partial Application for Construction Permit(s) and Facility License(s): Time for Submission of Views on Antitrust Matters.
- □ Notice of Availability of Applicant's Environmental Report.
- □ Notice of Proposed Issuance of Amendment to Facility Operating License.
- □ Notice of Receipt of Application for Facility License(s); Notice of Availability of Applicant's Environmental Report; and Notice of Consideration of Issuance of Facility License(s) and Notice of Opportunity for Hearing.
- □ Notice of Availability of NRC Draft/Final Environmental Statement.
- □ Notice of Limited Work Authorization.
- □ Notice of Availability of Safety Evaluation Report.
- □ Notice of Issuance of Construction Permit(s).
- XX Notice of Issuance of Facility Operating License(s).
- Other:___

Enclosure:

Office of Nuclear Reactor Regulation

As Stated

 OFFICE
 DL:LB#4

 SURNAME
 MDuncan

 DATE
 5/11/83

AMENDMENT NO.29 TO FACILITY OPERATING LICENSE DPR-77 - SEQUOYAH UNIT 1 AMENDMENT NO.18 TO FACILITY OPERATING LICENSE DPR-79 - SEQUOYAH UNIT 2

DISTRIBUTION w/enclosures: Docket No. 50-327/328 LB #4 r/f C. Stahle M. Duncan OELD E. Adensam R. Hartfield, MPA R. Diggs, ADM D. Eisenhut/R. Purple J. Souder T. Barnhart (8) E. L. Jordan, DEQA: I&E J. M. Taylor, DRP: I&E L. J. Harmon, IE File bcc w/enclosures:

NRC PDR Local PDR NSIC TERA A. Rosenthal, ASLAB ASLBP ACRS (16) W. Jones (10)