

Docket Nos.: 50-327  
and 50-328

September 16, 1986

Mr. S. A. White  
Manager of Nuclear Power  
Tennessee Valley Authority  
6N 38A Lookout Place  
1101 Market Street  
Chattanooga, Tennessee 37402-2801

Dear Mr. White:

Subject: Issuance of Amendment No.46 to Facility Operating License  
No. DPR-77 and Amendment No. 38 to Facility Operating  
License No. DPR-79 - Sequoyah Nuclear Plant, Units 1 and 2

The Nuclear Regulatory Commission has issued the enclosed Amendment No. 46 to Facility Operating License No. DPR-77 and Amendment No. 38 to Facility Operating License No. DPR-79. These amendments are in response to your request dated January 25, 1984. Other changes requested in that letter will be addressed in a future amendment.

The amendments change the Technical Specifications (TS) to include the reactor vessel level instrumentation system in the Accident Monitoring TS. The amendments are effective as of their date of issuance. This letter should not be construed as an authorization to commence operations prior to the Tennessee Valley Authority appropriately addressing the concerns identified in the 50.54(f) letter dated September 17, 1985.

A copy of the related safety evaluation supporting Amendment No.46 to Facility Operating License DPR-77 and Amendment No.38 to Facility Operating License DPR-79 is enclosed.

Notice of issuance will be included in the Commission's next bi-weekly Federal Register notice.

Sincerely,

151  
Carl R. Stahle, Project Manager  
PWR Project Directorate #4  
Division of PWR Licensing-A

Enclosures:

1. Amendment No.46 to DPR-77
2. Amendment No.38 to DPR-79
3. Safety Evaluation

cc w/enclosures: See next page

\* See previous concurrences

PWR#4/DPWR-A  
\*MDuncan/mac  
07/29/86

PWR#4/DPWR-A  
\*JHolonich  
07/29/86

PWR#4/DPWR-A  
\*CStahle  
08/04/86

PWR#4/DPWR-A  
BJYoungblood  
9/16/86

8609180387 860916  
PDR ADOCK 05000327  
P PDR

Mr. S. A. White  
Tennessee Valley Authority

Sequoyah Nuclear Plant

cc:  
Tennessee Department of Public  
Health  
ATTN: Director, Bureau of  
Environmental Health Services  
Cordell Hull Building  
Nashville, Tennessee 37219

Regional Administrator, Region II  
U.S. Nuclear Regulatory Commission,  
101 Marietta Street, N.W., Suite 2900  
Atlanta, Georgia 30323

W. C. Drotleff  
ATTN: J. A. Raulston  
Tennessee Valley Authority  
400 West Summit Hill Drive, W12 A12  
Knoxville, Tennessee 37902

Mr. Michael H. Mobley, Director  
Division of Radiological Health  
T.E.R.R.A. Building  
150 9th Avenue North  
Nashville, Tennessee 37203

Mr. Bob Faas  
Westinghouse Electric Corp.  
P.O. Box 355  
Pittsburgh, Pennsylvania 15230

County Judge  
Hamilton County Courthouse  
Chattanooga, Tennessee 37402

R. L. Gridley  
Tennessee Valley Authority  
5N 157B Lookout Place  
Chattanooga, Tennessee 37402-2801

M. R. Harding  
Tennessee Valley Authority  
Sequoyah Nuclear Plant  
P.O. Box 2000  
Soddy Daisy, Tennessee 37379

Resident Inspector/Sequoyah NPS  
c/o U.S. Nuclear Regulatory Commission  
2600 Igou Ferry Road  
Soddy Daisy, Tennessee 37379

September 16, 1986

AMENDMENT NO. 46 TO FACILITY OPERATING LICENSE NO. DPR-77 - Sequoyah Nuclear Plant  
Unit 1  
AMENDMENT NO. 38 TO FACILITY OPERATING LICENSE NO. DPR-79 - Sequoyah Nuclear Plant  
Unit 2

DISTRIBUTION w/ enclosures:

Docket No. 50-327/328

NRC PDR  
Local PDR  
NSIC  
PRC System  
PD#4 Reading File  
C. Stahle  
M. Duncan  
OGC-Beth  
R. Diggs, ADM  
T. Barnhart (8)  
E.L. Jordan, DEQA:I&E  
L.J. Harmon, I&E  
J. Youngblood  
J. Holonich  
N. Thompson  
E. Butcher  
W. Jones  
H. Denton  
J. Taylor  
G. Zech  
B. Hayes  
S. Weise. RII



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

TENNESSEE VALLEY AUTHORITY

DOCKET NO. 50-327

SEQUOYAH NUCLEAR PLANT, UNIT 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 46  
License No. DPR-77

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment to the Sequoyah Nuclear Plant, Unit 1 (the facility) Facility Operating License No. DPR-77 filed by the Tennessee Valley Authority (licensee), dated January 25, 1984, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's regulations as set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the license, as amended, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is hereby amended by page changes to the Appendix A Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-77 is hereby amended to read as follows:

8609180393 860916  
PDR ADDCK 05000327  
P PDR

(2) Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 46 are hereby incorporated into the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

151

B. J. Youngblood, Director  
PWR Project Directorate #4  
Division of PWR Licensing-A

Attachment"  
Appendix A Technical  
Specification Changes

Date of Issuance: September 16, 1986

PWR#4/DPWR-A  
MDuncan/mac  
7/29/86

PWR#4/DPWR-A  
JHolonich  
8/1/86

PWR#4/DPWR-A  
CStahle  
5/1/86

OGC/BETH  
8/17/86  
PWR#4/DPWR-A  
BJYoungblood  
9/16/86

ATTACHMENT TO LICENSE AMENDMENT NO. 46

FACILITY OPERATING LICENSE NO. DPR-77

DOCKET NO. 50-327

Replace the following pages of the Appendix "A" Technical Specifications with the enclosed pages. The revised pages are identified by Amendment number and contain vertical lines indicating the areas of change.

Amended  
Page

3/4 3-56

3/4 3-57

TABLE 3.3-10

ACCIDENT MONITORING INSTRUMENTATION

<u>INSTRUMENT</u>	<u>REQUIRED NO. OF CHANNELS</u>	<u>MINIMUM CHANNELS OPERABLE</u>
1. Reactor Coolant T <sub>Hot</sub> (Wide Range)	2	1
2. Reactor Coolant T <sub>Cold</sub> (Wide Range)	2	1
3. Containment Pressure (Wide Range)	2	1
4. Refueling Water Storage Tank Level	2	1
5. Reactor Coolant Pressure (Wide Range)	2	1
6. Pressurizer Level (Wide Range)	2	1
7. Steam Line Pressure	2/steam line	1/steam line
8. Steam Generator Level - (Wide Range)	1/steam generator	1/steam generator
9. Steam Generator Level - (Narrow Range)	1/steam generator	1/steam generator
10. Auxiliary Feedwater Flow Rate	1/pump	1/pump
11. Reactor Coolant System Subcooling Margin Monitor	1	0
12. Pressurizer PORV Position Indicator*	2/valve#	1/valve
13. Pressurizer PORV Block Valve Position Indicator**	2/valve	1/valve
14. Safety Valve Position Indicator	2/valve#	1/valve
°15. Containment Water Level (Wide Range)	2	1
16. In Core Thermocouples	4/core quadrant	2/core quadrant
17. Reactor Vessel Level Instrumentation System***	2	1

\*Not applicable if the associated block valve is in the closed position.

\*\*Not applicable if the block valve is verified in the closed position with power to the valve operator removed.

\*\*\*This Technical Specification and surveillance requirement will not be implemented until Sequoyah Specific Instructions are developed for the use of this system as committed to in the TVA response to Supplement 1 of NUREG-0737.

#At least one channel shall be the acoustic monitors.

TABLE 4.3-7

ACCIDENT MONITORING INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>INSTRUMENT</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL CALIBRATION</u>
1. Reactor Coolant T <sub>Hot</sub> (Wide Range)	M	R
2. Reactor Coolant T <sub>Cold</sub> (Wide Range)	M	R
3. Containment Pressure (Wide Range)	M	R
4. Refueling Water Storage Tank Level	M	R
5. Reactor Coolant Pressure (Wide Range)	M	R
6. Pressurizer Level	M	R
7. Steam Line Pressure	M	R
8. Steam Generator Level - Wide	M	R
9. Steam Generator Level - Narrow	M	R
10. Auxiliary Feedwater Flowrate	M	R
11. Reactor Coolant System Subcooling Margin Monitor	M	R
12. Pressurizer PORV Position Indicator	M	R
13. Pressurizer PORV Block Valve Position Indicator	M	R
14. Safety Valve Position Indicator	M	R
15. Containment Water Level (Wide Range)	M	R
16. In Core Thermocouples	M	R
17. Reactor Vessel Level Instrumentation**	M	R

\*\*This Technical Specification and surveillance requirement will not be implemented until Sequoyah Specific Instructions are developed for the use of this system as committed to in the TVA response to Supplement 1 of NUREG-0737.





UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

TENNESSEE VALLEY AUTHORITY

DOCKET NO. 50-328

SEQUOYAH NUCLEAR PLANT, UNIT 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 38  
License No. DPR-79

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment to the Sequoyah Nuclear Plant, Unit 2 (the facility) Facility Operating License No. DPR-79 filed by the Tennessee Valley Authority (licensee), dated January 25, 1984, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's regulations as set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the license, as amended, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is hereby amended by page changes to the Appendix A Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-79 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 38 are hereby incorporated into the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

151

B. J. Youngblood, Director  
PWR Project Directorate #4  
Division of PWR Licensing-A

Attachment  
Appendix A Technical  
Specification Changes

Date of Issuance: September 16, 1986

PWR#4/DPWR-A  
MDuncan/mac  
7/29/86

PWR#4/DPWR-A  
JHornich  
7/29/86

PWR#4/DPWR-A  
CStahle  
5/11/86

OGC/BETH PWR#4/DPWR-A  
BYoungblood  
8/8/86 9/16/86

W. Youngblood  
9/16/86

ATTACHMENT TO LICENSE AMENDMENT NO. 38

FACILITY OPERATING LICENSE NO. DPR-79

DOCKET NO. 50-328

Replace the following pages of the Appendix "A" Technical Specifications with the enclosed pages. The revised pages are identified by Amendment number and contain vertical lines indicating the areas of change.

Amended  
Page

3/4 3-57  
3/4 3-58

TABLE 3.3-10

ACCIDENT MONITORING INSTRUMENTATION

<u>INSTRUMENT</u>	<u>REQUIRED NO. OF CHANNELS</u>	<u>MINIMUM CHANNELS OPERABLE</u>
1. Reactor Coolant T <sub>Hot</sub> (Wide Range)	2	1
2. Reactor Coolant T <sub>Cold</sub> (Wide Range)	2	1
3. Containment Pressure (Wide Range)	2	1
4. Refueling Water Storage Tank Level	2	1
5. Reactor Coolant Pressure (Wide Range)	2	1
6. Pressurizer Level (Wide Range)	2	1
7. Steam Line Pressure	2/steam line	1/steam line
8. Steam Generator Level - (Wide Range)	1/steam generator	1/steam generator
9. Steam Generator Level - (Narrow Range)	1/steam generator	1/steam generator
10. Auxiliary Feedwater Flow Rate	1/pump	1/pump
11. Reactor Coolant System Subcooling Margin Monitor	1	0
12. Pressurizer PORV Position Indicator*	2/valve#	1/valve
13. Pressurizer PORV Block Valve Position Indicator**	2/valve	1/valve
14. Safety Valve Position Indicator	2/valve#	1/valve
°15. Containment Water Level (Wide Range)	2	1
16. In Core Thermocouples	4/core quadrant	2/core quadrant
17. Reactor Vessel Level Instrumentation System***	2	1

\*Not applicable if the associated block valve is in the closed position.

\*\*Not applicable if the block valve is verified in the closed position with power to the valve operator removed.

\*\*\*This Technical Specification and surveillance requirement will not be implemented until Sequoyah Specific Instructions are developed for the use of this system as committed to in the TVA response to Supplement 1 of NUREG-0737.

# At least one channel shall be the acoustic monitors.

TABLE 4.3-7

ACCIDENT MONITORING INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>INSTRUMENT</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL CALIBRATION</u>
1. Reactor Coolant T <sub>Hot</sub> (Wide Range)	M	R
2. Reactor Coolant T <sub>Cold</sub> (Wide Range)	M	R
3. Containment Pressure (Wide Range)	M	R
4. Refueling Water Storage Tank Level	M	R
5. Reactor Coolant Pressure (Wide Range)	M	R
6. Pressurizer Level	M	R
7. Steam Line Pressure	M	R
8. Steam Generator Level - (Wide)	M	R
9. Steam Generator Level - (Narrow)	M	R
10. Auxiliary Feedwater Flowrate	M	R
11. Reactor Coolant System Subcooling Margin Monitor	M	R
12. Pressurizer PORV Position Indicator	M	R
13. Pressurizer PORV Block Valve Position Indicator	M	R
14. Safety Valve Position Indicator	M	R
15. Containment Water Level (Wide Range)	M	R
16. In Core Thermocouples	M	R
17. Reactor Vessel Level Instrumentation System*	M	R

\*This Technical Specification and surveillance requirement will not be implemented until Sequoyah Specific Instructions are developed for the use of this system as committed to in the TVA response to Supplement 1 of NUREG-0737.



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION  
RELATED TO AMENDMENT NO.46 TO FACILITY OPERATING LICENSE DPR-77  
AND AMENDMENT NO.38 TO FACILITY OPERATING LICENSE DPR-79  
TENNESSEE VALLEY AUTHORITY

INTRODUCTION

The Tennessee Valley Authority (TVA) in a submittal dated January 25, 1984 requested a license amendment which would include the reactor vessel level instrumentation system (RVLIS) in the Accident Monitoring Instrumentation Technical Specifications.

EVALUATION

The staff has reviewed this request by comparing it to the requirements provided in Generic Letter 83-37. Based on the result of its review, the staff has concluded the following:

1. The surveillance requirements for channel check and channel calibration as specified in Item 17 of Table 4.3-7, "Accident Monitoring Instrumentation Surveillance Requirements," meet the requirements of Generic Letter 83-37 and are acceptable.
2. The required number of channels and minimum number of channels as specified in Item 17 of Table 3.3-10, "Accident Monitoring Instrumentation," are in accordance with the recommendation of Generic Letter 83-37 and also are acceptable.

In summary, the staff has found the proposed technical specification change to add RVLIS to Accident Monitoring Instrumentation acceptable. This proposed technical specification change should be implemented following the startup from the Cycle 3 refueling outage for each unit.

After upgrading of the Subcooling Margin Monitors (SMM) is completed, the technical specification change for SMM on Item 11 of Tables 3.3-10 and 4.3-7 and its action statements should also be changed in accordance with the Generic Letter No. 83-37 requirements.

ENVIRONMENTAL CONSIDERATION

These amendments involve changes in the use of facility components located within the restricted area as defined in 10 CFR Part 20. The staff has determined that the amendments involve no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously

8609180396 860916  
PDR ADDOCK 05000327  
P PDR

issued a proposed finding that these amendments involve no significant hazards consideration, and there has been no public comment on such finding. Accordingly, the amendments meet the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b) no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendments.

#### IV. CONCLUSION

The Commission made a proposed determination that the amendments involve no significant hazards consideration which was published in the Federal Register on September 28, 1984 (49 FR 38410) and consulted with the state of Tennessee. No public comments were received, and the state of Tennessee did not have any comments.

We have concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and (2) such activities will be conducted in compliance with the Commission's regulations and the issuance of these amendments will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributors: Carl R. Stahle, PWR#4, DPWR-A  
Joe Holonich, PWR#4, DPWR-A  
R. Karsch, RSB

Dated: September 16, 1986