

REACTIVITY CONTROL SYSTEMS

3/4.1.2 BORATION SYSTEMS

FLOW PATHS – SHUTDOWN

LIMITING CONDITION FOR OPERATION

- 3.1.2.1 As a minimum, one of the following boron injection flow paths shall be OPERABLE and capable of being powered from an OPERABLE emergency power source.
- a. A flow path from the boric acid makeup tank via either a boric acid pump or a gravity feed connection and any charging pump to the Reactor Coolant System if only the boric acid makeup tank in Specification 3.1.2.7a is OPERABLE, or
 - b. The flow path from the refueling water tank via either a charging pump or a high pressure safety injection pump* to the Reactor Coolant System if only the refueling water tank in Specification 3.1.2.7b is OPERABLE.

APPLICABILITY: MODES 5 and 6.

ACTION:

With none of the above flow paths OPERABLE, suspend all operations involving CORE ALTERATIONS or positive reactivity changes** until at least one injection path is restored to OPERABLE status.

SURVEILLANCE REQUIREMENTS

- 4.1.2.1 At least one of the above required flow paths shall be demonstrated OPERABLE:
- a. At least once per 31 days by verifying that each valve (manual, power operated or automatic) in the flow path that is not locked, sealed, or otherwise secured in position, is in its correct position.

* The flow path from the RWT to the RCS via a single HPSI pump shall only be established if: (a) the RCS pressure boundary does not exist, or (b) RCS pressure boundary integrity exists and no charging pumps are operable. In the latter case: 1) all charging pumps shall be disabled; 2) heatup and cooldown rates shall be limited in accordance with Figure 3.1-1b; and 3) at RCS temperatures below 115°F, any two of the following valves in the operable HPSI header shall be verified closed and have their power removed:

<u>High Pressure Header</u>	<u>Auxiliary Header</u>
HCV-3616	HCV-3617
HCV-3626	HCV-3627
HCV-3636	HCV-3637
HCV-3646	HCV-3647

** Plant temperature changes are allowed provided the temperature change is accounted for in the calculated SHUTDOWN MARGIN.

REACTIVITY CONTROL SYSTEMS

CHARGING PUMPS – SHUTDOWN

LIMITING CONDITION FOR OPERATION

- 3.1.2.3 At least one charging pump or high pressure safety injection pump* in the boron injection flow path required OPERABLE pursuant to Specification 3.1.2.1 shall be OPERABLE and capable of being powered from an OPERABLE emergency bus.

APPLICABILITY: MODES 5 and 6.

ACTION:

With no charging pump or high pressure safety injection pump* OPERABLE, suspend all operations involving CORE ALTERATIONS or positive reactivity changes** until at least one of the required pumps is restored to OPERABLE status.

SURVEILLANCE REQUIREMENTS

- 4.1.2.3 At least one of the above required pumps shall be demonstrated OPERABLE by verifying the charging pump develops a flow rate of greater than or equal to 40 gpm or the high pressure safety injection pump develops a total head of greater than or equal to 2571 ft. when tested pursuant to the Inservice Testing Program.

-
- * The flow path from the RWT to the RCS via a single HPSI pump shall be established only if: (a) the RCS pressure boundary does not exist, or (b) RCS pressure boundary integrity exists and no charging pumps are operable. In the latter case: 1) all charging pumps shall be disabled; 2) heatup and cooldown rates shall be limited in accordance with Figure 3.1-1b; and 3) at RCS temperatures below 115°F, any two of the following valves in the operable HPSI header shall be verified closed and have their power removed:

<u>High Pressure Header</u>	<u>Auxiliary Header</u>
HCV-3616	HCV-3617
HCV-3626	HCV-3627
HCV-3636	HCV-3637
HCV-3646	HCV-3647

- ** Plant temperature changes are allowed provided the temperature change is accounted for in the calculated SHUTDOWN MARGIN.

REACTIVITY CONTROL SYSTEMS

BORIC ACID PUMPS – SHUTDOWN

LIMITING CONDITION FOR OPERATION

- 3.1.2.5 At least one boric acid pump shall be OPERABLE if only the flow path through the boric acid pump in Specification 3.1.2.1a above, is OPERABLE.

APPLICABILITY: MODES 5 and 6.

ACTION:

With no boric acid pump OPERABLE as required to complete the flow path of Specification 3.1.2.1a, suspend all operations involving CORE ALTERATIONS or positive reactivity changes* until at least one boric acid pump is restored to OPERABLE status.

SURVEILLANCE REQUIREMENTS

- 4.1.2.5 The above required boric acid pump shall be demonstrated OPERABLE by verifying that on recirculation flow, the pump develops a discharge pressure of ≥ 75 psig when tested pursuant to the Inservice Testing Program.

* Plant temperature changes are allowed provided the temperature change is accounted for in the calculated SHUTDOWN MARGIN.

REACTIVITY CONTROL SYSTEMS

BORATED WATER SOURCES – SHUTDOWN

LIMITING CONDITION FOR OPERATION

3.1.2.7 As a minimum, one of the following borated water sources shall be OPERABLE:

- a. One boric acid makeup tank with a minimum borated water volume of 3650 gallons of 2.5 to 3.5 weight percent boric acid (4371 to 6119 ppm boron).
- b. The refueling water tank with:
 1. A minimum contained volume of 125,000 gallons,
 2. A minimum boron concentration of 1720 ppm, and
 3. A minimum solution temperature of 40°F.

APPLICABILITY: MODES 5 and 6.

ACTION:

With no borated water sources OPERABLE, suspend all operations involving positive reactivity changes* until at least one borated water source is restored to OPERABLE status.

SURVEILLANCE REQUIREMENTS

4.1.2.7 The above required borated water source shall be demonstrated OPERABLE:

- a. At least once per 7 days by:
 1. Verifying the boron concentration of the water,
 2. Verifying the water level of the tank, and.
- b. At least once per 24 hours by verifying the RWT temperature when it is the source of borated water and the site ambient air temperature is < 40°F.
- c. At least once per 24 hours when the Reactor Auxiliary Building air temperature is less than 55°F by verifying that the Boric Acid Makeup Tank solution temperature is greater than 55°F when that Boric Acid Makeup Tank is required to be OPERABLE.

* Plant temperature changes are allowed provided the temperature change is accounted for in the calculated SHUTDOWN MARGIN.

REACTOR COOLANT SYSTEM

HOT STANDBY

LIMITING CONDITION FOR OPERATION

3.4.1.2 The reactor coolant loops listed below shall be OPERABLE and at least one of these reactor coolant loops shall be in operation.*

- a. Reactor Coolant Loop A and its associated steam generator and at least one associated reactor coolant pump.
- b. Reactor Coolant Loop B and its associated steam generator and at least one associated reactor coolant pump.

APPLICABILITY: MODE 3.

ACTION:

- a. With less than the above required reactor coolant loops OPERABLE, restore the required loops to OPERABLE status within 72 hours or be in HOT SHUTDOWN within the next 12 hours.
- b. With no reactor coolant loop in operation, suspend operations that would cause introduction into the RCS, coolant with boron concentration less than required to meet SHUTDOWN MARGIN of Technical Specification 3.1.1.1 and within one (1) hour initiate corrective action to return the required reactor coolant loop to operation.

SURVEILLANCE REQUIREMENTS

4.4.1.2.1 At least the above required reactor coolant pumps, if not in operation, shall be determined to be OPERABLE once per 7 days by verifying correct breaker alignments and indicated power availability.

4.4.1.2.2 At least one reactor coolant loop shall be verified to be in operation and circulating reactor coolant at least once per 12 hours.

4.4.1.2.3 The required steam generators shall be determined OPERABLE by verifying the secondary side water level to be $\geq 10\%$ of narrow range indication at least once per 12 hours.

* All reactor coolant pumps may be de-energized for up to 1 hour provided (1) no operations are permitted that would cause introduction into the RCS, coolant with boron concentration less than required to meet the SHUTDOWN MARGIN of Technical Specification 3.1.1.1 and (2) core outlet temperature is maintained at least 10°F below saturation temperature.

REACTOR COOLANT SYSTEM

HOT SHUTDOWN

LIMITING CONDITION FOR OPERATION

3.4.1.3 At least two of the loops listed below shall be OPERABLE and at least one reactor coolant or shutdown cooling loop shall be in operation.*

- a. Reactor Coolant Loop A and its associated steam generator and at least one associated reactor coolant pump,
- b. Reactor Coolant Loop B and its associated steam generator and at least one associated reactor coolant pump,
- c. Shutdown Cooling Loop A,
- d. Shutdown Cooling Loop B.

APPLICABILITY: MODE 4.

ACTION:

- a. With less than the above required reactor coolant or shutdown cooling loops OPERABLE, within one (1) hour initiate corrective action to return the required loops to OPERABLE status. If the remaining OPERABLE loop is a shutdown cooling loop, be in COLD SHUTDOWN within 30 hours.
- b. With no reactor coolant or shutdown cooling loop in operation, suspend operations that would cause introduction into the RCS, coolant with boron concentration less than required to meet SHUTDOWN MARGIN of Technical Specification 3.1.1.1 and within one (1) hour initiate corrective action to return the required reactor coolant loop to operation.

* All reactor coolant pumps and shutdown cooling pumps may be de-energized for up to 1 hour provided (1) no operations are permitted that would cause introduction into the RCS, coolant with boron concentration less than required to meet the SHUTDOWN MARGIN of Technical Specification 3.1.1.1 and (2) core outlet temperature is maintained at least 10°F below saturation temperature.

REACTOR COOLANT SYSTEM

COLD SHUTDOWN – LOOPS FILLED

LIMITING CONDITION FOR OPERATION

3.4.1.4.1 At least one shutdown cooling loop shall be OPERABLE and in operation and either:

- a. One additional shutdown cooling loop shall be OPERABLE[#], or
- b. The secondary side water level of at least two steam generators shall be greater than 10% of narrow range indication.

APPLICABILITY: MODE 5 with reactor coolant loops filled^{##}.

ACTION:

- a. With less than the above required loops OPERABLE or with less than the required steam generator level, within one (1) hour initiate corrective action to return the required loops to OPERABLE status or to restore the required level.
- b. With no shutdown cooling loop in operation, suspend operations that would cause introduction into the RCS, coolant with boron concentration less than required to meet SHUTDOWN MARGIN of Technical Specification 3.1.1.2 and within one (1) hour initiate corrective action to return the required shutdown loop to operation.

SURVEILLANCE REQUIREMENTS

4.4.1.4.1.1 The secondary side water level of at least two steam generators when required shall be determined to be within limits at least once per 12 hours.

4.4.1.4.1.2 At least one shutdown cooling loop shall be determined to be in operation and circulating reactor coolant at least once per 12 hours.

* The shutdown cooling pump may be de-energized for up to 1 hour provided 1) no operations are permitted that would cause introduction into the RCS, coolant with boron concentration less than required to meet the SHUTDOWN MARGIN of Technical Specification 3.1.1.2 and 2) core outlet temperature is maintained at least 10°F below saturation temperature.

One shutdown cooling loop may be inoperable for up to 2 hours for surveillance testing provided the other shutdown cooling loop is OPERABLE and in operation.

A reactor coolant pump shall not be started with two idle loops unless the secondary water temperature of each steam generator is less than 30°F above each of the Reactor Coolant System cold leg temperatures.

REACTOR COOLANT SYSTEM

COLD SHUTDOWN – LOOPS NOT FILLED

LIMITING CONDITION FOR OPERATION

3.4.1.4.2 Two shutdown cooling loops shall be OPERABLE[#] and at least one shutdown cooling loop shall be in operation*.

APPLICABILITY: MODE 5 with reactor coolant loops not filled.

ACTION:

- a. With less than the above required loops OPERABLE, within one (1) hour initiate corrective action to return the required loops to OPERABLE status.
- b. With no shutdown cooling loop in operation, suspend operations that would cause introduction into the RCS, coolant with boron concentration less than required to meet SHUTDOWN MARGIN of Technical Specification 3.1.1.2 and within one (1) hour initiate corrective action to return the required shutdown cooling loop to operation.

SURVEILLANCE REQUIREMENTS

4.4.1.4.2 At least one shutdown cooling loop shall be determined to be in operation and circulating reactor coolant at least once per 12 hours.

One shutdown cooling loop may be inoperable for up to 2 hours for surveillance testing provided the other shutdown cooling loop is OPERABLE and in operation.

* The shutdown cooling pump may be de-energized for up to 1 hour provided 1) no operations are permitted that would cause introduction into the RCS, coolant with boron concentration less than required to meet the SHUTDOWN MARGIN of Technical Specification 3.1.1.2 and 2) core outlet temperature is maintained at least 10°F below saturation temperature.

ELECTRICAL POWER SYSTEMS

SHUTDOWN

LIMITING CONDITION FOR OPERATION

3.8.1.2 As a minimum, the following A.C. electrical power sources shall be OPERABLE:

- a. One circuit between the offsite transmission network and the onsite Class 1E distribution system, and
- b. One diesel generator set with:
 1. Engine-mounted fuel tanks containing a minimum of 152 gallons of fuel,
 2. A fuel storage system containing a minimum of 16,450 gallons of fuel, and
 3. A fuel transfer pump.

APPLICABILITY: MODES 5 and 6.

ACTION:

With less than the above minimum required A.C. electrical power sources OPERABLE, immediately suspend all operations involving CORE ALTERATIONS, operations involving positive reactivity additions that could result in loss of required SHUTDOWN MARGIN or boron concentration, movement of irradiated fuel, or crane operation with loads over the fuel storage pool. In addition, when in MODE 5 with the reactor coolant loops not filled, or in MODE 6 with the water level less than 23 feet above the top of irradiated fuel assemblies seated within the reactor vessel, immediately initiate corrective action to restore the required sources to OPERABLE status as soon as possible.

SURVEILLANCE REQUIREMENTS

4.8.1.2.1 The above required A.C. electrical power sources shall be demonstrated OPERABLE by the performance of each of the Surveillance Requirements of 4.8.1.1.1 and 4.8.1.1.2 except for requirement 4.8.1.1.2a.5.

REFUELING OPERATIONS

INSTRUMENTATION

LIMITING CONDITION FOR OPERATION

3.9.2 As a minimum, two wide range logarithmic neutron flux monitors shall be operating, each with continuous visual indication in the control room and one with audible indication in the containment.

APPLICABILITY: MODE 6.

ACTION:

With the requirements of the above specification not satisfied, immediately suspend all operations involving CORE ALTERATIONS or operations that would cause introduction into the RCS, coolant with boron concentration less than required to meet the boron concentration of Technical Specification 3.9.1. The provisions of Specification 3.0.3 are not applicable.

SURVEILLANCE REQUIREMENTS

4.9.2 Each wide range logarithmic neutron flux monitor shall be demonstrated OPERABLE by performance of:

- a. A CHANNEL FUNCTIONAL TEST at least once per 7 days.
- b. A CHANNEL FUNCTIONAL TEST within 8 hours prior to the start of CORE ALTERATIONS, and
- c. A CHANNEL CHECK at least once per 12 hours during CORE ALTERATIONS.

REFUELING OPERATIONS

SHUTDOWN COOLING AND COOLANT CIRCULATION

HIGH WATER LEVEL

LIMITING CONDITION FOR OPERATION

3.9.8.1 At least one shutdown cooling loop shall be OPERABLE and in operation*.

APPLICABILITY: MODE 6 when the water level above the top of irradiated fuel assemblies seated within the reactor pressure vessel is greater than or equal to 23 feet.

ACTION:

- a. With less than one shutdown cooling loop in operation, suspend all operations involving an increase in reactor decay heat load or operations that would cause introduction into the RCS, coolant with boron concentration less than required to meet the boron concentration of Technical Specification 3.9.1. Close all containment penetrations providing direct access from the containment atmosphere to the outside atmosphere within 4 hours.
- b. The provisions of Specification 3.0.3 are not applicable.

SURVEILLANCE REQUIREMENTS

4.9.8.1 At least one shutdown cooling loop shall be verified to be in operation and circulating reactor coolant at a flow rate of greater than or equal to 3000 gpm at least once per 12 hours.

* The shutdown cooling loop may be removed from operation for up to 1 hour per 8 hour period during the performance of CORE ALTERATIONS in the vicinity of reactor pressure vessel hot legs, provided no operations are permitted that would cause introduction into the RCS, coolant with boron concentration less than required to meet the SHUT DOWN MARGIN of Technical Specification 3.9.1.

REFUELING OPERATIONS

LOW WATER LEVEL

LIMITING CONDITION FOR OPERATION

3.9.8.2 Two independent shutdown cooling loops shall be OPERABLE and at least one shutdown cooling loop shall be in operation.

APPLICABILITY: MODE 6 when the water level above the top of irradiated fuel assemblies seated within the reactor pressure vessel is less than 23 feet.

ACTION:

- a. With less than the required shutdown cooling loops OPERABLE, within one (1) hour 1) initiate corrective action to return the required loops to OPERABLE status, or 2) establish greater than or equal to 23 feet of water above irradiated fuel assemblies seated within the reactor pressure vessel.
- b. With no shutdown cooling loop in operation, suspend operations that would cause introduction into the RCS, coolant with boron concentration less than required to meet the boron concentration of Technical Specification 3.9.1. and within one (1) hour initiate corrective action to return the required shutdown cooling loop to operation. Close all containment penetrations providing direct access from the containment atmosphere to the outside atmosphere within 4 hours.
- c. The provisions of Specification 3.0.3 are not applicable.

SURVEILLANCE REQUIREMENTS

4.9.8.2 At least one shutdown cooling loop shall be verified to be in operation and circulating reactor coolant at a flow rate of greater than or equal to 3000 gpm at least once per 12 hours.

REACTIVITY CONTROL SYSTEMS

3/4.1.2 BORATION SYSTEMS

FLOW PATHS – SHUTDOWN

LIMITING CONDITION FOR OPERATION

3.1.2.1 As a minimum, one of the following boron injection flow paths shall be OPERABLE and capable of being powered from an OPERABLE emergency power source:

- a. A flow path from the boric acid makeup tank via either a boric acid makeup pump or a gravity feed connection and any charging pump to the Reactor Coolant System if only the boric acid makeup tank in Specification 3.1.2.7a. is OPERABLE, or
- b. The flow path from the refueling water tank via either a charging pump or a high pressure safety injection pump to the Reactor Coolant System if only the refueling water tank in Specification 3.1.2.7b. is OPERABLE.

APPLICABILITY: MODES 5 and 6.

ACTION:

With none of the above flow paths OPERABLE or capable of being powered from an OPERABLE emergency power source, suspend all operations involving CORE ALTERATIONS or positive reactivity changes*.

SURVEILLANCE REQUIREMENTS

4.1.2.1 At least one of the above required flow paths shall be demonstrated OPERABLE:

- a. At least once per 31 days by verifying that each valve (manual, power-operated, or automatic) in the flow path that is not locked, sealed, or otherwise secured in position, is in its correct position.
- b. At least once per 24 hours when the Reactor Auxiliary Building air temperature is less than 55°F by verifying that the Boric Acid Makeup Tank solution temperature is greater than 55°F (when the flow path from the Boric Acid Makeup Tank is used).

* Plant temperature changes are allowed provided the temperature change is accounted for in the calculated SHUTDOWN MARGIN.

REACTIVITY CONTROL SYSTEMS

CHARGING PUMPS – SHUTDOWN

LIMITING CONDITION FOR OPERATION

- 3.1.2.3 At least one charging pump or high pressure safety injection pump in the boron injection flow path required OPERABLE pursuant to Specification 3.1.2.1 shall be OPERABLE and capable of being powered from an OPERABLE emergency power source.

APPLICABILITY: MODES 5 and 6.

ACTION:

With no charging pump or high pressure safety injection pump OPERABLE or capable of being powered from an OPERABLE emergency power source, suspend all operations involving CORE ALTERATIONS or positive reactivity changes*.

SURVEILLANCE REQUIREMENTS

- 4.1.2.3 At least the above required pumps shall be demonstrated OPERABLE by verifying the charging pump develops a flow rate of greater than or equal to 40 gpm or the high pressure safety injection pump develops a total head of greater than or equal to 2854 ft. when tested pursuant to the Inservice Testing Program.

* Plant temperature changes are allowed provided the temperature change is accounted for in the calculated SHUTDOWN MARGIN.

REACTIVITY CONTROL SYSTEMS

BORIC ACID MAKEUP PUMPS – SHUTDOWN

LIMITING CONDITION FOR OPERATION

- 3.1.2.5 At least one boric acid makeup pump shall be OPERABLE and capable of being powered from an OPERABLE emergency bus if only the flow path through the boric acid pump in Specification 3.1.2.1a is OPERABLE.

APPLICABILITY: MODES 5 and 6.

ACTION:

With no boric acid pump OPERABLE as required to complete the flow path of Specification 3.1.2.1a, suspend all operations involving CORE ALTERATIONS or positive reactivity changes*.

SURVEILLANCE REQUIREMENTS

- 4.1.2.5 The above required boric acid makeup pump shall be demonstrated OPERABLE by verifying, that on recirculation flow, the pump develops a discharge pressure of greater than or equal to 90 psig when tested pursuant to the Inservice Testing Program.

* Plant temperature changes are allowed provided the temperature change is accounted for in the calculated SHUTDOWN MARGIN.

REACTIVITY CONTROL SYSTEMS

BORATED WATER SOURCES – SHUTDOWN

LIMITING CONDITION FOR OPERATION

3.1.2.7 As a minimum, one of the following borated water sources shall be OPERABLE:

- a. One boric acid makeup tank with a minimum borated water volume of 3550 gallons of 2.5 to 3.5 weight percent boric acid (4371 to 6119 ppm boron).
- b. The refueling water tank with:
 1. A minimum contained borated water volume of 125,000 gallons,
 2. A minimum boron concentration of 1720 ppm, and
 3. A solution temperature between 40°F and 120°F.

APPLICABILITY: MODES 5 and 6.

ACTION:

With no borated water sources OPERABLE, suspend all operations involving CORE ALTERATIONS or positive reactivity changes*.

SURVEILLANCE REQUIREMENTS

4.1.2.7 The above required borated water source shall be demonstrated OPERABLE:

- a. At least once per 7 days by:
 1. Verifying the boron concentration of the water,
 2. Verifying the contained borated water volume of the tank, and
- b. At least once per 24 hours by verifying the RWT temperature when it is the source of borated water and the outside air temperature is outside the range of 40°F and 120°F.
- c. At least once per 24 hours when the Reactor Auxiliary Building air temperature is less than 55°F, by verifying that the boric acid makeup tank solution temperature is greater than 55°F when that boric acid makeup tank is required to be OPERABLE.

* Plant temperature changes are allowed provided the temperature change is accounted for in the calculated SHUTDOWN MARGIN.

TABLE 3.3-1 (Continued)

ACTION STATEMENTS

ACTION 2 - (Continued)

- | | |
|-------------------------|---|
| 6. Cold Leg Temperature | Variable Power Level – High (RPS)
Thermal Margin/Low Pressure (RPS)
Local Power Density – High (RPS) |
| 7. Hot Leg Temperature | Variable Power Level – High (RPS)
Thermal Margin /Low Pressure (RPS)
Local Power Density – High (RPS) |

ACTION 3 - With the number of channels OPERABLE one less than required by the Minimum Channels OPERABLE requirement, suspend all operations involving positive reactivity changes*. Verify compliance with the SHUTDOWN MARGIN requirements of Specification 3.1.1.1 or 3.1.1.2, as applicable, within 1 hour and at least once per 12 hours thereafter.

ACTION 4 - With the number of channels OPERABLE one less than required by the Minimum Channels OPERABLE requirements, STARTUP and/or POWER OPERATION may continue provided the reactor trip breakers of the inoperable channel are placed in the tripped condition within 1 hour, otherwise, be in at least HOT STANDBY within 6 hours; however, one channel may be bypassed for up to 1 hour, provided the trip breakers of any inoperable channel are in the tripped condition, for surveillance testing per Specification 4.3.1.1.

ACTION 5 - With the number of OPERABLE channels one less than the Minimum Channels OPERABLE requirement restore the inoperable channel to OPERABLE status within 48 hours or open the reactor trip breakers within the next hour.

* Limited plant cooldown or boron dilution is allowed provided the change is accounted for in the calculated SHUTDOWN MARGIN.

REACTOR COOLANT SYSTEM

HOT STANDBY

LIMITING CONDITION FOR OPERATION

3.4.1.2 The Reactor Coolant loops listed below shall be OPERABLE and at least one of these Reactor Coolant loops shall be in operation.*

- a. Reactor Coolant Loop 2A and its associated steam generator and at least one associated Reactor Coolant pump.
- b. Reactor Coolant Loop 2B and its associated steam generator and at least one associated Reactor Coolant pump.

APPLICABILITY: MODE 3

ACTION:

- a. With less than the above required Reactor Coolant loops OPERABLE, restore the required loops to OPERABLE status within 72 hours or be in HOT SHUTDOWN within the next 12 hours.
- b. With no Reactor Coolant loop in operation, suspend operations that would cause introduction into the RCS, coolant with boron concentration less than required to meet SHUTDOWN MARGIN of Technical Specification 3.1.1.1 and immediately initiate corrective action to return the required Reactor Coolant loop to operation.

SURVEILLANCE REQUIREMENTS

4.4.1.2.1 At least the above required Reactor Coolant pumps, if not in operation, shall be determined to be OPERABLE once per 7 days by verifying correct breaker alignments and indicated power availability.

4.4.1.2.2 At least one Reactor Coolant loop shall be verified to be in operation and circulating reactor coolant at least once per 12 hours.

4.4.1.2.3 The required steam generator(s) shall be determined OPERABLE verifying the secondary side water level to be $\geq 10\%$ indicated narrow range level at least once per 12 hours.

* All Reactor Coolant pumps may be deenergized for up to 1 hour provided (1) no operations are permitted that would cause introduction into the RCS, coolant with boron concentration less than required to meet the SHUTDOWN MARGIN of Technical Specification 3.1.1.1 and (2) core outlet temperature is maintained at least 10°F below saturation temperature.

REACTOR COOLANT SYSTEM

HOT SHUTDOWN

LIMITING CONDITION FOR OPERATION

3.4.1.3 At least two of the loop(s)/train(s) listed below shall be OPERABLE and at least one Reactor Coolant and/or shutdown cooling loops shall be in operation.*

- a. Reactor Coolant Loop 2A and its associated steam generator and at least one associated Reactor Coolant pump,**
- b. Reactor Coolant Loop 2B and its associated steam generator and at least one associated Reactor Coolant pump,**
- c. Shutdown Cooling Train 2A,
- d. Shutdown Cooling Train 2B.

APPLICABILITY: MODE 4.

ACTION:

- a. With less than the above required Reactor Coolant and/or shutdown cooling loops OPERABLE, immediately initiate corrective action to return the required loops to OPERABLE status as soon as possible; if the remaining OPERABLE loop is a shutdown cooling loop, be in COLD SHUTDOWN within 30 hours.
- b. With no Reactor Coolant or shutdown cooling loop in operation, suspend operations that would cause introduction into the RCS, coolant with boron concentration less than required to meet SHUTDOWN MARGIN of Technical Specifications 3.1.1.1 and immediately initiate corrective action to return the required coolant loop to operation.

* All Reactor Coolant pumps and shutdown cooling pumps may be de-energized for up to 1 hour provided (1) no operations are permitted that would cause introduction into the RCS, coolant with boron concentration less than required to meet the SHUTDOWN MARGIN of Technical Specification 3.1.1.1 and (2) core outlet temperature is maintained at least 10°F below saturation temperature.

** A Reactor Coolant pump shall not be started with two idle loops and one or more of the Reactor Coolant System cold leg temperatures less than or equal to that specified in Table 3.4-3 unless the secondary water temperature of each steam generator is less than 40°F above each of the Reactor Coolant System cold leg temperatures.

REACTOR COOLANT SYSTEM

COLD SHUTDOWN – LOOPS FILLED

LIMITING CONDITION FOR OPERATION

3.4.1.4.1 At least one shutdown cooling loop shall be OPERABLE and in operation*, and either:

- a. One additional shutdown cooling loop shall be OPERABLE[#], or
- b. The secondary side water level of at least two steam generators shall be greater than 10% indicated narrow range level.

APPLICABILITY: MODE 5 with Reactor Coolant loops filled^{##}.

ACTION:

- a. With one of the shutdown cooling loops inoperable and with less than the required steam generator level, immediately initiate corrective action to return the inoperable shutdown cooling loop to OPERABLE status or to restore the required steam generator level as soon as possible.
- b. With no shutdown cooling loop in operation, suspend operations that would cause introduction into the RCS, coolant with boron concentration less than required to meet SHUTDOWN MARGIN of Technical Specification 3.1.1.2 and immediately initiate corrective action to return the required shutdown cooling loop to operation.

SURVEILLANCE REQUIREMENTS

4.4.1.4.1.1 The secondary side water level of at least two steam generators when required shall be determined to be within limits at least once per 12 hours.

4.4.1.4.1.2 At least one shutdown cooling loop shall be determined to be in operation and circulating reactor coolant at least once per 12 hours.

* The shutdown cooling pump may be de-energized for up to 1 hour provided
1) no operations are permitted that would cause introduction into the RCS, coolant with boron concentration less than required to meet the SHUTDOWN MARGIN of Technical Specification 3.1.1.2 and 2) core outlet temperature is maintained at least 10°F below saturation temperature.

One shutdown cooling loop may be inoperable for up to 2 hours for surveillance testing provided the other shutdown cooling loop is OPERABLE and in operation.

A Reactor Coolant pump shall not be started with two idle loops unless the secondary water temperature of each steam generator is less than 40°F above each of the Reactor Coolant System cold leg temperatures.

REACTOR COOLANT SYSTEM

COLD SHUTDOWN – LOOPS NOT FILLED

LIMITING CONDITION FOR OPERATION

3.4.1.4.2 Two shutdown cooling loops shall be OPERABLE[#] and at least one shutdown cooling loop shall be in operation.*

APPLICABILITY: MODE 5 with reactor coolant loops not filled.

ACTION:

- a. With less than the above required loops OPERABLE, within 1 hour initiate corrective action to return the required loops to OPERABLE status as soon as possible.
- b. With no shutdown cooling loop in operation, suspend operations that would cause introduction into the RCS, coolant with boron concentration less than required to meet SHUTDOWN MARGIN of Technical Specification 3.1.1.2 and within 1 hour initiate corrective action to return the required shutdown cooling loop to operation.

SURVEILLANCE REQUIREMENTS

4.4.1.4.2 At least one shutdown cooling loop shall be determined to be in operation and circulating reactor coolant at least once per 12 hours.

One shutdown cooling loop may be inoperable for up to 2 hours for surveillance testing provided the other shutdown cooling loop is OPERABLE and in operation.

* The shutdown cooling pump may be deenergized for up to 1 hour provided (1) no operations are permitted that would cause introduction into the RCS, coolant with boron concentration less than required to meet the SHUTDOWN MARGIN of Technical Specification 3.1.1.2 and (2) core outlet temperature is maintained at least 10°F below saturation temperature.

PLANT SYSTEMS

3/4.7.7 CONTROL ROOM EMERGENCY AIR CLEANUP SYSTEM (CREACS)

LIMITING CONDITION FOR OPERATION

3.7.7 Two independent control room emergency air cleanup systems shall be OPERABLE with:

- a. A filter train and its associated fan per system, and
- b. At least one air conditioning unit per system, and
- c. Two isolation valves in the kitchen area exhaust duct, and
- d. Two isolation valves in the toilet area exhaust duct, and
- e. Two isolation valves in each (North and South) air intake duct.

APPLICABILITY: ALL MODES.

ACTION:

MODES 1, 2, 3, and 4:

- a. With one control room emergency air cleanup system inoperable, restore the inoperable system to OPERABLE status within 7 days or be in at least HOT STANDBY within 6 hours and in COLD SHUTDOWN within the following 30 hours.
- b. With both control room emergency air cleanup systems inoperable, restore at least one system to OPERABLE status within 24 hours or be in at least HOT STANDBY within the next 6 hours and COLD SHUTDOWN within the next 30 hours.
- c. With an isolation valve in an air intake duct or air exhaust duct inoperable, operation may continue provided the other isolation valve in the same air intake or air exhaust duct is maintained closed; otherwise be in at least HOT STANDBY in the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

MODES 5 and 6:

- a. With one control room emergency air cleanup system inoperable, restore the inoperable system to OPERABLE status within 7 days or initiate and maintain operation of the remaining OPERABLE control room emergency air cleanup system in the recirculation mode.
- b. With both control room emergency air cleanup systems inoperable, suspend all operations involving CORE ALTERATIONS or positive reactivity changes*.
- c. With an isolation valve in an air intake duct or air exhaust duct inoperable, maintain the other isolation valve in the same air intake or air exhaust duct closed or suspend any core alterations or positive reactivity addition operations.

* Limited plant cooldown or boron dilution is allowed provided the change is accounted for in the calculated SHUTDOWN MARGIN.

ELECTRICAL POWER SYSTEMS

A.C. SOURCES

SHUTDOWN

LIMITING CONDITION FOR OPERATION

- 3.8.1.2 As a minimum, the following A.C. electrical power sources shall be OPERABLE:
- a. One circuit between the offsite transmission network and the onsite Class 1E distribution system, and
 - b. One diesel generator with:
 1. Two engine-mounted fuel tanks containing a minimum volume of 200 gallons of fuel,
 2. A fuel storage system containing a minimum volume of 40,000 gallons of fuel, and
 3. A fuel transfer pump.

APPLICABILITY: MODES 5 and 6.

ACTION:

With less than the above minimum required A.C. electrical power sources OPERABLE, immediately suspend all operations involving CORE ALTERATIONS, operations involving positive reactivity additions that could result in loss of required SHUTDOWN MARGIN or boron concentration, movement of irradiated fuel, or crane operation with loads over the fuel storage pool, and within 8 hours, depressurize and vent the Reactor Coolant System through a greater than or equal to 3.58 square inch vent. In addition, when in MODE 5 with the reactor coolant loops not filled, or in MODE 6 with the water level less than 23 feet above the reactor vessel flange, immediately initiate corrective action to restore the required sources to OPERABLE status as soon as possible.

SURVEILLANCE REQUIREMENTS

- 4.8.1.2.1 The above required A.C. electrical power sources shall be demonstrated OPERABLE by the performance of each of the Surveillance Requirements of 4.8.1.1.1 and 4.8.1.1.2 (except for requirement 4.8.1.1.2a.5).

ELECTRICAL POWER SYSTEMS

D.C. SOURCES

SHUTDOWN

LIMITING CONDITION FOR OPERATION

3.8.2.2 As a minimum, one 125-volt battery bank and a full capacity charger shall be OPERABLE.

APPLICABILITY: MODES 5 and 6.

ACTION:

- a. With the required battery bank inoperable, immediately suspend all operations involving CORE ALTERATIONS, operations involving positive reactivity additions that could result in loss of required SHUTDOWN MARGIN or boron concentration, or movement of irradiated fuel; initiate corrective action to restore the required battery bank to OPERABLE status as soon as possible, and within 8 hours, depressurize and vent the Reactor Coolant System through a 3.58 square inch vent.
- b. With the required full capacity charger inoperable, demonstrate the OPERABILITY of its associated battery banks by performing Surveillance Requirement 4.8.2.1a.1. within 1 hour, and at least once per 8 hours thereafter. If any Category A limit in Table 4.8-2 is not met, declare the battery inoperable.

SURVEILLANCE REQUIREMENTS

4.8.2.2 The above required 125-volt battery bank and charger shall be demonstrated OPERABLE per Surveillance Requirement 4.8.2.1.

ELECTRICAL POWER SYSTEMS

ONSITE POWER DISTRIBUTION

SHUTDOWN

LIMITING CONDITION FOR OPERATION

3.8.3.2 As a minimum, the following electrical busses shall be energized and in the specified manner:

- a. One train of A.C. emergency busses consisting of one 4160 volt and two 480 volt A.C. emergency busses.
- b. Two 120 volt A.C. Instrument Busses energized from their associated inverters connected to their respective D.C. busses.
- c. One 125 volt D.C. bus energized from its associated battery bank.

APPLICABILITY: MODES 5 and 6.

ACTION:

With any of the above required electrical busses not energized in the required manner, immediately suspend all operations involving CORE ALTERATIONS, operations involving positive reactivity additions that could result in loss of required SHUTDOWN MARGIN or boron concentration, or movement of irradiated fuel, initiate corrective action to energize the required electrical busses in the specified manner as soon as possible, and within 8 hours depressurize and vent the RCS through a 3.58 square inch vent.

SURVEILLANCE REQUIREMENTS

4.8.3.2 The specified busses shall be determined energized in the required manner at least once per 7 days by verifying correct breaker alignment and indicated voltage on the busses.

REFUELING OPERATIONS

3/4.9.2 INSTRUMENTATION

LIMITING CONDITION FOR OPERATION

3.9.2 As a minimum, two startup range neutron flux monitors shall be OPERABLE and operating, each with continuous visual indication in the control room and one with audible indication in the containment and control room.

APPLICABILITY: MODE 6.

ACTION:

- a. With one of the above required monitors inoperable or not operating, immediately suspend all operations involving CORE ALTERATIONS or operations that would cause introduction into the RCS, coolant with boron concentration less than required to meet the boron concentration of Technical Specification 3.9.1.
- b. With both of the above required monitors inoperable or not operating, determine the boron concentration of the Reactor Coolant System at least once per 12 hours.
- c. The provisions of Specification 3.0.3 are not applicable.

SURVEILLANCE REQUIREMENTS

4.9.2 Each startup range neutron flux monitor shall be demonstrated OPERABLE by performance of:

- a. A CHANNEL CHECK at least once per 12 hours,
- b. A CHANNEL FUNCTIONAL TEST within 8 hours prior to the initial start of CORE ALTERATIONS, and
- c. A CHANNEL FUNCTIONAL TEST at least once per 7 days.

REFUELING OPERATIONS

3/4.9.8 SHUTDOWN COOLING AND COOLANT CIRCULATION

HIGH WATER LEVEL

LIMITING CONDITION FOR OPERATION

3.9.8.1 At least one shutdown cooling loop shall be OPERABLE and in operation.*

APPLICABILITY: MODE 6 when the water level above the top of the reactor pressure vessel flange is greater than or equal to 23 feet.

ACTION:

With no shutdown cooling loop OPERABLE and in operation, suspend all operations involving an increase in reactor decay heat load or operations that would cause introduction into the RCS, coolant with boron concentration less than required to meet the boron concentration of Technical Specification 3.9.1 and within 1 hour initiate corrective action to return the required shutdown cooling loop to OPERABLE and operating status as soon as possible. Close all containment penetrations providing direct access from the containment atmosphere to the outside atmosphere within 4 hours.

SURVEILLANCE REQUIREMENTS

4.9.8.1 At least once per 12 hours:

- a. At least one shutdown cooling loop shall be verified to be in operation
- b. The total flow rate of reactor coolant to the reactor pressure vessel shall be verified to be greater than or equal to 3000 gpm.**

* The shutdown cooling loop may be removed from operation for up to 1 hour per 8-hour period during the performance of CORE ALTERATIONS in the vicinity of reactor pressure vessel hot legs, provided no operations are permitted that would cause introduction into the RCS, coolant with boron concentration less than required to meet the SHUTDOWN MARGIN of Technical Specification 3.9.1.

** The reactor coolant flow rate requirement may be reduced to 1850 gpm if the following conditions are satisfied before the reduced requirement is implemented: the reactor has been determined to have been subcritical for at least 125 hours, the maximum RCS temperature is $\leq 117^{\circ}\text{F}$, and the temperature of CCW to the shutdown cooling heat exchanger is $\leq 87^{\circ}\text{F}$.

REFUELING OPERATIONS

LOW WATER LEVEL

LIMITING CONDITION FOR OPERATION

3.9.8.2 The independent shutdown cooling loops shall be OPERABLE and at least one shutdown cooling shall be in operation.

APPLICABILITY: MODE 6 when the water level above the top of the reactor pressure vessel flange is less than 23 feet.

ACTION:

- a. With less than the required shutdown cooling loops OPERABLE, within 1 hour initiate corrective action to return the required loops to OPERABLE status, or to establish greater than or equal to 23 feet of water above the reactor pressure vessel flange, as soon as possible.
- b. With no shutdown cooling loop in operation, suspend operations that would cause introduction into the RCS, coolant with boron concentration less than required to meet the boron concentration of Technical Specification 3.9.1 and within 1 hour initiate corrective action to return the required shutdown cooling loop to operation. Close all containment penetrations providing direct access from the containment atmosphere to the outside atmosphere within 4 hours.

SURVEILLANCE REQUIREMENTS

4.9.8.2 At least once per 12 hours:

- a. At least one shutdown cooling loop shall be verified to be in operation.
- b. The total flow rate of reactor coolant to the reactor pressure vessel shall be verified to be greater than or equal to 3000 gpm.*

* The reactor coolant flow rate requirement may be reduced to 1850 gpm if the following conditions are satisfied before the reduced requirement is implemented: the reactor has been determined to have been subcritical for at least 125 hours, the maximum RCS temperature is $\leq 117^{\circ}\text{F}$, and the temperature of CCW to the shutdown cooling heat exchanger is $\leq 87^{\circ}\text{F}$.