

October 14, 1988

Docket Nos. 50-327/328

Distribution

Docket File	EJordan	MSimms
NRC PDR	BGrimes	SQN File
Local PDR	DHagan	
Projects Reading	GPA/CA	
OSP Reading	GPA/PA	
JPartlow	ACRS(10)	
SRichardson	EButcher	
SBlack	Projects Rdg.	
BDLiaw	JDonohew(2)	
FMcCoy	TBarnhart(8)	
FMiraglia	WJones	
JRutberg	LFMB	

Mr. S. A. White
 Senior Vice President, Nuclear Power
 Tennessee Valley Authority
 6N 38A Lookout Place
 1101 Market Street
 Chattanooga, Tennessee 37402-2801

Dear Mr. White:

SUBJECT: MAXIMUM ALLOWABLE PRESSURE DROP ACROSS THE HIGH EFFICIENCY
 PARTICULATE AIR (HEPA) AND CHARCOAL FILTERS (TAC RO052, RO053)
 (TS 87 (C)) - SEQUOYAH NUCLEAR PLANT, UNITS 1 AND 2

The Commission has issued the enclosed Amendment No.88 to Facility
 Operating License No. DPR-77 and Amendment No. 77 to Facility Operating
 License No. DPR-79 for the Sequoyah Nuclear Plant, Units 1 and 2, respectively.
 These amendments are in response to your application dated April 17, 1987, as
 supplemented by your letter dated July 15, 1988.

The amendments modify the surveillance requirements (SR) in specifica-
 tions 4.6.1.8.d.1, 4.7.7.e.1, 4.7.8.d.1, and 4.9.12.d.1 of the
 Sequoyah Units 1 and 2 Technical Specifications (TS). The amendments decrease
 the maximum allowable pressure drop across the HEPA and charcoal filters in the
 emergency gas treatment system, auxiliary building gas treatment system, and
 the control room emergency ventilation system.

A copy of the Safety Evaluation is also enclosed. Notice of Issuance will be
 included in the Commission's Bi-Weekly Federal Register Notice.

Sincerely,

Suzanne Black, Assistant Director
 for Projects
 TVA Projects Division
 Office of Special Projects

Enclosures:

1. Amendment No. 88 to License No. DPR-77
2. Amendment No. 77 to License No. DPR-79
3. Safety Evaluation

DF01
||

cc w/enclosures:
 See next page

8810240414 881014
 PDR ADDCK 05000327
 PDC

OFC	OSP: TVA/CA	OSP: TVA/PM	O&C	TVA:AD/P		
NAME	MSimms	JDonohew	R.Bachmann	SBlack		
DATE	9/12/88	9/27/88	10/4/88	10/14/88		

CP1



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

TENNESSEE VALLEY AUTHORITY

DOCKET NO. 50-327

SEQUOYAH NUCLEAR PLANT, UNIT 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 88
License No. DPR-77

1. The Nuclear Regulatory Commission (the Commission) has found that:

- A. The application for amendment by Tennessee Valley Authority (the licensee) dated April 17, 1987, as supplemented by letter dated July 15, 1988, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
- B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
- C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
- D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
- E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

8810240416 881014
PDR ADOCK 05000327
P PDC


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C.(2) of Facility Operating License No. DPR-77 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 88, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Suzanne Black, Assistant Director
for Projects
TVA Projects Division
Office of Special Projects

Attachment:
Changes to the Technical
Specifications

Date of Issuance: October 14, 1988

ATTACHMENT TO LICENSE AMENDMENT NO. 88

FACILITY OPERATING LICENSE NO. DPR-77

DOCKET NO. 50-327

Revise the Appendix A Technical Specifications by removing the pages identified below and inserting the enclosed pages. The revised pages are identified by the captioned amendment number and contain marginal lines indicating the area of change. Asterisked pages* are provided to maintain document completeness.

REMOVE

3/4 6-13*

3/4 6-14

3/4 7-17*

3/4 7-18

3/4 7-20

3/4 9-13

INSERT

3/4 6-13*

3/4 6-14

3/4 7-17*

3/4 7-18

3/4 7-20

3/4 9-13

CONTAINMENT SYSTEMS

EMERGENCY GAS TREATMENT SYSTEM - EGTS - CLEANUP SUBSYSTEM

LIMITING CONDITION FOR OPERATION

3.6.1.8 Two independent emergency gas treatment system cleanup subsystems (EGTS) shall be OPERABLE.

APPLICABILITY: MODES 1, 2, 3 and 4.

ACTION:

With one EGTS cleanup subsystem inoperable, restore the inoperable subsystem to OPERABLE status within 7 days or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

SURVEILLANCE REQUIREMENTS

4.6.1.8 Each EGTS cleanup subsystem shall be demonstrated OPERABLE:

- a. At least once per 31 days on a STAGGERED TEST BASIS by initiating, from the control room, flow through the HEPA filters and charcoal adsorbers and verifying that the system operates for at least 10 hours with the heaters on.
- b. At least once per 18 months or (1) after any structural maintenance on the HEPA filter or charcoal adsorber housings, or (2) following painting, fire or chemical release in any ventilation zone communicating with the system by:
 1. Verifying that the cleanup system satisfies the in-place testing acceptance criteria and uses the test procedures of Regulatory Position C.5.a., C.5.c and C.5.d of Regulatory Guide 1.52, Revision 2, March 1978 (except for the provisions of ANSI N510 Sections 8 and 9), and the system flow rate is 4000 cfm \pm 10%.
 2. Verifying within 31 days after removal that a laboratory analysis of a representative carbon sample obtained in accordance with Regulatory Position C.6.b of Regulatory Guide 1.52, Revision 2, March 1978, meets the laboratory testing criteria of Regulatory Position C.6.a of Regulatory Guide 1.52, Revision 2, March 1978.
 3. Verifying a system flow rate of 4000 cfm \pm 10% during system operation when tested in accordance with ANSI N510-1975.

CONTAINMENT SYSTEMS

SURVEILLANCE REQUIREMENTS (Continued)

- c. After every 720 hours of charcoal adsorber operation by verifying within 31 days after removal that a laboratory analysis of representative carbon sample obtained in accordance with Regulatory Position C.6.b of Regulatory Guide 1.52, Revision 2, March 1978, meets the laboratory testing criteria of Regulatory Position C.6.a of Regulatory Guide 1.52, Revision 2, March 1978.
- d. At least once per 18 months by:
 - 1. Verifying that the pressure drop across the combined HEPA filters and charcoal adsorber banks is less than 5 inches Water Gauge while operating the filter train at a flow rate of 4000 cfm \pm 10%.
 - 2. Verifying that the filter train starts on a Phase A containment isolation Test Signal.
 - 3. Verify the operation of the filter cooling bypass valves.
 - 4. Verifying that the heaters dissipate 16 ± 1.6 kw when tested in accordance with ANSI N510-1975.
 - 5. Verifying that each system produces a negative pressure of greater than or equal to 0.5 inches W. G. in the annulus within 1 minute after a start signal.
- e. After each complete or partial replacement of a HEPA filter bank by verifying that the HEPA filter banks remove greater than or equal to 99.95% of the DOP when they are tested in-place in accordance with ANSI N510-1975 while operating the system at a flow rate of 4000 cfm \pm 10%.
- f. After each complete or partial replacement of a charcoal adsorber bank by verifying that the charcoal adsorbers remove greater than or equal to 99.95% of a halogenated hydrocarbon refrigerant test gas when they are tested in-place in accordance with ANSI N510-1975 while operating the system at a flow rate of 4000 cfm \pm 10%.

PLANT SYSTEMS

3/4.7.7 CONTROL ROOM EMERGENCY VENTILATION SYSTEM

LIMITING CONDITION FOR OPERATION

3.7.7 Two independent control room emergency ventilation systems shall be OPERABLE.

APPLICABILITY: ALL MODES

ACTION:

MODES 1, 2, 3 and 4

With one control room emergency ventilation system inoperable, restore the inoperable system to OPERABLE status within 7 days or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

MODES 5 and 6

- a. With one control room emergency ventilation system inoperable, restore the inoperable system to OPERABLE status within 7 days or initiate and maintain operation of the control room emergency ventilation system in the recirculation mode.
- b. With both control room emergency air ventilation systems inoperable, suspend all operations involving CORE ALTERATIONS or positive reactivity changes.
- c. The provisions of Specification 3.0.3 are not applicable in MODE 6.

SURVEILLANCE REQUIREMENTS

4.7.7 Each control room emergency ventilation system shall be demonstrated OPERABLE:

- a. At least once per 12 hours by verifying that the control room air temperature is less than or equal to 104°F.
- b. At least once per 31 days on a STAGGERED TEST BASIS by initiating, from the control room, flow through the HEPA filters and charcoal adsorbers and verifying that the system operates for at least 15 minutes.
- c. At least once per 18 months or (1) after any structural maintenance on the HEPA filter or charcoal adsorber housings, or (2) following painting, fire or chemical release in any ventilation zone communicating with the system by:

PLANT SYSTEMS

SURVEILLANCE REQUIREMENTS (Continued)

1. Verifying that the cleanup system satisfies the in-place testing acceptance criteria and uses the test procedures of Regulatory Positions C.5.a, C.5.c and C.5.d of Regulatory Guide 1.52, Revision 2, March 1978 (except for the provisions of ANSI N510 Sections 8 and 9), and the system flow rate is 4000 cfm \pm 10%.
 2. Verifying within 31 days after removal that a laboratory analysis of a representative carbon sample obtained in accordance with Regulatory Position C.6.b of Regulatory Guide 1.52, Revision 2, March 1978, meets the laboratory testing criteria of Regulatory Position C.6.a of Regulatory Guide 1.52, Revision 2, March 1978.
 3. Verifying a system flow rate of 4000 cfm \pm 10% during system operation when tested in accordance with ANSI N510-1975.
- d. After every 720 hours of charcoal adsorber operation by verifying within 31 days after removal that a laboratory analysis of representative carbon sample obtained in accordance with Regulatory Position C.6.b of Regulatory Guide 1.52, Revision 2, March 1978, meets the laboratory testing criteria of Regulatory Position C.6.a of Regulatory Guide 1.52, Revision 2, March 1978.
- e. At least once per 18 months by:
1. Verifying that the pressure drop across the combined HEPA filters and charcoal adsorber banks is less than 3 inches Water Gauge while operating the system at a flow rate of 4000 cfm \pm 10%.
 2. Verifying that on a safety injection signal or a high radiation signal from the air intake stream, the system automatically diverts its inlet flow through the HEPA filters and charcoal adsorber banks.
 3. Verifying that the system maintains the control room at a positive pressure of greater than or equal to 1/8 inch Water Gauge relative to the outside atmosphere at a system flow rate of 4000 cfm \pm 10% (\geq 3000 cfm recirculation and \leq 1000 cfm fresh air).
- f. After each complete or partial replacement of a HEPA filter bank by verifying that the HEPA filter banks remove greater than or equal to 99.95% of the DOP when they are tested in-place in accordance with ANSI N510-1975 while operating the system at a flow rate of 4000 cfm \pm 10%.
- g. After each complete or partial replacement of a charcoal adsorber bank by verifying that the charcoal adsorbers remove greater than or equal to 99.95% of a halogenated hydrocarbon refrigerant test gas when they are tested in-place in accordance with ANSI N510-1975 while operating the system at a flow rate of 4000 cfm \pm 10%.

PLANT SYSTEMS

SURVEILLANCE REQUIREMENTS (Continued)

- c. After every 720 hours of charcoal adsorber operation by verifying within 31 days after removal that a laboratory analysis of representative carbon sample obtained in accordance with Regulatory Position C.6.b of Regulatory Guide 1.52, Revision 2, March 1978, meets the laboratory testing criteria of Regulatory Position C.6.a of Regulatory Guide 1.52, Revision 2, March 1978.
- d. At least once per 18 months by:
 - 1. Verifying that the pressure drop across the combined HEPA filters and charcoal adsorber banks is less than 3 inches Water Gauge while operating the filter train at a flow rate of 9000 cfm \pm 10%.
 - 2. Verifying that the filter trains start on a Containment Phase A Isolation test signal; or a high radiation signal from the fuel pool radiation monitoring system or the auxiliary building ventilation monitoring system.
 - 3. Verifying that the system maintains the spent fuel storage area and the ESF pump rooms at a pressure equal to or more negative than minus 1/4 inch water gage relative the outside atmosphere while maintaining a vacuum relief flow greater than 2000 cfm and a total system flow of 9000 cfm \pm 10%.
 - 4. Verifying that the heaters disipate 32 \pm 3.2 kw when tested in accordance with ANSI N510-1975.
- e. After each complete or partial replacement of a HEPA filter bank by verifying that the HEPA filter banks remove greater than or equal to 99.95% of the DOP when they are tested in-place in accordance with ANSI N510-1975 while operating the system at a flow rate of 9000 cfm \pm 10%.
- f. After each complete or partial replacement of a charcoal adsorber bank by verifying that the charcoal adsorbers remove greater than or equal to 99.95% of a halogenated hydrocarbon refrigerant test gas when they are tested in-place in accordance with ANSI N510-1975 while operating the system at a flow rate of 9000 cfm \pm 10%.

REFUELING OPERATIONS

SURVEILLANCE REQUIREMENTS (Continued)

- c. After every 720 hours of charcoal adsorber operation by verifying within 31 days after removal that a laboratory analysis of representative carbon sample obtained in accordance with Regulatory Position C.6.b of Regulatory Guide 1.52, Revision 2, March 1978, meets the laboratory testing criteria of Regulatory Position C.6.a of Regulatory Guide 1.52, Revision 2, March 1978.
- d. At least once per 18 months by:
 - 1. Verifying that the pressure drop across the combined HEPA filters and charcoal adsorber banks is less than 3 inches Water Gauge while operating the filter train at a flow rate of 9000 cfm \pm 10%.
 - 2. Verifying that the filter train starts on a Containment Phase A Isolation Test Signal; or a high radiation signal from the fuel pool radiation monitoring system or the auxiliary building ventilation monitoring system.
 - 3. Verifying that the heaters dissipate 32 ± 3.2 kw when tested in accordance with ANSI N510-1975.
- e. After each complete or partial replacement of a HEPA filter bank by verifying that the HEPA filter banks remove greater than or equal to 99.95% of the DOP when they are tested in-place in accordance with ANSI N510-1975 while operating the system at a flow rate of 9000 cfm \pm 10%.
- f. After each complete or partial replacement of a charcoal adsorber bank by verifying that the charcoal adsorbers remove greater than or equal to 99.95% of a halogenated hydrocarbon refrigerant test gas when they are tested in-place in accordance with ANSI N510-1975 while operating the system at a flow rate of 9000 cfm \pm 10%.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

TENNESSEE VALLEY AUTHORITY

DOCKET NO. 50-328

SEQUOYAH NUCLEAR PLANT, UNIT 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 77
License No. DPR-79

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Tennessee Valley Authority (the licensee) dated April 17, 1987, as supplemented by letter dated July 15, 1988, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C.(2) of Facility Operating License No. DPR-79 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 77, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Suzanne Black, Assistant Director
for Projects
TVA Projects Division
Office of Special Projects

Attachment:
Changes to the Technical
Specifications

Date of Issuance: October 14, 1988

ATTACHMENT TO LICENSE AMENDMENT NO. 77

FACILITY OPERATING LICENSE NO. DPR-79

DOCKET NO. 50-328

Revise the Appendix A Technical Specifications by removing the pages identified below and inserting the enclosed pages. The revised pages are identified by the captioned amendment number and contain marginal lines indicating the area of change. Asterisked pages* are provided to maintain document completeness.

REMOVE

3/4 6-13*

3/4 6-14

3/4 7-17*

3/4 7-18

3/4 7-19*

3/4 7-20

3/4 9-15

INSERT

3/4 6-13*

3/4 6-14

3/4 7-17*

3/4 7-18

3/4 7-19*

3/4 7-20

3/4 9-15

CONTAINMENT SYSTEMS

EMERGENCY GAS TREATMENT SYSTEM - EGTS - CLEANUP SUBSYSTEM

LIMITING CONDITION FOR OPERATION

3.6.1.8 Two independent emergency gas treatment system cleanup subsystems (EGTS) shall be OPERABLE.

APPLICABILITY: MODES 1, 2, 3 and 4.

ACTION:

With one EGTS cleanup subsystem inoperable, restore the inoperable subsystem to OPERABLE status within 7 days or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

SURVEILLANCE REQUIREMENTS

4.6.1.8 Each EGTS cleanup subsystem shall be demonstrated OPERABLE:

- a. At least once per 31 days on a STAGGERED TEST BASIS by initiating, from the control room, flow through the HEPA filters and charcoal adsorbers and verifying that the system operates for at least 10 hours with the heaters on.
- b. At least once per 18 months or (1) after any structural maintenance on the HEPA filter or charcoal adsorber housings, or (2) following painting, fire or chemical release in any ventilation zone communicating with the system by:
 1. Verifying that the cleanup system satisfies the in-place testing acceptance criteria and uses the test procedures of Regulatory Position C.5.a., C.5.c and C.5.d of Regulatory Guide 1.52, Revision 2, March 1978 (except for the provisions of ANSI N510 Sections 8 and 9), and the system flow rate is 4000 cfm \pm 10%.
 2. Verifying within 31 days after removal that a laboratory analysis of a representative carbon sample obtained in accordance with Regulatory Position C.6.b of Regulatory Guide 1.52, Revision 2, March 1978 meets the laboratory testing criteria of Regulatory Position C.6.a of Regulatory Guide 1.52, Revision 2, March 1978.
 3. Verifying a system flow rate of 4000 cfm \pm 10% during system operation when tested in accordance with ANSI N510-1975.

CONTAINMENT SYSTEMS

SURVEILLANCE REQUIREMENTS (Continued)

- c. After every 720 hours of charcoal adsorber operation by verifying within 31 days after removal that a laboratory analysis of representative carbon sample obtained in accordance with Regulatory Position C.6.b of Regulatory Guide 1.52, Revision 2, March 1978, meets the laboratory testing criteria of Regulatory Position C.6.a of Regulatory Guide 1.52, Revision 2, March 1978.
- d. At least once per 18 months by:
 - 1. Verifying that the pressure drop across the combined HEPA filters and charcoal adsorber banks is less than 5 inches Water Gauge while operating the filter train at a flow rate of 4000 cfm + 10%.
 - 2. Verifying that the filter train starts on a Phase A containment isolation Test Signal.
 - 3. Verify the operation of the filter cooling bypass valves.
 - 4. Verifying that the heaters dissipate 16 + 1.6 kw when tested in accordance with ANSI N510-1975.
 - 5. Verifying that each system produces a negative pressure of greater than or equal to 0.5 inches W.G. in the annulus within 1 minute after a start signal.
- e. After each complete or partial replacement of a HEPA filter bank by verifying that the HEPA filter banks remove greater than or equal to 99.95% of the DOP when they are tested in-place in accordance with ANSI N510-1975 while operating the system at a flow rate of 4000 cfm + 10%.
- f. After each complete or partial replacement of a charcoal adsorber bank by verifying that the charcoal adsorbers remove greater than or equal to 99.95% of a halogenated hydrocarbon refrigerant test gas when they are tested in-place in accordance with ANSI N510-1975 while operating the system at a flow rate of 4000 cfm + 10%.

PLANT SYSTEMS

3/4.7.7 CONTROL ROOM EMERGENCY VENTILATION SYSTEM

LIMITING CONDITION FOR OPERATION

3.7.7 Two independent control room emergency ventilation systems shall be OPERABLE.

APPLICABILITY: ALL MODES

ACTION:

MODES 1, 2, 3 and 4:

With one control room emergency ventilation system inoperable, restore the inoperable system to OPERABLE status within 7 days or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

MODES 5 and 6:

- a. With one control room emergency ventilation system inoperable, restore the inoperable system to OPERABLE status within 7 days or initiate and maintain operation of the control room emergency ventilation system in the recirculation mode.
- b. With both control room emergency air ventilation systems inoperable, suspend all operations involving CORE ALTERATIONS or positive reactivity changes.
- c. The provisions of Specification 3.0.3 are not applicable in MODE 6.

SURVEILLANCE REQUIREMENTS

4.7.7 Each control room emergency ventilation system shall be demonstrated OPERABLE:

- a. At least once per 12 hours by verifying that the control room air temperature is less than or equal to 104°F.
- b. At least once per 31 days on a STAGGERED TEST BASIS by initiating, from the control room, flow through the HEPA filters and charcoal adsorbers and verifying that the system operates for at least 15 minutes.
- c. At least once per 18 months or (1) after any structural maintenance on the HEPA filter or charcoal adsorber housings, or (2) following painting, fire or chemical release in any ventilation zone communicating with the system by:

PLANT SYSTEMS

SURVEILLANCE REQUIREMENTS (Continued)

1. Verifying that the cleanup system satisfies the in-place testing acceptance criteria and uses the test procedures of Regulatory Positions C.5.a, C.5.c and C.5.d of Regulatory Guide 1.52, Revision 2, March 1978 (except for the provisions of ANSI N510 Sections 8 and 9), and the system flow rate is 4000 cfm \pm 10%.
 2. Verifying, within 31 days after removal, that a laboratory analysis of a representative carbon sample obtained in accordance with Regulatory Position C.6.b of Regulatory Guide 1.52, Revision 2, March 1978, meets the laboratory testing criteria of Regulatory Position C.6.a of Regulatory Guide 1.52, Revision 2, March 1978.
 3. Verifying a system flow rate of 4000 cfm \pm 10% during system operation when tested in accordance with ANSI N510-1975.
- d. After every 720 hours of charcoal adsorber operation by verifying within 31 days after removal, that a laboratory analysis of a representative carbon sample obtained in accordance with Regulatory Position C.6.b of Regulatory Guide 1.52, Revision 2, March 1978, meets the laboratory testing criteria of Regulatory Position C.6.a of Regulatory Guide 1.52, Revision 2, March 1978.
- e. At least once per 18 months by:
1. Verifying that the pressure drop across the combined HEPA filters and charcoal adsorber banks is less than 3 inches Water Gauge while operating the system at a flow rate of 4000 cfm \pm 10%.
 2. Verifying that on a safety injection signal or high radiation signal from the air intake stream, the system automatically diverts its inlet flow through the HEPA filters and charcoal adsorber banks.
 3. Verifying that the system maintains the control room at a positive pressure of greater than or equal to 1/8 inch Water Gauge relative to the outside atmosphere at a system flow rate of 4000 cfm \pm 10% (\geq 3000 cfm recirculation and \leq 1000 cfm fresh air).
- f. After each complete or partial replacement of a HEPA filter bank by verifying that the HEPA filter banks remove greater than or equal to 99.95% of the DOP when they are tested in-place in accordance with ANSI N510-1975 while operating the system at a flow rate of 4000 cfm \pm 10%.
- g. After each complete or partial replacement of a charcoal adsorber bank by verifying that the charcoal adsorbers remove greater than or equal to 99.95% of a halogenated hydrocarbon refrigerant test gas when they are tested in-place in accordance with ANSI N510-1975 while operating the system at a flow rate of 4000 cfm \pm 10%.

PLANT SYSTEMS

3/4.7.8 AUXILIARY BUILDING GAS TREATMENT SYSTEM

LIMITING CONDITION FOR OPERATION

3.7.8 Two independent auxiliary building gas treatment filter trains shall be OPERABLE.

APPLICABILITY: Modes 1, 2, 3 and 4.

ACTION:

With one auxiliary building gas treatment filter train inoperable, restore the inoperable train to OPERABLE status within 7 days or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

SURVEILLANCE REQUIREMENTS

4.7.8 Each auxiliary building gas treatment filter train shall be demonstrated OPERABLE:

- a. At least once per 31 days on a STAGGERED TEST BASIS by initiating, from the control room, flow through the HEPA filter and charcoal adsorber train and verifying that the system operates for at least 10 hours with the heaters on.
- b. At least once per 18 months or (1) after any structural maintenance on the HEPA filter or charcoal adsorber housings, or (2) following painting, fire or chemical release in any ventilation zone communicating with the system by:
 1. Verifying that the cleanup system satisfies the in-place testing acceptance criteria and uses the test procedures of Regulatory Positions C.5.a, C.5.c and C.5.d of Regulatory Guide 1.52, Revision 2, March 1978 (except for the provisions of ANSI N510 Sections 8 and 9), and the system flow rate is 9000 cfm \pm 10%.
 2. Verifying within 31 days after removal that a laboratory analysis of a representative carbon sample obtained in accordance with Regulatory Position C.6.b of Regulatory Guide 1.52, Revision 2, March 1978, meets the laboratory testing criteria of Regulatory Position C.6.a of Regulatory Guide 1.52, Revision 2, March 1978.
 3. Verifying a system flow rate of 9000 cfm \pm 10% during system operation when tested in accordance with ANSI N510-1975.

PLANT SYSTEMS

SURVEILLANCE REQUIREMENTS (Continued)

- c. After every 720 hours of charcoal adsorber operation by verifying within 31 days after removal that a laboratory analysis of representative carbon sample obtained in accordance with Regulatory Position C.6.b of Regulatory Guide 1.52, Revision 2, March 1978, meets the laboratory testing criteria of Regulatory Position C.6.a of Regulatory Guide 1.52, Revision 2, March 1978.
- d. At least once per 18 months by:
 - 1. Verifying that the pressure drop across the combined HEPA filters and charcoal adsorber banks is less than 3 inches Water Gauge while operating the filter train at a flow rate of 9000 cfm \pm 10%.
 - 2. Verifying that the filter trains start on a Containment Phase A Isolation test signal; or a high radiation signal from the fuel pool radiation monitoring system or the auxiliary building ventilation monitoring system.
 - 3. Verifying that the system maintains the spent fuel storage area and the ESF pump rooms at a pressure equal to or more negative than minus 1/4 inch water gauge relative the outside atmosphere while maintaining a vacuum relief flow greater than 2000 cfm and a total system flow of 9000 cfm \pm 10%.
 - 4. Verifying that the heaters dissipate 32 ± 3.2 kw when tested in accordance with ANSI N510-1975.
- e. After each complete or partial replacement of a HEPA filter bank by verifying that the HEPA filter banks remove greater than or equal to 99.95% of the DOP when they are tested in-place in accordance with ANSI N510-1975 while operating the system at a flow rate of 9000 cfm \pm 10%.
- f. After each complete or partial replacement of a charcoal adsorber bank by verifying that the charcoal adsorbers remove greater than or equal to 99.95% of a halogenated hydrocarbon refrigerant test gas when they are tested in-place in accordance with ANSI N510-1975 while operating the system at a flow rate of 9000 cfm \pm 10%.

REFUELING OPERATIONS

SURVEILLANCE REQUIREMENTS (Continued)

- c. After every 720 hours of charcoal adsorber operation by verifying within 31 days after removal that a laboratory analysis of representative carbon sample obtained in accordance with Regulatory Position C.6.b of Regulatory Guide 1.52, Revision 2, March 1978, meets the laboratory testing criteria of Regulatory Position C.6 a of Regulatory Guide 1.52, Revision 2, March 1978.
- d. At least once per 18 months by:
 - 1. Verifying that the pressure drop across the combined HEPA filters and charcoal adsorber banks is less than 3 inches Water Gauge while operating the filter train at a flow rate of 9000 cfm \pm 10%.
 - 2. Verifying that the filter train starts on a Containment Phase A Isolation Test Signal; or a high radiation signal from the fuel pool radiation monitoring system or the auxiliary building ventilation monitoring system.
 - 3. Verifying that the heaters dissipate 32 ± 3.2 kw when tested in accordance with ANSI N510-1975.
- e. After each complete or partial replacement of a HEPA filter bank by verifying that the HEPA filter banks remove greater than or equal to 99.95% of the DOP when they are tested in-place in accordance with ANSI N510-1975 while operating the system at a flow rate of 9000 cfm \pm 10%.
- f. After each complete or partial replacement of a charcoal adsorber bank by verifying that the charcoal adsorbers remove greater than or equal to 99.95% of a halogenated hydrocarbon refrigerant test gas when they are tested in-place in accordance with ANSI N510-1975 while operating the system at a flow rate of 9000 cfm \pm 10%.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF SPECIAL PROJECTS

SUPPORTING AMENDMENT NO. 88 TO FACILITY OPERATING LICENSE NO. DPR-77

AND AMENDMENT NO. 77 TO FACILITY OPERATING LICENSE NO. DPR-79

TENNESSEE VALLEY AUTHORITY

SEQUOYAH NUCLEAR PLANT, UNITS 1 AND 2

DOCKET NOS. 50-327 AND 50-328

1.0 INTRODUCTION

By letter dated April 17, 1987, as supplemented by letter dated July 15, 1988, the Tennessee Valley Authority (TVA) proposed changes to surveillance requirements (SR) in the Sequoyah Units 1 and 2 Technical Specifications (TS). The proposed changes involve the reduction in the maximum acceptable pressure drop across the high efficient particulate air (HEPA) filters and charcoal adsorber banks in the emergency gas treatment system (SR 4.6.1.8.d.1), auxiliary building gas treatment systems (SR 4.7.8.d.1 and 4.9.12.d.1) and control room emergency ventilation system (SR 4.7.7.e.1).

Specifically, TVA proposed that the maximum acceptable pressure drop of eight inches water gauge (WG) across the combined HEPA filters and charcoal banks referenced in SR 4.6.1.8.d.1 be lowered to five inches WG. The maximum acceptable pressure drop of six inches WG across the combined HEPA filters and charcoal banks referenced in SR 4.7.7.e.1, SR 4.7.8.d.1 and 4.9.12.d.1 be lowered to three inches.

2.0 EVALUATION

TVA stated in its application that as a result of its Technical Specification Verification Program at Sequoyah, it was determined that the current maximum acceptable pressure drops specified in SR 4.6.1.8.d.1, 4.7.7.e.1, 4.7.8.d.1, and 4.9.12.d.1 for the various air cleanup system filter trains could not be substantiated. The staff's review of TVA's design calculations (Reference 5.1) indicated that the calculations were performed to determine the fan size based on the desired airflow rate and estimated pressure drop losses due to the duct configuration such as elbows, dampers, grills and the filters. The current SR requires inspection of the pressure drop across the HEPA and charcoal adsorber filter banks. Because the HEPA and charcoal filter banks only contribute approximately 50% of the total pressure drop of the system, the current maximum values of the pressure drop across the filters are too high to be effective in detecting any substantial air blocking. The lower values will allow the detection of substantial air blockage and this improves safety.

TVA stated in its application that it is requesting that the pressure drop values in SR 4.6.1.8.d.1, 4.7.7.e.1, 4.7.8.d.1 and 4.9.12.d.1 be revised to reflect the values used in its design calculations. The pressure drop losses attributed to the filters in the calculations assumed that the filters are dirty and that they will be changed before the associated pressure drop exceeds the specified value. These specified maximum pressure drop values are the new values proposed in TVA's application. This will result in a traceable documented basis for each of the subject pressure drop values.

Exceeding the SR requirement requires replacement of the filter and charcoal adsorber bank. Therefore, the proposed reduction of the SR pressure drop requirement will require more frequent replacements of the filter. This is in the conservative direction.

Therefore, based on the above, the proposed change is acceptable.

3.0 ENVIRONMENTAL CONSIDERATION

These amendments involve a change to a requirement with respect to the installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20 and changes to the surveillance requirements. The staff has determined that the amendments involve no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that these amendments involve no significant hazards consideration and there has been no public comment on such finding. Accordingly, the amendments meet the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b), no environmental impact statement nor environmental assessment need be prepared in connection with the issuance of these amendments.

4.0 CONCLUSION

The Commission made a proposed determination that the amendment involves no significant hazards consideration which was published in the Federal Register (52 FR 26598) on July 15, 1987 and consulted with the State of Tennessee on October 12, 1987. No public comments were received and the State of Tennessee did not have any comments.

We have concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and (2) such activities will be conducted in compliance with the Commission's regulations, and the issuance of these amendments will not be inimical to the common defense and security nor to the health and safety of the public.

5.0 REFERENCE

5.1 TVA submittal, "Additional Information For Technical Specification Change TS 87-10" dated July 15, 1988.

Principal Contributor: Sang Bo Kim

Dated: October 14, 1988