Docket Nos. 50-327/328

Mr. Oliver D. Kingsley, Jr. Senior Vice President, Nuclear Power Tennessee Valley Authority 6N 38A Lookout Place 1101 Market Street Chattanooga, Tennessee 37402-2801

Dear Mr. Kingsley:

ISSUANCE OF CHANGE TO TABLES 3.3-9 AND 4.3-6 - SEQUOYAH NUCLEAR SUBJECT: PLANT, UNITS 1 AND 2 (TAC 73020, 73021) (TS 89-23)

The Commission has issued the enclosed Amendment No.113 to Facility Operating License No. DPR-77 and Amendment No. 103 to Facility Operating License No. DPR-79 for the Sequoyah Nuclear Plant, Units 1 and 2, respectively. These amendments are in response to your application dated May 2, 1989.

These amendments delete the remote shutdown instrumentation requirements for full-length, control rod position limit switches contained in Tables 3.3-9 and 4.3-6.

A copy of the Safety Evaluation is also enclosed. Notice of Issuance will be included in the Commission's Bi-Weekly Federal Register Notice.

> Sincerely, ORIGINAL SIGNED BY

B. D. Liaw, Director **TVA Projects Division** Office of Nuclear Reactor Regulation

Enclosures: 1. Amendment No.113 to License No. DPR-77 Amendment No.103 to 2. License No. DPR-79 Safety Evaluation

3.

cc w/enclosures: See next page

8905120262 890504 PDR ADOCK 05000327 ÊDŔ PDC

OFFICIAL RECORD COPY

***SEE PREVIOUS CONCURRENCE**

DISTRIBUTION:		
Docket File	LWatson	BFN Rdg.
NRC PDR	JBrady	BWilson
Local PDR	BGrimes	
Projects Reading	EJordan	
ADSP Reading	DHagan	
DCrutchfield	TMeek(4 for	each)
BDLiaw	WJones	
SBlack	EButcher	
RPierson	ACRS(10)	OF0
MSimms	GPA/CA	1
JDonohew	GPA/PA	1]1
OGC	ARM/LFMB	ļ

OFC	:NRR:TVA/LA*	:NRR:TVA/PM*	: OGC* :	TVA:D	· · · · · · · · · · · · · · · · · · ·
NAME	: :MSimms	: :GGears:as		BDLiaw 89	(PaA)
DATE	5/03/89	5/03/89	5/03/89	5/4/89	<u>ly</u> .

OFFICIAL RECORD COPY

May 4, 1989

Docket Nos. 50-327/328

Mr. Oliver D. Kingsley, Jr. <u>Manager of Nuclear Power</u> Tennessee Valley Authority 6N 38A Lookout Place 1101 Market Street Chattanooga, Tennessee 37402-2801

Dear Mr. Kingsley:

SUBJECT: ISSUANCE OF CHANGE TO TABLES 3.3-9 AND 4.3-6 - SEQUOYAH NUCLEAR PLANT, UNITS 1 AND 2 (TAC 73020, 73021) (TS 89-23)

The Commission has issued the enclosed Amendment No. 113 to Facility Operating License No. DPR-77 and Amendment No. 103 to Facility Operating License No. DPR-79 for the Sequoyah Nuclear Plant, Units 1 and 2, respectively. These amendments are in response to your application dated May 2, 1989.

These amendments delete the remote shutdown instrumentation requirements for full-length, control rod position limit switches contained in Tables 3.3-9 and 4.3-6.

A copy of the Safety Evaluation is also enclosed. Notice of Issuance will be included in the Commission's Bi-Weekly <u>Federal Register</u> Notice.

Sincerely,

Original signed by Edward Goodwin for

Suzanne Black, Assistant Director for Projects TVA Projects Division Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No. 113 to License No. DPR-77

- 2. Amendment No. 103 to License No. DPR-79
- 3. Safety Evaluation

cc w/enclosures: See next page **DISTRIBUTION:** LWatson Docket File JBrady NRC PDR Local PDR BGrimes EJordan Projects Reading ADSP Reading DHagan DCrutchfield BDLiaw WJones EButcher SB1ack ACRS(10)RPierson GPA/CA MSimms **JDonohew** GPA/PA ARM/LFMB OGC

LWatson BFN Rdg. JBrady BWilson BGrimes EJordan DHagan TMeek(4 for each) WJones EButcher ACRS(10)

OFFICIAL RECORD COPY

			10			
OFC	:NRR:TVA/LA	:NRR:TVA/PM	: OGC XB	TVA:AD/P :	TVA:AD/TP	TVA LAP/BS
NAME	MSimms MB	: GGeans Xas	<i>R</i> Bachmann	SBlack	RPierson	TROTELLA:
DATE	5/4/89	5/3/89	5/3/89	5/ /89	5/ 3 /89	5/3/89
OFFIC	IAL RECORD CO	PY				

Mr. Oliver D. Kingsley, Jr.

cc: General Counsel Tennessee Valley Authority 400 West Summit Hill Drive E11 B33 Knoxville, Tennessee 37902

Mr. C. H. Fox Tennessee Valley Authority 5N 157B Lookout Place Chattanooga, Tennessee 37402-2801

Mr. John T. LaPoint Tennessee Valley Authority Sequoyah Nuclear Plant P.O. Box 2000 Soddy Daisy, Tennessee 37379

Mr. M. Burzynski Tennessee Valley Authority Sequoyah Nuclear Plant P.O. Box 2000 Soddy Daisy, Tennessee 37379

Mr. D. L. Williams Tennessee Valley Authority 400 West Summit Hill Drive W10 B85 Knoxville, Tennessee 37902

County Judge Hamilton County Courthouse Chattanooga, Tennessee 37402 -2- Sequoyah Nuclear Plant

Regional Administrator, Region II U.S. Nuclear Regulatory Commission 101 Marietta Street, N.W. Atlanta, Georgia 30323

Resident Inspector/Sequoyah NP c/o U.S. Nuclear Regulatory Commission 2600 Igou Ferry Road Soddy Daisy, Tennessee 37379

Mr. Michael H. Mobley, Director Division of Radiological Health T.E.R.R.A. Building, 6th Floor 150 9th Avenue North Nashville, Tennessee 37219-5404

Dr. Henry Myers, Science Advisor Committee on Interior and Insular Affairs U.S. House of Representatives Washington, D.C. 20515

Tennessee Valley Authority Rockville Office 11921 Rockville Pike Suite 402 Rockville, Maryland 20852



8905120264 890504 PDR ADOCK 050003

UNITED STATES UCLEAR REGULATORY COMMISSI WASHINGTON, D. C. 20555

TENNESSEE VALLEY AUTHORITY

DOCKET NO. 50-327

SEQUOYAH NUCLEAR PLANT, UNIT 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 113 License No. DPR-77

- 1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Tennessee Valley Authority (the licensee) dated May 2, 1989, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

- 2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C.(2) of Facility Operating License No. DPR-77 is hereby amended to read as follows:
 - (2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No.113, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

B. D. Liaw, Director

TVA Projects Division Office of Nuclear Reactor Regulation

Attachment: Technical Specifications Changes

Date of Issuance: May 4,1989

ATTACHMENT TO LICENSE AMENDMENT NO. 113

FACILITY OPERATING LICENSE NO. DPR-77

DOCKET NO. 50-327

Revise the Appendix A Technical Specifications by removing the pages identified below and inserting the enclosed pages. The revised pages are identified by the captioned amendment number and contain marginal lines indicating the area of change. Overleaf pages* are provided to maintain document completeness.

REMOVE	INSERT
3/4 3-51	3/4 3-51
3/4 3-52	3/4 3-52*
3/4 3-53	3/4 3-53
3/4 3-54	3/4 3-54*

TABLE 3.3-9

REMOTE SHUTDOWN MONITORING INSTRUMENTATION

- UNIT	INS	STRUMENT	READOUT LOCATION	MEASUREMENT RANGE	MINIMUM CHANNELS OPERABLE
щ	1.	Source Range Nuclear Flux	NOTE 1	1 to 1 x 10 ⁶ cps	1
	2.	Reactor Trip Breaker Indication	at trip switchgear	OPEN-CLOSE	l/trip breaker
	3.	Reactor Coolant Temperature - Hot Leg	NOTE 1	0-650°F	1/loop
	4.	Pressurizer Pressure	NOTE 1	0-3000 psig	1
3/4	5.	Pressurizer Level	NOTE 1	0-100%	1
ω - 5	6.	Steam Generator Pressure	NOTE 1	0-1200 psig	l/steam generator
┝╾┙	7.	Steam Generator Level	NOTE 2 or near Auxilary F. W. Pump	0-100%	l/steam generator
	8.	Deleted	•		·/ · · · · · · · · · · · · · · · · · ·
	9.	RHR Flow Rate	NOTE 1	0-4500 gpm	1
	10.	RHR Temperature	NOTE 1	50-400°F	1
	11.	Auxiliary Feedwater Flow Rate	NOTE 1	0-440 gpm	1/steam generator

TABLE 3.3-9 (Continued)

REMOTE SHUTDOWN MONITORING INSTRUMENTATION

SEQUOY,	REMOTE SHUTDOWN MONITORING INSTRUMENTATION							
AH - UNIT	INST	RUMENT	READOUT LOCATION	MEASUREMENT RANGE	MINIMUM CHANNELS OPERABLE			
н Н	12.	Pressurizer Relief Tank Pressure	NOTE 1	0-100 psig	1			
	13.	Containment Pressure	NOTE 1	-1 to +15 psig	1			
	NOTE	1: Auxiliary Control Room Panel	1-L-10					

NOTE 2: Auxiliary Control Room Panels 1-L-11A and 1-L-11B

TABLE 4.3-6

REMOTE SHUTDOWN MONITORING INSTRUMENTATION SURVEILLANCE REQUIREMENTS

- UN	INS	TRUMENT	CHANNEL CHECK	CHANNEL CALIBRATION
IT 1	1.	Source Range Nuclear Flux	М	R
	2.	Reactor Trip Breaker Indication	Μ	N.A.
	3.	Reactor Coolant Temperature - Hot Leg	м	R
	4.	Pressurizer Pressure	M	R
	5.	Pressurizer Level	М	R
3/4	6.	Steam Generator Pressure	Μ	R
ω-5 5	7.	Steam Generator Level	м	R
ພິ	8.	Deleted		
	9.	RHR Flow Rate	М	R
	10.	RHR Temperature	м	R
	11.	Auxiliary Feedwater Flow Rate	М	R
	12.	Pressurizer Relief Tank Pressure	м	R
	13.	Containment Pressure	М	R

SEQUOYAH - UNIT 1

CHLORINE DETECTION SYSTEMS

LIMITING CONDITION FOR OPERATION

This specification deleted.



UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

TENNESSEE VALLEY AUTHORITY

DOCKET NO. 50-328

SEQUOYAH NUCLEAR PLANT, UNIT 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No.103 License No. DPR-79

- 1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Tennessee Valley Authority (the licensee) dated May 2, 1989, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

- 2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C.(2) of Facility Operating License No. DPR-79 is hereby amended to read as follows:
 - (2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. $_{103}$, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

mar

B. D. Liaw, Director → TVA Projects Division Office of Nuclear Reactor Regulation

Attachment: Technical Specifications Changes

Date of Issuance: May 4, 1989

- 2 -

ATTACHMENT TO LICENSE AMENDMENT NO. 103

FACILITY OPERATING LICENSE NO. DPR-79

DOCKET NO. 50-328

Revise the Appendix A Technical Specifications by removing the pages identified below and inserting the enclosed pages. The revised pages are identified by the captioned amendment number and contain marginal lines indicating the area of change. Overleaf pages* are provided to maintain document completeness.

REMOVE	INSERT		
3/4 3-51	3/4 3-51*		
3/4 3-52	3/4 3-52		
3/4 3-54	3/4 3-54		

ı.

INSTRUMENTATION

REMOTE SHUTDOWN INSTRUMENTATION

LIMITING_CONDITION FOR OPERATION

3.3.3.5 The remote shutdown monitoring instrumentation channels shown in Table 3.3-9 shall be OPERABLE with readouts displayed external to the control room.

APPLICABILITY: MODES 1, 2 and 3.

ACTION:

- a. With the number of OPERABLE remote shutdown monitoring channels less than required by Table 3.3-9, restore the inoperable channel(s) to OPERABLE status within 7 days, or be in HOT SHUTDOWN within the next 12 hours.
- b. The provisions of Specification 3.0.4 are not applicable.

SURVEILLANCE REQUIREMENTS

4.3.3.5 Each remote shutdown monitoring instrumentation channel shall be demonstrated OPERABLE by performance of the CHANNEL CHECK and CHANNEL CALIBRATION operations at the frequencies shown in Table 4.3-6.

TABLE 3.3-9

REMOTE SHUTDOWN MONITORING INSTRUMENTATION

	INS	TRUMENT	READOUT LOCATION	MEASUREMENT RANGE	MINIMUM CHANNELS OPERABLE
	1.	Source Range Nuclear Flux	NOTE 1	1 to 1 x 10 ⁶ cps	1
	2.	Reactor Trip Breaker Indication	at trip switchgear	OPEN-CLOSE	1/trip breaker
	3.	Reactor Coolant Temperature - Hot Leg	NOTE 1	0-650°F	1/loop
	4.	Pressurizer Pressure	NOTE 1	0-3000 psig	1
	5.	Pressurizer Level	NOTE 1	0-100%	1
) 1	6.	Steam Generator Pressure	NOTE 1	0-1200 psig	1/steam generator
	7.	Steam Generator Level	NOTE 2 or near Auxilary F. W. Pump	0-100%	l/steam generator
	8.	Deleted			
	9.	RHR Flow Rate	NOTE 1	0-4500 gpm	1
	10.	RHR Temperature	NOTE 1	50-400°F	1
	11.	Auxiliary Feedwater Flow Rate	NOTE 1	0-440 gpm	l/steam generator

SEQUOYAH - UNIT 2

T	A	B	L	E	4	 3-	6

REMOTE SHUTDOWN MONITORING INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>INS</u>	RUMENT	CHANNEL CHECK	CHANNEL CALIBRATION
1.	Source Range Nuclear Flux	м	R
2.	Reactor Trip Breaker Indication	м	N.A.
3.	Reactor Coolant Temperature - Hot Leg	м	R
4.	Pressurizer Pressure	м	R
5.	Pressurizer Level	м	R
6.	Steam Generator Pressure	м	R
7.	Steam Generator Level	M	R
8.	Deleted		
9.	RHR Flow Rate	м	R
10.	RHR Temperature	м	R
11.	Auxiliary Feedwater Flow Rate	м	R
12.	Pressurizer Relief Tank Pressure	М	R
13.	Containment Pressure	м	R

4

UNITED STATES WUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555



ENCLOSURE 3

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION

SUPPORTING AMENDMENT NO. 113 TO FACILITY OPERATING LICENSE NO. DPR-77

AND AMENDMENT NO. 103 TO FACILITY OPERATING LICENSE NO. DPR-79

TENNESSEE VALLEY AUTHORITY

SEQUOYAH NUCLEAR PLANT, UNITS 1 AND 2

DOCKET NOS. 50-327 AND 50-328

1.0 INTRODUCTION

By submittal dated May 2, 1989, the Tennessee Valley Authority (TVA) proposed to modify the Sequoyah Nuclear Plant (SQN), Units 1 and 2 Technical Specifications (TS) to revise Table 3.3-9, "Remote Shutdown Monitoring Instrumentation," and Table 4.2-6, "Remote Shutdown Monitoring Instrumentation Surveillance Requirements." The proposed change deletes the requirements for full-length control rod position limit switches (Item 8) from these tables. A footnote on Table 4.2-6 (Unit 2) is also proposed to be deleted. TVA has determined that the remote rod bottom indications currently required by TS Limiting Condition for Operation (LCO) 3.3.3.5 are not needed to achieve and maintain the SQN units in a safe shutdown condition.

The need for these proposed TS changes to be processed by the staff on an emergency basis was due to the fact that the Unit 1 full-length control rod E-13 was declared inoperable because of voltage fluctuations in the associated analog rod position indication (RPI) instrument channel. SQN, Unit 1 is currently at approximately 100 percent power. Since the remote rod bottom indication has been declared inoperable, SQN, Unit 1 has entered TS LCO 3.3.3.5, and the instrumentation must be repaired within seven days or the unit must shutdown. As stated above, TVA has determined that this instrumentation is not needed for remote safe shutdown; therefore, rather than force the shutdown of Unit 1 to effect repairs, TVA has submitted the proposed TS changes to delete the Operability and Surveillance Requirements for this equipment.

2.0 EVALUATION

8905120265 890504 PDR ADOCK 05000327

As described above, TVA has proposed to delete from TS Table 3.3-9, Item 8, "Instrument, Full Length Control Rod Position Limit Switches" and its associated Readout Location, Measurement Range, and Minimum Channels Operable. TVA has also proposed to delete Item 8 from TS Table 4.3-6, the Instrument, Channel Check, and Channel Calibration which are the TS Surveillance Requirements for the same instrument. As TVA has described in their submittal referenced above, the purpose of the remote shutdown instrumentation is to ensure sufficient capability to achieve and maintain a unit in a safe shutdown condition from outside the main control room. TVA has determined that the rod bottom indications located in the auxiliary instrument room (racks R41-44) are not required to achieve this purpose.

Abnormal Operating Instruction (AOI) 27, "Control Room Inaccessibility," provides procedural guidance to SQN operations personnel regarding appropriate actions to be taken in the event that the main control room must be abandoned. Part A of AOI-27 specifically addresses the appropriate actions if either or both units are at power. Immediate operator Actions (Step III.A) states, that when it is decided that the main control room must be abandoned, the reactor is to be tripped in accordance with emergency instructions.

Emergency Instructions (E or ES), 0, "Reactor Trip or Safety Injection," provides the actions necessary to verify the proper responses following a manual or automatic reactor trip. Immediate Action 1 of E-O verifies that the reactor is tripped. This is accomplished by verifying that the rod bottom lights in the main control room are on, the reactor trip breakers are open, the rod position indication (RPI) instruments indicate zero steps, and the neutron flux is decreasing. The combination of all these indications provides assurance that the reactor has been shutdown. If the verification of the above four steps indicates that the reactor has not tripped, the operator is instructed by procedure to initiate boration to the core. Emergency boration is also initiated for the case in which any control rod is not verified to be fully inserted.

The procedural steps described above provide the necessary action to ensure that the reactor is shut down before the control room is abandoned. The remote rod bottom indications located in the auxiliary instrument room are not relied upon to achieve shutdown of the reactor.

AOI-27 also provides the guidance for maintaining the unit in hot standby and for taking the unit to cold shutdown. Again, the remote rod bottom indicators located in the auxiliary instrument room are not relied upon. The remote reactor trip breaker position indicators provide a status of the rod drive system's ability to move rods. The source range indication in the auxiliary control room provides an indication of anomalies in this neutron flux after the unit is tripped. Should any anomalies arise, boration control is still available outside the control room.

In summary, TVA has concluded that the rod bottom indicators located in the auxiliary instrument room are not required or used to achieve or maintain the SQN units shutdown from outside the main control room. TVA has stated that shutdown is achieved and verified from the main control room before it is abandoned. The staff has evaluated the proposed TS changes and has found that the rod bottom indicators are not referenced in Section 7.4 of the SQN Final Safety Analysis Report (FSAR) as equipment required to achieve and maintain safe shutdown and, therefore, are not required equipment needed to mitigate the SQN FSAR Chapter 15 accidents. As such, their deletion from the TS does not

e ...

alter the conclusions of the SQN Safety Evaluation Report (NUREG-0011) and the rod bottom indicators are, therefore, not required to meet the intent of TS 3.3.3.5.

The staff has concluded that the proposed TS deletions for remote rod bottom indication from Tables 3.3-9 and 4.3-6 is acceptable. The staff also notes that TVA has proposed to delete an expired footnote on TS Table 4.3-6 for purposes of clarity and completeness. The staff has evaluated this proposed deletion and has concluded that this change is purely administrative in nature, adds clarity to TS Table 4.3-6, in no way affects safety, and is, therefore, acceptable.

3.0 FINAL NO SIGNIFICANT HAZARDS CONSIDERATION DETERMINATION

The State of Tennessee was informed by telephone on May 3, 1989, of the staff's no significant hazards consideration determination. The State contact has no comments on the determination.

TVA has evaluated the proposed technical specification (TS) change and has determined that it does not represent a significant hazards consideration based on criteria established in 10 CFR 50.92(c). Operation of SQN in accordance with the proposed amendment will not:

(1) Involve a significant increase in the probability or consequences of an accident previously evaluated. The rod control system, as described in Final Safety Analysis Report (FSAR) Section 7.7, provides for reactor power modulation by manual or automatic control of full-length control rod banks. The RPI system provides a direct continuous readout of each control rod assemblies' position. This position indication is produced for each control assembly by a linear variable transformer. A rod bottom indication is also provided for each RPI channel.

The proposed change to the SON TS is to delete the requirements for the remote rod bottom instrumentation. The bases for Specification 3.3.3.5 state that the remote shutdown instrumentation is provided to achieve and maintain a plant shutdown from outside the control room. The SON procedures that would be used for control room abandonment do not rely upon the remote rod bottom indicators to achieve or maintain safe shutdown of the unit. Because the remote rod bottom indicators are not assumed to be the cause of a previously evaluated accident, their deletion from Tables 3.3-9 and 4.3-6 will not increase the probabilities of such accidents. Because the remote rod bottom indicators are not used to determine operator responses, their deletion will not alter plant responses to previously evaluated accidents, and the consequences of such accidents are not increased. The deletion of the Unit 2 footnote is an administrative change made for clarity and completeness, and as such, will not increase the probability or consequences of any previously evaluated accident.

- (2) Create the possibility of a new or different kind of accident from any previously analyzed. As described above, the proposed change deletes instrumentation from Tables 3.3-9 and 4.3-6 that is not required or relied upon to achieve and maintain a plant shutdown from outside the main control room. No changes are being made to the rod control system. The system will continue to function as previously evaluated. Because the remote rod bottom indicators are not currently relied upon or required, the plant response for control room abandonment remains unchanged. The deletion of the Unit 2 footnote is made for completeness and is administrative in nature. Therefore, the proposed changes to Tables 3.3-9 and 4.3-6 do not create the possibility of a new or different kind of accident from any previously analyzed.
- Involve a significant reduction in the margin of safety. The (3) bases of Specification 3.3.3.5 state that the remote shutdown instrumentation ensures the capability to permit shutdown, maintenance of hot standby conditions, and the potential for subsequent cold shutdown from outside the main control room. Because the remote rod bottom indicators are not currently relied upon in control [room] abandonment or reactor trip response procedures, their deletion from Tables 3.3-9 and 4.3-6 does not impact the remote shutdown capabilities at SON; and compliance with 10 CFR 50 General Design Criterion 19 is maintained. The rod bottom indicators are not discussed in FSAR Section 7.4 as being necessary equipment to achieve safe shutdown. Their deletion from the TSs does not alter the boration or residual heat removal systems required to ensure safe shutdown capabilities. As such, the conclusions drawn in Section 7.4 of the SQN Safety Evaluation Report (NUREG-0011) are not changed, and compliance with Table 7-1 of the Standard Review Plan is maintained. The Unit 2 footnote deletion is administrative in nature and made for clarity and completeness. Therefore, the proposed changes do not reduce the margin of safety.

The staff has reviewed TVA's evaluation and agrees that the proposed TS changes do not represent a significant hazards consideration.

4.0 FINDINGS OF EMERGENCY WARRANTING AN AMENDMENT WITHOUT NOTICE

The licensee's application for the TS change has been timely. The licensee stated that on April 29, 1989, the rod bottom circuitry for Unit 1 was declared inoperable because of voltage fluctuations in the analog RPI instrument channel. Failure to have remote shutdown instrumentation for full-length control rod position indication resulting from this unanticipated failure of the RPI would cause a shutdown of Sequoyah, Unit 1 as currently required by TS 3.3.3.5.

The staff concurs that failure to grant the proposed changes in a timely manner would cause a shutdown of Sequoyah, Unit 1. We find that the licensee could not reasonably have avoided the situation, that the licensee has responded in a timely manner, and has not delayed its application to take advantage of the Emergency License Amendments provision of 10 CFR 50.91. Furthermore, since the staff agrees that the remote rod bottom indicators are not required to meet the underlying purpose of TS 3.3.3.5 and the TS are the same for both units, it is desirable to change both sets of TS at the same time. Accordingly, the staff concludes that the licensee has satisfied the requirements of 10 CFR 50.91(a)(5), and that a valid emergency exists.

5.0 ENVIRONMENTAL CONSIDERATION

These amendments involve changes to a requirement with respect to the installation or use of a facility component located within the restricted areas as defined in 10 CFR Part 20 and changes to the surveillance requirements. The staff has determined that amendments involve no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has made a final no significant hazards consideration finding with respect to these amendments. Accordingly, the amendments meet the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(C)(9). Pursuant to 10 CFR 51.22(b), neither environmental impact statement nor environmental assessment needs to be prepared in connection with the issuance of the amendments.

6.0 CONCLUSION

We have concluded, based on the considerations discussed above, that: (1) the amendments do not (a) significantly increase the probability or consequences of an accident previously evaluated, (b) create the possibility or a new or different kind of accident from any previously evaluated or, (c) significantly reduce a safety margin and, therefore, the amendments do not involve significant hazards consideration; (2) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and (3) such activities will be conducted in compliance with the Commission's regulations, and the issuance of these amendments will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributor: T. Rotella

Dated May 4, 1989