January 22, 1989

Docket Nos. 50-327/328

Dear Mr. Kingsley:

Mr. Oliver D. Kingsley, Jr. Senior Vice President, Nuclear Power Tennessee Valley Authority 6N 38A Lookout Place 1101 Market Street Chattanooga, TN 37402-2801 DISTRIBUTION Docket File NRC PDR Local PDR JPartlow BDLiaw SBlack JDonohew FMcCoy DCrutchfield EJordan ARM/LFMB

SON Rd. File GPA/CA TMeek(8) GPA/PA ACRS(10) EButcher **OSP** Reading Projects Reading JRutberg **MSimms** WJones DHagan

- SUBJECT: CORRECTIONS TO AMENDMENT NO. 80 (TS 88-18) TAC R00457, AMENDMENT
  - NOS.92 AND 82 (TS 87-27) TAC R00203/R00204
- 1. In Amendment No. 80 to Facility Operating License DPR-79 for Sequoyah, Unit 2, the footnote change was incorrectly stated. It should read as follows:

\*One time extension to be performed no later than Unit 2, Cycle 3 refueling outage or January 22, 1989, whichever occurs first.

A corrected page is enclosed.

2. In Amendment Nos. 92 and 82 to Facility Operating License DPR-77 and DPR-79, for Sequoyah, Units 1 and 2, respectively, the licensee submittal page with pen and ink changes were inadvertently transmitted as actual TS pages. A revised TS page for each unit is enclosed.

We apologize for any inconvenience caused by these omissions. If you have any questions please contact Jack Donohew, Sequoyah Project Manager (301-492-0704).

Sincerely,

Original signed by

Suzanne Black, Assistant Director for Projects TVA Projects Division Office of Nuclear Reactor Regulation

Enclosures: 1. TS pg. 3/4 6-27 (Unit 2) 2. TS pg. 3/4 5-6 (Units 1&2)

cc w/enclosures: See next page

OFC	ADSPATIANA	: ADSP/ WAYPM	:ASSP/AD/TP	:ADSP/AD/P		•	
NAME	MStimms	: JDo Minew	:RPiecon	:SBlack		•	• •
DATE	1/ 1/89	:1/19/89	1 /89	:1/22/89			· · · · · · · · · · · · · · · · · · ·
	OFFICIAL	RECORD COPY			DFOI		UDA1
	, <u> </u>	8901250331 PDR ADOCK P	820122 85000327 PDC		1/1		lp.N.

Mr. Oliver D. Kingsley, Jr.

cc: General Counsel Tennessee Valley Authority 400 West Summit Hill Drive E11 B33 Knoxville, Tennessee 37902

Mr. R. L. Gridley Tennessee Valley Authority 5N 157B Lookout Place Chattanooga, Tennessee 37402-2801

Mr. John T. LaPoint Tennessee Valley Authority Sequoyah Nuclear Plant P.O. Box 2000 Soddy Daisy, Tennessee 37379

Mr. M. Ray Tennessee Valley Authority Sequoyah Nuclear Plant P.O. Box 2000 Soddy Daisy, Tennessee 37379

Mr. D. L. Williams Tennessee Valley Authority 400 West Summit Hill Drive W10 B85 Knoxville, Tennessee 37902

County Judge Hamilton County Courthouse Chattanooga, Tennessee 37402 -2- Sequoyah Nuclear Plant

Regional Administrator, Region II U.S. Nuclear Regulatory Commission 101 Marietta Street, N.W. Atlanta, Georgia 30323

Resident Inspector/Sequoyah NP c/o U.S. Nuclear Regulatory Commission 2600 Igou Ferry Road Soddy Daisy, Tennessee 37379

Mr. Michael H. Mobley, Director Division of Radiological Health T.E.R.R.A. Building, 6th Floor 150 9th Avenue North Nashville, Tennessee 37219-5404

Dr. Henry Myers, Science Advisor Committee on Interior and Insular Affairs U.S. House of Representatives Washington, D.C. 20515

Tennessee Valley Authority Rockville Office 11921 Rockville Pike Suite 402 Rockville, Maryland 20852

### CONTAINMENT SYSTEMS

## 3/4.6.5 ICE CONDENSER

ICE BED

## LIMITING CONDITION FOR OPERATION

- 3.6.5.1 The ice bed shall be OPERABLE with:
  - a. The stored ice having a boron concentration of at least 1800 ppm boron as sodium tetraborate and a pH of 9.0 to 9.5,
  - b. Flow channels through the ice condenser,
  - c. A maximum ice bed temperature of less than or equal to  $27^{\circ}$ F,
  - d. A total ice weight of at least 2,333,100 pounds at a 95% level of confidence, and
  - e. 1944 ice baskets.

APPLICABILITY: MODES 1, 2, 3 and 4.

### ACTION:

With the ice bed inoperable, restore the ice bed to OPERABLE status within 48 hours or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

#### SURVEILLANCE REQUIREMENTS

- 4.6.5.1 The ice condenser shall be determined OPERABLE:
  - a. At least once per 12 hours by using the ice bed temperature monitoring system to verify that the maximum ice bed temperature is less than or equal to 27°F.
  - b. At least once per 6 months during the first 2 years following initial criticality and at least once per 12 months\* thereafter by:
    - 1. Chemical analyses which verify that at least 9 representative samples of stored ice have a boron concentration of at least 1800 ppm as sodium tetraborate and a pH of 9.0 to 9.5 at 20°C.

8901250466 890122 PDR ADOCK 0500032

One time extension to be performed no later than Unit 2, Cycle 3 refueling outage or January 22, 1989, whichever occurs first.

# EMERGENCY CORE COOLING SYSTEMS (ECCS)

## SURVEILLANCE REQUIREMENTS (Continued)

Valve Number		Valve Function Va	Valve Position	
a.	FCV-63-1	RHR Suction from RWST	open	
b.	FCV-63-22	SIS Discharge to Common Piping		

- b. At least once per 31 days by:
  - 1. Verifying that the ECCS piping is full of water by venting the ECCS pump casings and accessible discharge piping high points, and
  - Verifying that each valve (manual, power operated or automatic) in the flow path that is not locked, sealed, or otherwise secured in position, is in its correct position.
- c. By a visual inspection which verifies that no loose debris (rags, trash, clothing, etc.) is present in the containment which could be transported to the containment sump and cause restriction of the pump suctions during LOCA conditions. This visual inspection shall be performed:
  - 1. For all accessible areas of the containment prior to . establishing CONTAINMENT INTEGRITY, and
  - Of the areas affected within containment at the completion of each containment entry when CONTAINMENT INTEGRITY is established.
- d. At least once per 18 months by:
  - 1. Verifying automatic isolation and interlock action of the RHR system from the Reactor Coolant System when the Reactor Coolant System pressure is above 700 psig.
  - 2. A visual inspection of the containment sump and verifying that the subsystem suction inlets are not restricted by debris and that the sump components (trash racks, screens, etc.) show no evidence of structural distress or corrosion.
- e. At least once per 18 months, during shutdown, by:
  - 1. Verifying that each automatic valve in the flow path actuates to its correct position on a safety injection test signal and automatic switchover to containment sump test signal.

## EMERGENCY CORE COOLING SYSTEMS

## SURVEILLANCE REQUIREMENTS (Continued)

Valve Number		Valve Function Va	Valve Position	
a.	FCV-63-1	RHR Suction from RWST	open	
b.	FCV-63-22	SIS Discharge to Common Piping	open	

- b. At least once per 31 days by:
  - 1. Verifying that the ECCS piping is full of water by venting the ECCS pump casings and accessible discharge piping high points, and
  - 2. Verifying that each valve (manual, power operated or automatic) in the flow path that is not locked, sealed, or otherwise secured in position, is in its correct position.
- c. By a visual inspection which verifies that no loose debris (rags, trash, clothing, etc.) is present in the containment which could be transported to the containment sump and cause restriction of the pump suctions during LOCA conditions. This visual inspection shall be performed:
  - 1. For all accessible areas of the containment prior to establishing . CONTAINMENT INTEGRITY, and
  - 2. Of the areas affected within containment at the completion of each containment entry when CONTAINMENT INTEGRITY is established.
- d. At least once per 18 months by:
  - 1. Verifying automatic isolation and interlock action of the RHR system from the Reactor Coolant System when the Reactor Coolant System pressure is above 700 psig.
  - 2. A visual inspection of the containment sump and verifying that the subsystem suction inlets are not restricted by debris and that the sump components (trash racks, screens, etc.) show no evidence of structural distress or corrosion.
- e. At least once per 18 months, during shutdown, by:
  - 1. Verifying that each automatic valve in the flow path actuates to its correct position on a safety injection test signal and automatic switchover to containment sump test signal.