Docket Nos. 50-327/32%

Dear Mr. Kingsley:

Mr. Oliver D. Kingsley, Jr. Senior Vice President, Nuclear Power Tennessee Valley Authority 6N 38A Lookout Place 1101 Market Street Chattanooga, Tennessee 37402-2801 Distribution Docket File NRC PDR Local PDR ADSP Reading DCrutchfield BDLiaw SBlack JDonohew EJordan ARM/LFMB GPA/PA

GPA/CA ACRS(10) EButcher Projects Rdg. JRutberg MSimms WJones DHagan TMeek(8) SQN Rdg.

BWilson LWatson JBrady OGC

SUBJECT: CORRECTIONS TO AMENDMENT NOS. 97 AND 86 (TS 87-45 AND 88-08) (TAC NOS. R00293/R00294/R00423 AND R00424) AND TO AMENDMENT NO. 101 (TS 88-25) (TAC NO. R00502) - SEQUOYAH NUCLEAR PLANT, UNITS 1 AND 2

This letter provides new pages for the Sequoyah Nuclear Plant, Units 1 and 2, Technical Specifications (TS) for the following corrections:

- In Amendment No. 97, dated January 22, 1989, to Facility Operating License DPR-77 for Sequoyah, Unit 1, Pages 3/4 3-62 and 3-67 were issued without one change on each page proposed in the applications.
- In Amendment No. 86, dated January 22, 1989, to Facility Operating License DPR-79 for Sequoyah, Unit 2, Pages 3/4 3-63, 3-64, 3-66 and 3-67 were issued without a change on each page proposed in the applications.
- 3. In Amendment No. 101, dated April 3, 1989, to Facility Operating License DPR-79 for Sequoyah, Unit 2, Page 3/4 4-8 was issued without an "(s)" on a reference to PORVs and solenoid valve(s) in Action Statement d, as was issued for Unit 1.

Enclosed are the following corrected TS pages: Pages 3/4 3-62 and 3-67 for Unit 1 and Pages 3/4 3-63, 3-64, 3-66, 3-67 and 4-8 for Unit 2.

Sincerely,

Original signed by Rajender Auluck

for Suzanne Black, Assistant Director for Projects TVA Projects Division Office of Nuclear Reactor Regulation

cc: See next p	age		OFOL	
8905080329 890 PDR ADOCK 050 P	0501 000327 PDC 0		<i>,</i> /1	 CSAN
OFC :NRR: TVA/LA :NRR: TV	ACPM : HA APAP	:		 
NAME :MSimms NED : Doneh	new:as :SBlack			 
DATE 4/10/89 4/- /8	9 :4/1 /89			 
OFFICIAL RECORD	COPY 1			

Mr. Oliver D. Kingsley, Jr.

cc: General Counsel Tennessee Valley Authority 400 West Summit Hill Drive Ell B33 Knoxville, Tennessee 37902

Mr. C. H. Fox Tennessee Valley Authority 5N 157B Lookout Place Chattanooga, Tennessee 37402-2801

Mr. John T. LaPoint Tennessee Valley Authority Sequoyah Nuclear Plant P.O. Box 2000 Soddy Daisy, Tennessee 37379

Mr. M. Burzynski Tennessee Valley Authority Sequoyah Nuclear Plant P.O. Box 2000 Soddy Daisy, Tennessee 37379

Mr. D. L. Williams Tennessee Valley Authority 400 West Summit Hill Drive W10 B85 Knoxville, Tennessee 37902

County Judge Hamilton County Courthouse Chattanooga, Tennessee 37402 Regional Administrator, Region II U.S. Nuclear Regulatory Commission 101 Marietta Street, N.W. Atlanta, Georgia 30323

Resident Inspector/Sequoyah NP c/o U.S. Nuclear Regulatory Commission 2600 Igou Ferry Road Soddy Daisy, Tennessee 37379

Mr. Michael H. Mobley, Director Division of Radiological Health T.E.R.R.A. Building, 6th Floor 150 9th Avenue North Nashville, Tennessee 37219-5404

Dr. Henry Myers, Science Advisor Committee on Interior and Insular Affairs U.S. House of Representatives Washington, D.C. 20515

Tennessee Valley Authority Rockville Office 11921 Rockville Pike Suite 402 Rockville, Maryland 20852

<b>1</b>			TABLE 3.3-11 (	Continued)		
	R R R R R		FIRE DETECTION	INSTRUMENTS		
	Fire ⊅∞ Zone D∞	Instrument Location	<u>Min</u> Ionization	imum Instrument <u>Photoelectric</u>	s Operable	e Infrared
	80 81 00	Charging Pump Rm. 1B, El. 669 Charging Pump Rm. 1A, El. 669	1			
I	88 000	Aux. Bldg. Corridor A1-A8,	8			
	89 200	Aux. Bldg. Corridor A1-A8, Fl. 669	8			
	90	Aux. Bldg. Corridor A8-A15, El. 669	8			
	91	Aux. Bldg. Corridor A8-A15, El. 669	8			
,	92	Aux. Bldg. Corridor Col. U-W El. 669	4			
	93	Aux. Bldg. Corridor Col. U-W, El. 669	4			
1	94 95	Valve Galley, El. 669 Valve galley, El. 669	2 2			
	98 99	Cntmt Purge Air Fltr., El. 690 Cntmt Purge Air Fltr. El. 690		2 2	2 2	
	102 103	Pipe Gallery, El. 690 Pipe Gallery, El. 690	4 4			
	106 107	Aux. Building, El. 690 Aux. Building, El. 690	8 8			
	108	Radio Chemical Lab. Area, El. 690	3			
	109	Radio Chemical Lab. Area, El. 690	3			
	110	Aux. Bldg. A1-A8, Col. Q-U, E1. 690	10			
	111	Aux. Bldg. A1-A8, Col. Q-U El. 690	10			
	112	Aux. Bldg. A8-A15, Col. Q-U El. 690	9			
I	113	Aux. B1dg. A8-A15, Col. Q-U El. 690	9			
	114	Waste Packaging Area El. 706	3			

• •

,

.

SEQUOYAH - UNIT 1

3/4 3-62

Amendment No. 97

1

# FIRE DETECTION INSTRUMENTS

AH H	Fire		Min	imum Instrument	s Operabl	е
1	<u>Zone</u>	Instrument Location	Ionization	Photoelectric	Thermal	
NN	210	CD 51+~ A 51 722	1		7	
П	210	CR FILF. A EI. 732 CR FI+- A FI 732			1 1	
<u>ш</u>	219	UK FILF. A EL. 732 Mosim CD EL 732	L OF		1	
	220	Main UK El. 732 Tachainal Currant Cantan	25			
	221	El. 732	5			
	222	Technical Support Center, El. 732	5			
	225	Relay Bd. Rm. El. 732	13	<i>,</i>		
	226	Electric Cont. Bds. El. 732	11			
	227	Oper. Living Area El. 732	7		1	
	228	Oper. Living Area El. 732			8	
$\widetilde{\omega}$	229	Main Cont. Bds. El. 732	9		-	
4	230	Aux. CR Bds. L-4A, 4C, 11A &	9			
ယ္		10, E1, 734	_			
5	233	Ctrl. Rod Dr. Eapt. Rm. El. 759	4			
-	234	Ctrl. Rod Dr. Eqpt. Rm. El. 759	4			
	235	Ctrl. Rod Dr. Egpt. Rm. El. 759	4			
	236	Ctrl. Rod Dr. Eqpt. Rm. El. 759	4			
	237	Mech. Egpt. Rm. El. 749	1			
	238	Mech. Egpt. Rm. El. 749	1			
	239	Mech. Egpt. Rm. El. 749	2			
	240	Mech. Egpt. Rm. El. 749	2			
	241	480-V XFMR Rm. 1A E1. 749	3			
	242	480-V XFMR Rm. 1A E1. 749	3			
	243	480-V XFMR Rm. 1B E1. 749	3			
An	244	480-V XFMR Rm. 1B E1. 749	3			
คุ	245	480-V xfmr Rm. 2A El. 749	3			
đ	246	480-V xfmr Rm. 2A E1. 749	3			
ler	247	480-V xfmr Rm. 2B El. 749	3			
Ъ,	248	480-V xfmr Rm. 2B El. 749	3			
X	249	125-V Batt. Rm. I El. 749	1			
	250	125-V Batt. Rm. I El. 749	1			
20	251	125-V Batt. Rm. II El. 749	1.			
~	252	125-V Batt. Rm. II El. 749	1			
	253	125-V Batt. Rm. III El. 749	1			
	254	125-V Batt. Rm. III El. 749	1			

.

# FIRE DETECTION INSTRUMENTS

FIRE		Ň	INIMUM INSTRUMENTS	S OPERABLE	
<u>ZONE</u>	INSTRUMENT LOCATION	Ionization -	Photoelectric	Thermal	Infrared
110	Now Eucl Stonage Amon 51 700	0			
110	New Fuel Storage Area, EL. 706	2			
119	APOTE Filton F1 714	Z	1	-	
120	ADUIS FILLER, EL. 714 ADOTE Filton El 714			1 1	
121	ADUIS FILLER, EL. /14	C	Ţ	T	
122	Add. Eqpt. Bldg., El. 706 & 717.5	6			
124	Add. Equip. Bldg. El. 706	6			
126	ABGIS Rm., EL. /14	2			
127	ABGIS Rm., EI. /14	2			
128	ABGIS Rm., El. /14	2			
129	ABGIS Rm., El. 714	2			
130	Vent. & Purge Air Rm., El. 714	3			
131	Vent. & Purge Air Rm., El. 714	3			
132	Vent. & Purge Air Rm., El. 714	3			
133	Vent. & Purge Air Rm., El. 714	3			
134	Aux. Bldg. A5-A11, Col. U-W, E1. 714	7			
135	Aux. Bldg. A5-A11, Col. V-W, El. 714	7			
136	Heat. & Vent. Rm., E1. 714	4			
137	Heat. & Vent. Rm., El. 714	4			
138	Heat. & Vent. Rm., E1. 714	4			
139	Heat. & Vent. Rm. E1. 714	4			
140	Above Hot Instr. Rm., E1, 714	1			
141	Above Hot Instr. Rm., E1, 714	ī			
142	Aux, Bldg, Al-A8, Col. 0-U, F1, 714	12			
143	Aux B1dg, A1-A8, Co1, O-U, F1, 714	12			
144	Aux Bldg A8-A15 Col. $0-U$ F1. 714				
145	Aux Bldg A8-A15 Col $0-11$ F1 714	ğ			
146	No. Storage Area $F1 = 706$	4			
1/7	ABGTS Filton F1 714	•	1	1	
1/8	$\Delta RGTS Filtor F1 714$		1	1	
1/0	Cable Spreading Rm $C3-C7$ F1 706	15	+	-	
150	Cable Spreading Rm C2-C7 F1 706	15			
150	VCT $P_{0,0}$ and $P_{0,1}$ $P_{0,0}$ $P_{0,1}$ $P_{0,0}$ $P_{0,1}$ $P_{0,0}$ $P_{0,1}$ $P_{0,0}$ $P_{0,1}$ $P_{0,0}$ $P_{0,1}$ $P_{0,0}$ $P_{0,1}$ $P_{0,1$	+5 1			
101	$V_{\text{CT}} = 0$	⊥ 1			
197	VUI KUUM ZA, EI. 090	T			

SEQUOYAH - UNIT 2

3/4 3-63

Amendment No. 86

•

•

÷

# FIRE DETECTION INSTRUMENTS

FIRE		М	INIMUM INSTRUMENTS	S OPERABLE	
ZONE	INSTRUMENT LOCATION		Photoelectric	Thermal	Infrared
152	Add Four Bldg F1 740 5	Λ			
154	Add Equip Bldg F1 740.5	4			
155	Refuel Rm F1 734	19			
158	RB Access $Rm = F1 = 734$	2			
159	$\frac{RB}{RB} \text{ Access } Rm = F1 = 734$	2			
160	SG Riwdn Rm F1 734	<u>ک</u>			
161	SG Blwdn, Rm F1, 734	4			
162	EGTS Rm. E1. 734	3			
163	EGTS Rm. E1. 734	3			
164	EGTS Filter A. El. 734		1	2	
165	EGTS Filter A, E1. 734		1	2	
166	EGTS Filter B, El. 734		1	2	
167	EGTS Filter B, E1. 734		1	2	
172	Mech. Equip. Ŕm., El. 734	1			
173	Mech. Equip. Rm., El. 734	1			
174	Mech. Eqpt. Rm. E1. 734	1			
175	Mech. Eqpt. Rm. E1.734	1			
176	480-V SD Bd. Rm. 1A1, E1. 734	2			
177	480-V SD Bd. Rm. 1A1, E1. 734	2			
178	480-V SD Bd. Rm. 1A2, E1. 734	2			
179	480-V SD Bd. Rm. 1A2, E1. 734	2			
180	480-V SD Bd. Rm. 1B1, E1. 734	2			
181	480-V SD Bd. Rm. 1B1 E1. 734	2			
182	480-V SD Bd. Rm. 1B2 E1. 734	3			
183	480-V SD Bd. Rm. 1B2 E1. 734	3			
184	6.9KV SD Bd. Rm. A E1. 734	b			
185	6.9KV SD Bd. Rm. A E1. 734	b			
186	6.9KV SD Bd. Rm. B E1. 734	6			
187	6.9KV SD Bd. Rm. B E1. /34	b 2			
188	480-V SD Bd. Rm. 2A1 E1. 734	2			
189	48U-V SU BO. KM. 2A1 E1. 734	2			
190	480-7 SU BQ. KM. 2A2 E1. 734	э э			
191	480-V SD Ba. KM. ZAZ EI. 734	3			

3/4 3-64

Amendment No. 86

•

## FIRE DETECTION INSTRUMENTS

	FIRE		M	INIMUM INSTRUMENTS	OPERABLE	
-	ZONE	INSTRUMENT LOCATION	Ionization -	Photoelectric	Thermal	Infrared
4	227	Operator Living Area, E1. 732	7		1	
2	228	Operator Living Area, E1. 732			8	
	229	Main CR Bds., E1. 732	9			
	230	Aux. CR Bds. L-4A, 4C, 11A & 10, E1. 734	9			
	233	CRDM Eqpt. Rm., E1. 759	4			
	234	CRDM Eqpt. Rm., El. 759	4			
	235	CRDM Equip. Rm., E1. 759	4			
	236	CRDM Equip. Rm., E1. 759	4			
	237	Mech. Eqpt. Rm., E1. 749	1			
	238	Mech. Eqpt. Rm., El. 749	1			
د \	239	Mech. Eqpt. Rm., El. 749	2			
2	240	Mech. Eqpt. Rm., El. 749	2			
د	241	480-V XFMR Rm. 1A, E1. 749	3			
r r	242	480-V XFMR Rm. 1A, E1. 749	3			
	243	480-V XFMR Rm. 1B, E1. 749	3			
	244	480-V XFMR Rm. 1B, E1. 749	3			
	245	480-V XFMR Rm. 2A, E1. 749	3			
	246	480-V XFMR Rm. 2A, E1. 749	3			
	247	480-V XFMR Rm. 2B, E1. 749	3			
	248	480-V XFMR Rm. 2B, E1. 749	3			
	249	125-V Batt. Rm. I, E1. 749	1			
	250	125-V Batt. Rm. I, E1. 749	1			
>	251	125-V Batt. Rm. II, E1. 749	1			
	252	125-V Batt. Rm. II, E1. 749	1			
<u>_</u>	253	125-V Batt. Rm. III, E1. 749	1			
	254	125-V Batt. Rm. III, E1. 749	1			
F	255	125-V Batt. Rm. IV, E1. 749	1			
5	256	125-V Batt. Rm. IV, E1. 749	1			
	257	480-V Bd. Rm. 1B, E1. 749	4			
د د	258	480-V Bd. Rm. 1B, E1. 749	4			
-	259	480-V Bd. Rm. 1A, E1. 749	4			
S	260	480-V Bd. Rm. 1A, E1. 749	4			
•	261	480-V Bd. Rm. 2A, E1. 749	4			

3/4 3-66

Amendment No. 32, 86

•

.

# FIRE DETECTION INSTRUMENTS

FIRE		Μ	INIMUM INSTRUMENT	S OPERABLE	
ZONE	INSTRUMENT LOCATION	<u>Ionization</u>	Photoelectric	Thermal	Infrared
262	180-1/ Rd Pm 20 E1 740	Δ			
262	400  V Du. Rill. ZA, E1. 749 180-1/ Bd Dm 20 E1 740	4			
203	190 + 100 V Du. RM. 2D, E1. 749 190 + 100 Pm 2D E1 740	4			
267	Aux Inct $Dm = F1 + 695$	4			
207	Aux Inst. RH., EL. 000 Aux Inst. Dm. El 605	8		0	
200	Aux. 1150. Rul., E1. 000 Computer $Pm$ E1 E0E	Λ.		9	
203	Computer RM. E1. 000	4		4	
270	Aux Inct Dm E1 605	0		4	
271	Aux. Inst. Rm. E1, 000 Aux. Inst. $Pm$ E1 COE	ð		0	·
272	AUX. INSC. KIII. EI. 000 Computon Dm. Convidon El. COE	Э		9	
275	Intaka Dump Sta El 600 % 670 E	3			
270	$\begin{array}{c} \text{Intake Pump States} \\ \text{EPCM Dump States} \\ \text{EPCM Dump States} \\ \text{E1} \\ \text{704} \\ \text$	21 CL		0	
206	ERGW PUNIP Sta. EI, 704 Aux CD Ddo LaAD AD & 11D El 724	21		8	
290	Mux. UK DUS. $L^-4D$ , $4D$ , $\alpha$ IID EI. 734 Main CD Edg. EI. 732	D O			
297	Common MCD Pdc El 722	9			
230	Depaten Building Annulus	9	2		
- <u>-</u>	Reactor Building Annulus		3		
333	keactor Bullaing Annulus		4		
303	Lwr. Compt. Coolers, El. 693		4		
300	opr. compt. conters, E1. 778		4	n	
358	KUP 2 E1. 093			2	
359	RUP Z E1. 093			2	
362	KLY I EL. 693			2	
303	KLP 1 E1. 093			2	
366	RUP 3 E1. 693			2	
367	RLP 3 E1. 693			2	
370	RUP 4 E1. 693			2	
3/1	RCP 4 E1. 693		00	Z	
3/4	Reactor Building Annulus		20		
3/5	Reactor Building Annulus		13	10	
387	lurbine Cont. Bldg. Wall, El. 706	0		19	
42/	125-V Batt. Rm. V, E1. /49	Z			
428	125-V Batt. Rm. V, EI. /49	Z			

3/4 3-67

Amendment No. 32, 86

### REACTOR COOLANT SYSTEM

### RELIEF VALVES - OPERATING

### LIMITING CONDITION FOR OPERATION

3.4.3.2 All power operated relief valves (PORVs) and their associated block valves shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3.

#### ACTION:

- a. With one or more PORV(s) inoperable, but capable of RCS pressure control, within 1 hour either restore the PORV(s) to OPERABLE status or close the associated block valve(s); otherwise, be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.
- b. With one PORV inoperable and incapable of RCS pressure control, within 1 hour either restore the PORV to OPERABLE status or close the associated block valve and remove power from the block valve; restore the PORV to OPERABLE status within the following 72 hours or be in HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.
- c. With both PORVs inoperable and incapable of RCS pressure control, within 1 hour either restore each of the PORVs to OPERABLE status or close their associated block valves and remove power from the block valves and be in HOT STANDBY within the next 6 hours and COLD SHUTDOWN within the following 30 hours.
- d. With one or more block valve(s) inoperable, within 1 hour:
  (1) restore the block valve(s) to OPERABLE status, or close the block valve(s) and remove power from the block valve(s), or close the PORV(s) and remove power from its associated solenoid valve(s); and (2) apply the ACTION b. or c. above, as appropriate, for the isolated PORV(s).
- e. The provisions of Specification 3.0.4 are not applicable.

#### SURVEILLANCE REQUIREMENTS

4.4.3.2.1 In addition to the requirements of Specification 4.0.5, each PORV shall be demonstrated OPERABLE at least once per 18 months by:

- a. Performance of a CHANNEL CALIBRATION, and
- b. Operating the valve through one complete cycle of full travel.

4.4.3.2.2 Each block valve shall be demonstrated OPERABLE at least once per 92 days by operating the valve through one complete cycle of full travel.