

Tennessee Valley Authority
ATTN: Dr. Mark O. Medford, Vice President
Nuclear Assurance, Licensing & Fuels
3B Lookout Place
1101 Market Street
Chattanooga, Tennessee 37402-2801

Dear Dr. Medford:

SUBJECT: ISSUANCE OF AMENDMENTS (TAC NOS. M83545 AND M83546) (TS 92-03)

The Commission has issued the enclosed Amendment No.162 to Facility Operating License No. DPR-77 and Amendment No. 152 to Facility Operating License No. DPR-79 for the Sequoyah Nuclear Plant, Units 1 and 2, respectively. These amendments are in response to your application dated May 26, 1992.

The amendments remove the provision in Specification 4.0.2 that limits the combined time interval for three consecutive surveillance tests to less than 3.25 times the interval specified in the technical specifications for the surveillance test.

A copy of the Safety Evaluation is also enclosed. Notice of Issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

Original signed by

David E. LaBarge, Senior Project Manager
Project Directorate II-4
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No.162 to License No. DPR-77
2. Amendment No.152 to License No. DPR-79
3. Safety Evaluation

cc w/enclosures:
See next page

OFC:	PDII-4/LA	PDII-4/PM <i>W</i>	PDII-2/LPM	OGC <i>M. J.</i>	PDII-4/D
NAME:	MSanders <i>MS</i>	DLaBarge	HSilver	<i>M. Finkelstein</i>	FHebbon
DATE:	<i>7/24/92</i>	<i>7/24/92</i>	<i>1/92</i>	<i>7/28/92</i>	<i>8/12/92</i>

CP



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555

August 13, 1992

Docket Nos. 50-327
and 50-328

Tennessee Valley Authority
ATTN: Dr. Mark O. Medford, Vice President
Nuclear Assurance, Licensing & Fuels
3B Lookout Place
1101 Market Street
Chattanooga, Tennessee 37402-2801

Dear Dr. Medford:

SUBJECT: ISSUANCE OF AMENDMENTS (TAC NOS. M83545 AND M83546) (TS 92-03)

The Commission has issued the enclosed Amendment No. 162 to Facility Operating License No. DPR-77 and Amendment No. 152 to Facility Operating License No. DPR-79 for the Sequoyah Nuclear Plant, Units 1 and 2, respectively. These amendments are in response to your application dated May 26, 1992.

The amendments remove the provision in Specification 4.0.2 that limits the combined time interval for three consecutive surveillance tests to less than 3.25 times the interval specified in the technical specifications for the surveillance test.

A copy of the Safety Evaluation is also enclosed. Notice of Issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

David E. LaBarge, Senior Project Manager
Project Directorate II-4
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No. 162 to License No. DPR-77
2. Amendment No. 152 to License No. DPR-79
3. Safety Evaluation

cc w/enclosures:
See next page

9208200027 920813
PDR ADOCK 05000327
P PDR

DF.01
NRC FILE CENTER COPY

Tennessee Valley Authority
ATTN: Dr. Mark O. Medford

cc:

Mr. John B. Waters, Director
Tennessee Valley Authority
ET 12A
400 West Summit Hill Drive
Knoxville, Tennessee 37902

Mr. J. R. Bynum, Vice President
Nuclear Operations
3B Lookout Place
1101 Market Street
Chattanooga, Tennessee 37402-2801

Mr. M. J. Burzynski, Manager
Nuclear Licensing and Regulatory Affairs
Tennessee Valley Authority
5B Lookout Place
Chattanooga, Tennessee 37402-2801

Mr. Jack Wilson, Vice President
Sequoyah Nuclear Plant
Tennessee Valley Authority
P.O. Box 2000
Soddy Daisy, Tennessee 37379

TVA Representative
Tennessee Valley Authority
11921 Rockville Pike
Suite 402
Rockville, Maryland 20852

Ms. Marci Cooper, Site Licensing Manager
Sequoyah Nuclear Plant
Tennessee Valley Authority
P.O. Box 2000
Soddy Daisy, Tennessee 37379

Mr. Michael H. Mobley, Director
Division of Radiological Health
3rd Floor, L and C Annex
401 Church Street
Nashville, Tennessee 37243-1532

General Counsel
Tennessee Valley Authority
ET 11H
400 West Summit Hill Drive
Knoxville, Tennessee 37902

Sequoyah Nuclear Plant

County Judge
Hamilton County Courthouse
Chattanooga, Tennessee 37402

Regional Administrator
U.S.N.R.C. Region II
101 Marietta Street, N.W.
Suite 2900
Atlanta, Georgia 30323

Mr. William E. Holland
Senior Resident Inspector
Sequoyah Nuclear Plant
U.S.N.R.C.
2600 Igou Ferry Road
Soddy Daisy, Tennessee 37379

AMENDMENT NO. 162 FOR SEQUOYAH UNIT NO. 1 - DOCKET NO. 50-327 and
AMENDMENT NO. 152 FOR SEQUOYAH UNIT NO. 2 - DOCKET NO. 50-328
DATED: August 13, 1992

Distribution

Docket File

NRC PDR

Local PDR

SQN Reading File

S. Varga	14-E-4
F. Hebdon	
M. Sanders	
D. LaBarge	
B. Wilson	RII
W. Little	RII
OGC	15-B-13
D. Hagan	MNBB-3302
E. Jordan	MNBB-3302
G. Hill	P1-130 (8)
Wanda Jones	MNBB-7103
J. Calvo	14-E-4
ACRS(10)	
OPA	2-G-5
OC/LFMB	MNBB-9112
H. Silver	14-H-22



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555

TENNESSEE VALLEY AUTHORITY

DOCKET NO. 50-327

SEQUOYAH NUCLEAR PLANT, UNIT 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 162
License No. DPR-77

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Tennessee Valley Authority (the licensee) dated May 26, 1992, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

9208200035 920813
PDR ADOCK 05000327
P FDR

2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C.(2) of Facility Operating License No. DPR-77 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 162, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance, to be implemented within 30 days.

FOR THE NUCLEAR REGULATORY COMMISSION



Frederick J. Hebdon, Director
Project Directorate II-4
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: August 13, 1992

ATTACHMENT TO LICENSE AMENDMENT NO. 162

FACILITY OPERATING LICENSE NO. DPR-77

DOCKET NO. 50-327

Revise the Appendix A Technical Specifications by removing the pages identified below and inserting the enclosed pages. The revised pages are identified by the captioned amendment number and contain marginal lines indicating the area of change. Overleaf pages [*] are provided to maintain document completeness.

REMOVE

3/4 0-2
B3/4 0-3
B3/4 0-4*

INSERT

3/4 0-2
B3/4 0-3
B3/4 0-4*

APPLICABILITY

SURVEILLANCE REQUIREMENTS

4.0.1 Surveillance Requirements shall be met during the OPERATIONAL MODES or other conditions specified for individual Limiting Conditions for Operation unless otherwise stated in an individual Surveillance Requirement.

4.0.2 Each Surveillance Requirement shall be performed within the specified surveillance interval with a maximum allowable extension not to exceed 25 percent of the specified surveillance interval.

4.0.3 Failure to perform a Surveillance Requirement within the allowed surveillance interval, defined by Specification 4.0.2, shall constitute noncompliance with the OPERABILITY requirements for a Limiting Condition for Operation. The time limits of the ACTION requirements are applicable at the time it is identified that a Surveillance Requirement has not been performed. The ACTION requirements may be delayed for up to 24 hours to permit the completion of the surveillance when the allowable outage time limits of the ACTION requirements are less than 24 hours. Surveillance Requirements do not have to be performed on inoperable equipment.

4.0.4 Entry into an OPERATIONAL MODE or other specified condition shall not be made unless the Surveillance Requirement(s) associated with the Limiting Condition for Operation have been performed within the specified surveillance interval or as otherwise specified. This provision shall not prevent passage through or to OPERATIONAL MODES as required to comply with ACTION requirements.

4.0.5 Surveillance Requirements for inservice inspection and testing of ASME Code Class 1, 2 and 3 components shall be applicable as follows:

- a. Inservice inspection of ASME Code Class 1, 2 and 3 components and inservice testing of ASME Code Class 1, 2 and 3 pumps and valves shall be performed in accordance with Section XI of the ASME Boiler and Pressure Vessel Code and applicable Addenda as required by 10 CFR 50, Section 50.55a(g), except where specific written relief has been granted by the Commission pursuant to 10 CFR 50, Section 50.55a(g)(6)(i).

APPLICABILITY

BASES

instead, provided the other specified conditions are satisfied. In this case, this would mean that for one division the emergency power source must be OPERABLE (as must be the components supplied by the emergency power source) and all redundant systems, subsystems, trains, components and devices in both divisions must also be OPERABLE. If these conditions are not satisfied, action is required in accordance with this specification.

In MODES 5 or 6, Specification 3.0.5 is not applicable, and thus the individual ACTION statements for each applicable Limiting Condition for Operation in these MODES must be adhered to.

4.0.1 This specification provides that surveillance activities necessary to insure the Limiting Conditions for Operation are met and will be performed during the OPERATIONAL MODES or other conditions for which the Limiting Conditions for Operation are applicable. Provisions for additional surveillance activities to be performed without regard to the applicable OPERATIONAL MODES or other conditions are provided in the individual Surveillance Requirements. Surveillance Requirements for Special Test Exceptions need only be performed when the Special Test Exception is being utilized as an exception to an individual Specification.

4.0.2 Specification 4.0.2 establishes the limit for which the specified time interval for Surveillance Requirements may be extended. It permits an allowable extension of the normal surveillance interval to facilitate surveillance scheduling and consideration of plant operating conditions that may not be suitable for conducting the surveillance; e.g., transient conditions or other ongoing surveillance or maintenance activities. It also provides flexibility to accommodate the length of a fuel cycle for surveillances that are performed at each refueling outage and are specified with an 18-month surveillance interval. It is not intended that this provision be used repeatedly as a convenience to extend surveillance intervals beyond that specified for surveillances that are not performed during refueling outages. The limitation of Specification 4.0.2 is based on engineering judgement and the recognition that the most probable result of any particular surveillance being performed is the verification of conformance with the Surveillance Requirements. This provision is sufficient to ensure that the reliability ensured through surveillance activities is not significantly degraded beyond that obtained from the specified surveillance interval.

4.0.3 This specification establishes the failure to perform a Surveillance Requirement within the allowed surveillance interval, defined by the provisions of Specification 4.0.2, as a condition that constitutes a failure to meet the OPERABILITY requirements for a Limiting Condition for Operation. Under the provisions of this specification, systems and components are assumed to be OPERABLE when Surveillance Requirements have been satisfactorily performed within the specified time interval. However, nothing in this provision is to be construed as implying that systems or components are OPERABLE when they are found or known to be inoperable although still meeting the Surveillance Requirements. This specification also clarifies that the ACTION requirements are applicable when Surveillance Requirements have not been completed within the allowed surveillance interval and that the time limits of the ACTION requirements apply from the point in time it is

APPLICABILITY

BASES

identified that a surveillance has not been performed and not at the time that the allowed surveillance interval was exceeded. Completion of the Surveillance Requirement within the allowable outage time limits of the ACTION requirements restores compliance with the requirements of Specification 4.0.3. However, this does not negate the fact that the failure to have performed the surveillance within the allowed surveillance interval, defined by the provisions of Specification 4.0.2, was a violation of the OPERABILITY requirements of a Limiting Condition for Operation that is subject to enforcement action. Further, the failure to perform a surveillance within the provisions of Specification 4.0.2 is a violation of a Technical Specification requirement and is, therefore, a reportable event under the requirements of 10 CFR 50.73(a)(2)(i)(B) because it is a condition prohibited by the plant's Technical Specifications.

If the allowable outage time limits of the ACTION requirement are less than 24 hours (the allowable outage time limits are defined as the first timeframe encountered in the ACTION requirement) or a shutdown is required to comply with ACTION requirements, e.g., Specification 3.0.3, a 24-hour allowance is provided to permit a delay in implementing the ACTION requirements. This provides an adequate time limit to complete Surveillance Requirements that have not been performed. The purpose of this allowance is to permit the completion of a surveillance before a shutdown is required to comply with ACTION requirements or before other remedial measures would be required that may preclude completion of a surveillance. The basis for this allowance include consideration for plant conditions, adequate planning, availability of personnel, the time required to perform the surveillance, and the safety significance of the delay in completing the required surveillance. This provision also provides a time limit for the completion of Surveillance Requirements that become applicable as a consequence of MODE changes imposed by ACTION requirements and for completing Surveillance Requirements that are applicable when an exception to the requirements of Specification 4.0.4 is allowed. If a surveillance is not completed within the 24-hour allowance, the time limits of the ACTION requirements are applicable at that time. When a surveillance is performed within the 24-hour allowance and the Surveillance Requirements are not met, the time limits of the ACTION requirements are applicable at the time that the surveillance is terminated.

Surveillance Requirements do not have to be performed on inoperable equipment because the ACTION requirements define the remedial measures that apply. However, the Surveillance Requirements have to be met to demonstrate that inoperable equipment has been restored to OPERABLE status.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555

TENNESSEE VALLEY AUTHORITY

DOCKET NO. 50-328

SEQUOYAH NUCLEAR PLANT, UNIT 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 152
License No. DPR-79

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Tennessee Valley Authority (the licensee) dated May 26, 1992, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C.(2) of Facility Operating License No. DPR-79 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 152, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance, to be implemented within 30 days.

FOR THE NUCLEAR REGULATORY COMMISSION



Frederick J. Hebdon, Director
Project Directorate II-4
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: August 13, 1992

ATTACHMENT TO LICENSE AMENDMENT NO. 152

FACILITY OPERATING LICENSE NO. DPR-79

DOCKET NO. 50-328

Revise the Appendix A Technical Specifications by removing the pages identified below and inserting the enclosed pages. The revised pages are identified by the captioned amendment number and contain marginal lines indicating the area of change. Overleaf pages [*] are provided to maintain document completeness.

REMOVE

3/4 0-2
B3/4 0-3
B3/4 0-4*

INSERT

3/4 0-2
B3/4 0-3
B3/4 0-4*

APPLICABILITY

SURVEILLANCE REQUIREMENTS

4.0.1 Surveillance Requirements shall be met during the OPERATIONAL MODES or other conditions specified for individual Limiting Conditions for Operation unless otherwise stated in an individual Surveillance Requirement.

4.0.2 Each Surveillance Requirement shall be performed within the specified surveillance interval with a maximum allowable extension not to exceed 25 percent of the specified surveillance interval.

4.0.3 Failure to perform a Surveillance Requirement within the allowed surveillance interval, defined by Specification 4.0.2, shall constitute noncompliance with the OPERABILITY requirements for a Limiting Condition for Operation. The time limits of the ACTION requirements are applicable at the time it is identified that a Surveillance Requirement has not been performed. The ACTION requirements may be delayed for up to 24 hours to permit the completion of the surveillance when the allowable outage time limits of the ACTION requirements are less than 24 hours. Surveillance Requirements do not have to be performed on inoperable equipment.

4.0.4 Entry into an OPERATIONAL MODE or other specified condition shall not be made unless the Surveillance Requirement(s) associated with the Limiting Condition for Operation have been performed within the specified surveillance interval or as otherwise specified. This provision shall not prevent passage through or to OPERATIONAL MODES as required to comply with ACTION requirements.

4.0.5 Surveillance Requirements for inservice inspection and testing of ASME Code Class 1, 2 and 3 components shall be applicable as follows:

- a. Inservice inspection of ASME Code Class 1, 2 and 3 components and inservice testing of ASME Code Class 1, 2 and 3 pumps and valves shall be performed in accordance with Section XI of the ASME Boiler and Pressure Vessel Code and applicable Addenda as required by 10 CFR 50, Section 50.55a(g), except where specific written relief has been granted by the Commission pursuant to 10 CFR 50, Section 50.55a(g)(6)(i).

3.0.5 (Continued)

specified conditions are satisfied. In this case, this would mean that for one division the emergency power source must be OPERABLE (as must be the components supplied by the emergency power source) and all redundant systems, subsystems, trains, components and devices in both divisions must also be OPERABLE. If these conditions are not satisfied, action is required in accordance with this specification.

In MODES 5 or 6, Specification 3.0.5 is not applicable, and thus the individual ACTION statements for each applicable Limiting Condition for Operation in these MODES must be adhered to.

4.0.1 This specification provides that surveillance activities necessary to insure the Limiting Conditions for Operation are met and will be performed during the OPERATIONAL MODES or other conditions for which the Limiting Conditions for Operation are applicable. Provisions for additional surveillance activities to be performed without regard to the applicable OPERATIONAL MODES or other conditions are provided in the individual Surveillance Requirements. Surveillance Requirements for Special Test Exceptions need only be performed when the Special Test Exception is being utilized as an exception to an individual specification.

4.0.2 Specification 4.0.2 establishes the limit for which the specified time interval for Surveillance Requirements may be extended. It permits an allowable extension of the normal surveillance interval to facilitate surveillance scheduling and consideration of plant operating conditions that may not be suitable for conducting the surveillance; e.g., transient conditions or other ongoing surveillance or maintenance activities. It also provides flexibility to accommodate the length of a fuel cycle for surveillances that are performed at each refueling outage and are specified with an 18-month surveillance interval. It is not intended that this provision be used repeatedly as a convenience to extend surveillance intervals beyond that specified for surveillances that are not performed during refueling outages. The limitation of Specification 4.0.2 is based on engineering judgement and the recognition that the most probable result of any particular surveillance being performed is the verification of conformance with the Surveillance Requirements. This provision is sufficient to ensure that the reliability ensured through surveillance activities is not significantly degraded beyond that obtained from the specified surveillance interval.

4.0.3 This specification establishes the failure to perform a Surveillance Requirement within the allowed surveillance interval, defined by the provisions of Specification 4.0.2, as a condition that constitutes a failure to meet the OPERABILITY requirements for a Limiting Condition for Operation. Under the provisions of this specification, systems and components are assumed to be OPERABLE when Surveillance Requirements have been satisfactorily performed within the specified time interval. However, nothing in this provision is to be construed as implying that systems or components are OPERABLE when they are found or known to be inoperable although still meeting the Surveillance Requirements. This specification also clarifies that the ACTION requirements are applicable when Surveillance Requirements have not been completed within the allowed surveillance interval and that the time limits of the ACTION requirements apply from the point in time it is identified that a surveillance has not been performed and not at the time that the allowed surveillance interval was exceeded. Completion of the Surveillance Requirement within the

4.0.3 (Continued)

allowable outage time limits of the ACTION requirements restores compliance with the requirements of Specification 4.0.3. However, this does not negate the fact that the failure to have performed the surveillance within the allowed surveillance interval, defined by the provisions of Specification 4.0.2, was a violation of the OPERABILITY requirements of a Limiting Condition for Operation that is subject to enforcement action. Further, the failure to perform a surveillance within the provisions of Specification 4.0.2 is a violation of a Technical Specification requirement and is, therefore, a reportable event under the requirements of 10 CFR 50.73(a)(2)(i)(B) because it is a condition prohibited by the plant's Technical Specifications.

If the allowable outage time limits of the ACTION requirement are less than 24 hours (the allowable outage time limits are defined as the first timeframe encountered in the ACTION requirement) or a shutdown is required to comply with ACTION requirements, e.g., Specification 3.0.3, a 24-hour allowance is provided to permit a delay in implementing the ACTION requirements. This provides an adequate time limit to complete Surveillance Requirements that have not been performed. The purpose of this allowance is to permit the completion of a surveillance before a shutdown is required to comply with ACTION requirements or before other remedial measures would be required that may preclude completion of a surveillance. The basis for this allowance includes consideration for plant conditions, adequate planning, availability of personnel, the time required to perform the surveillance, and the safety significance of the delay in completing the required surveillance. This provision also provides a time limit for the completion of Surveillance Requirements that become applicable as a consequence of MODE changes imposed by ACTION requirements and for completing Surveillance Requirements that are applicable when an exception to the requirements of Specification 4.0.4 is allowed. If a surveillance is not completed within the 24-hour allowance, the time limits of the ACTION requirements are applicable at that time. When a surveillance is performed within the 24-hour allowance and the Surveillance Requirements are not met, the time limits of the ACTION requirements are applicable at the time that the surveillance is terminated.

Surveillance Requirements do not have to be performed on inoperable equipment because the ACTION requirements define the remedial measures that apply. However, the Surveillance Requirements have to be met to demonstrate that inoperable equipment has been restored to OPERABLE status.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555

ENCLOSURE 3

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION
RELATED TO AMENDMENT NO. 162 TO FACILITY OPERATING LICENSE NO. DPR-77
AND AMENDMENT NO. 152 TO FACILITY OPERATING LICENSE NO. DPR-79
TENNESSEE VALLEY AUTHORITY
SEQUOYAH NUCLEAR PLANT, UNITS 1 AND 2
DOCKET NOS. 50-327 AND 50-328

1.0 INTRODUCTION

By application dated May 26, 1992, the Tennessee Valley Authority (the licensee) proposed amendments to the Technical Specifications (TS) for Sequoyah Nuclear Plant (SQN) Units 1 and 2. The proposed changes would remove the provision of Specification 4.0.2 that limits the combined time interval for three consecutive surveillance tests to less than 3.25 times the interval specified in the TS for the test. Guidance on this proposed change was provided to all power reactor licensees and applicants by Generic Letter 89-14, "A Line Item Technical Specification Improvement - Removal of 3.25 Limit on Extending Surveillance Intervals," dated August 21, 1989.

2.0 EVALUATION

Specification 4.0.2 includes the provision that allows a surveillance test interval to be extended by 25 percent of the time interval specified in the TS for the test. The purpose of this extension is to allow the flexibility needed for scheduling the performance of the surveillance tests and to permit consideration of plant operating conditions that may not be suitable for conducting a surveillance test at the specified time interval. Such operating conditions include transient plant operation, ongoing surveillance, or maintenance activities.

Specification 4.0.2 further limits the allowance for extending a surveillance interval for a test by requiring that the combined time interval for three consecutive surveillance tests not exceed 3.25 times the time interval specified in the TS. The purpose of this provision is to assure that surveillance tests are not extended repeatedly as an operational convenience to provide an overall increase in the surveillance interval.

Experience has shown, however, that the 18-month surveillance test interval with the provision that allows extending the interval by 25 percent, is usually sufficient to accommodate normal variations in the length of a fuel cycle. Also, the NRC staff has routinely granted requests for one-time

risk to safety is low in contrast to the alternative of a forced shutdown to perform these tests. Therefore, the 3.25 limitation on extending surveillance intervals has not been a practical limit on the use of the 25-percent allowance for extending surveillances that are performed on a refueling outage basis.

Extending surveillance intervals during plant operation can also result in a benefit to safety when a scheduled surveillance is due at a time that is not suitable for conducting the test. This may occur when transient plant operating conditions exist, or when safety systems are out of service for maintenance or other surveillance activities. In such cases, the benefit to safety of extending a surveillance interval would exceed any safety benefit derived by limiting the use of the 25 percent allowance to extend the interval. Furthermore, there is the administrative burden associated with tracking the use of the 25 percent allowance to ensure compliance with the 3.25 limit.

In view of these findings, the staff concluded that Specification 4.0.2 should be changed to remove the 3.25 limit for all surveillance tests because its removal will have an overall positive effect on safety. The guidance provided in Generic Letter 89-14 included the following change to this specification and replaced the 3.25 limit on three consecutive surveillances with the following statement:

"4.0.2 Each Surveillance Requirement shall be performed within the specified surveillance interval with a maximum allowable extension not to exceed 25 percent of the specified surveillance interval."

In addition, a change to the Bases of this specification was submitted. This change emphasizes that it is not intended that the allowance for extending surveillance intervals be used repeatedly merely as an operational convenience to extend surveillance intervals beyond that specified in the TS.

The licensee has proposed changes to Specification 4.0.2 that are consistent with the guidance provided in Generic Letter 89-14, as noted above. On the basis of our review, the staff finds that these changes to the TS are acceptable.

3.0 STATE CONSULTATION

In accordance with the Commission's regulations, the Tennessee State official was notified of the proposed issuance of the amendment. The State official had no comments.

4.0 ENVIRONMENTAL CONSIDERATION

The amendment changes a requirement with respect to installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20 and changes to the Surveillance Requirements. The NRC staff has determined that the amendment involves no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative

occupational radiation exposure. The Commission has previously issued a proposed finding that the amendment involves no significant hazards consideration, and there has been no public comment on such finding (57 FR 30261). Accordingly, the amendment meets the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b) no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendment.

5.0 CONCLUSION

The Commission has concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of the amendment will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributor: D. LaBarge

Date: August 13, 1992

APPLICABILITY

SURVEILLANCE REQUIREMENTS

4.0.1 Surveillance Requirements shall be met during the OPERATIONAL MODES or other conditions specified for individual Limiting Conditions for Operation unless otherwise stated in an individual Surveillance Requirement.

4.0.2 Each Surveillance Requirement shall be performed within the specified surveillance interval with a maximum allowable extension not to exceed 25 percent of the specified surveillance interval.

4.0.3 Failure to perform a Surveillance Requirement within the allowed surveillance interval, defined by Specification 4.0.2, shall constitute noncompliance with the OPERABILITY requirements for a Limiting Condition for Operation. The time limits of the ACTION requirements are applicable at the time it is identified that a Surveillance Requirement has not been performed. The ACTION requirements may be delayed for up to 24 hours to permit the completion of the surveillance when the allowable outage time limits of the ACTION requirements are less than 24 hours. Surveillance Requirements do not have to be performed on inoperable equipment.

4.0.4 Entry into an OPERATIONAL MODE or other specified condition shall not be made unless the Surveillance Requirement(s) associated with the Limiting Condition for Operation have been performed within the specified surveillance interval or as otherwise specified. This provision shall not prevent passage through or to OPERATIONAL MODES as required to comply with ACTION requirements.

4.0.5 Surveillance Requirements for inservice inspection and testing of ASME Code Class 1, 2 and 3 components shall be applicable as follows:

- a. Inservice inspection of ASME Code Class 1, 2 and 3 components and inservice testing of ASME Code Class 1, 2 and 3 pumps and valves shall be performed in accordance with Section XI of the ASME Boiler and Pressure Vessel Code and applicable Addenda as required by 10 CFR 50, Section 50.55a(g), except where specific written relief has been granted by the Commission pursuant to 10 CFR 50, Section 50.55a(g)(6)(i).

3.0.5 (Continued)

specified conditions are satisfied. In this case, this would mean that for one division the emergency power source must be OPERABLE (as must be the components supplied by the emergency power source) and all redundant systems, subsystems, trains, components and devices in both divisions must also be OPERABLE. If these conditions are not satisfied, action is required in accordance with this specification.

In MODES 5 or 6, Specification 3.0.5 is not applicable, and thus the individual ACTION statements for each applicable Limiting Condition for Operation in these MODES must be adhered to.

4.0.1 This specification provides that surveillance activities necessary to insure the Limiting Conditions for Operation are met and will be performed during the OPERATIONAL MODES or other conditions for which the Limiting Conditions for Operation are applicable. Provisions for additional surveillance activities to be performed without regard to the applicable OPERATIONAL MODES or other conditions are provided in the individual Surveillance Requirements. Surveillance Requirements for Special Test Exceptions need only be performed when the Special Test Exception is being utilized as an exception to an individual specification.

4.0.2 Specification 4.0.2 establishes the limit for which the specified time interval for Surveillance Requirements may be extended. It permits an allowable extension of the normal surveillance interval to facilitate surveillance scheduling and consideration of plant operating conditions that may not be suitable for conducting the surveillance; e.g., transient conditions or other ongoing surveillance or maintenance activities. It also provides flexibility to accommodate the length of a fuel cycle for surveillances that are performed at each refueling outage and are specified with an 18-month surveillance interval. It is not intended that this provision be used repeatedly as a convenience to extend surveillance intervals beyond that specified for surveillances that are not performed during refueling outages. The limitation of Specification 4.0.2 is based on engineering judgement and the recognition that the most probable result of any particular surveillance being performed is the verification of conformance with the Surveillance Requirements. This provision is sufficient to ensure that the reliability ensured through surveillance activities is not significantly degraded beyond that obtained from the specified surveillance interval.

4.0.3 This specification establishes the failure to perform a Surveillance Requirement within the allowed surveillance interval, defined by the provisions of Specification 4.0.2, as a condition that constitutes a failure to meet the OPERABILITY requirements for a Limiting Condition for Operation. Under the provisions of this specification, systems and components are assumed to be OPERABLE when Surveillance Requirements have been satisfactorily performed within the specified time interval. However, nothing in this provision is to be construed as implying that systems or components are OPERABLE when they are found or known to be inoperable although still meeting the Surveillance Requirements. This specification also clarifies that the ACTION requirements are applicable when Surveillance Requirements have not been completed within the allowed surveillance interval and that the time limits of the ACTION requirements apply from the point in time it is identified that a surveillance has not been performed and not at the time that the allowed surveillance interval was exceeded. Completion of the Surveillance Requirement within the

4.0.3 (Continued)

allowable outage time limits of the ACTION requirements restores compliance with the requirements of Specification 4.0.3. However, this does not negate the fact that the failure to have performed the surveillance within the allowed surveillance interval, defined by the provisions of Specification 4.0.2, was a violation of the OPERABILITY requirements of a Limiting Condition for Operation that is subject to enforcement action. Further, the failure to perform a surveillance within the provisions of Specification 4.0.2 is a violation of a Technical Specification requirement and is, therefore, a reportable event under the requirements of 10 CFR 50.73(a)(2)(i)(B) because it is a condition prohibited by the plant's Technical Specifications.

If the allowable outage time limits of the ACTION requirement are less than 24 hours (the allowable outage time limits are defined as the first timeframe encountered in the ACTION requirement) or a shutdown is required to comply with ACTION requirements, e.g., Specification 3.0.3, a 24-hour allowance is provided to permit a delay in implementing the ACTION requirements. This provides an adequate time limit to complete Surveillance Requirements that have not been performed. The purpose of this allowance is to permit the completion of a surveillance before a shutdown is required to comply with ACTION requirements or before other remedial measures would be required that may preclude completion of a surveillance. The basis for this allowance includes consideration for plant conditions, adequate planning, availability of personnel, the time required to perform the surveillance, and the safety significance of the delay in completing the required surveillance. This provision also provides a time limit for the completion of Surveillance Requirements that become applicable as a consequence of MODE changes imposed by ACTION requirements and for completing Surveillance Requirements that are applicable when an exception to the requirements of Specification 4.0.4 is allowed. If a surveillance is not completed within the 24-hour allowance, the time limits of the ACTION requirements are applicable at that time. When a surveillance is performed within the 24-hour allowance and the Surveillance Requirements are not met, the time limits of the ACTION requirements are applicable at the time that the surveillance is terminated.

Surveillance Requirements do not have to be performed on inoperable equipment because the ACTION requirements define the remedial measures that apply. However, the Surveillance Requirements have to be met to demonstrate that inoperable equipment has been restored to OPERABLE status.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555

ENCLOSURE 3

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION
RELATED TO AMENDMENT NO. 162 TO FACILITY OPERATING LICENSE NO. DPR-77
AND AMENDMENT NO. 152 TO FACILITY OPERATING LICENSE NO. DPR-79

TENNESSEE VALLEY AUTHORITY

SEQUOYAH NUCLEAR PLANT, UNITS 1 AND 2

DOCKET NOS. 50-327 AND 50-328

1.0 INTRODUCTION

By application dated May 26, 1992, the Tennessee Valley Authority (the licensee) proposed amendments to the Technical Specifications (TS) for Sequoyah Nuclear Plant (SQN) Units 1 and 2. The proposed changes would remove the provision of Specification 4.0.2 that limits the combined time interval for three consecutive surveillance tests to less than 3.25 times the interval specified in the TS for the test. Guidance on this proposed change was provided to all power reactor licensees and applicants by Generic Letter 89-14, "A Line Item Technical Specification Improvement - Removal of 3.25 Limit on Extending Surveillance Intervals," dated August 21, 1989.

2.0 EVALUATION

Specification 4.0.2 includes the provision that allows a surveillance test interval to be extended by 25 percent of the time interval specified in the TS for the test. The purpose of this extension is to allow the flexibility needed for scheduling the performance of the surveillance tests and to permit consideration of plant operating conditions that may not be suitable for conducting a surveillance test at the specified time interval. Such operating conditions include transient plant operation, ongoing surveillance, or maintenance activities.

Specification 4.0.2 further limits the allowance for extending a surveillance interval for a test by requiring that the combined time interval for three consecutive surveillance tests not exceed 3.25 times the time interval specified in the TS. The purpose of this provision is to assure that surveillance tests are not extended repeatedly as an operational convenience to provide an overall increase in the surveillance interval.

Experience has shown, however, that the 18-month surveillance test interval with the provision that allows extending the interval by 25 percent, is usually sufficient to accommodate normal variations in the length of a fuel cycle. Also, the NRC staff has routinely granted requests for one-time

risk to safety is low in contrast to the alternative of a forced shutdown to perform these tests. Therefore, the 3.25 limitation on extending surveillance intervals has not been a practical limit on the use of the 25-percent allowance for extending surveillances that are performed on a refueling outage basis.

Extending surveillance intervals during plant operation can also result in a benefit to safety when a scheduled surveillance is due at a time that is not suitable for conducting the test. This may occur when transient plant operating conditions exist, or when safety systems are out of service for maintenance or other surveillance activities. In such cases, the benefit to safety of extending a surveillance interval would exceed any safety benefit derived by limiting the use of the 25 percent allowance to extend the interval. Furthermore, there is the administrative burden associated with tracking the use of the 25 percent allowance to ensure compliance with the 3.25 limit.

In view of these findings, the staff concluded that Specification 4.0.2 should be changed to remove the 3.25 limit for all surveillance tests because its removal will have an overall positive effect on safety. The guidance provided in Generic Letter 89-14 included the following change to this specification and replaced the 3.25 limit on three consecutive surveillances with the following statement:

"4.0.2 Each Surveillance Requirement shall be performed within the specified surveillance interval with a maximum allowable extension not to exceed 25 percent of the specified surveillance interval."

In addition, a change to the Bases of this specification was submitted. This change emphasizes that it is not intended that the allowance for extending surveillance intervals be used repeatedly merely as an operational convenience to extend surveillance intervals beyond that specified in the TS.

The licensee has proposed changes to Specification 4.0.2 that are consistent with the guidance provided in Generic Letter 89-14, as noted above. On the basis of our review, the staff finds that these changes to the TS are acceptable.

3.0 STATE CONSULTATION

In accordance with the Commission's regulations, the Tennessee State official was notified of the proposed issuance of the amendment. The State official had no comments.

4.0 ENVIRONMENTAL CONSIDERATION

The amendment changes a requirement with respect to installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20 and changes to the Surveillance Requirements. The NRC staff has determined that the amendment involves no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative

occupational radiation exposure. The Commission has previously issued a proposed finding that the amendment involves no significant hazards consideration, and there has been no public comment on such finding (57 FR 30261). Accordingly, the amendment meets the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b) no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendment.

5.0 CONCLUSION

The Commission has concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of the amendment will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributor: D. LaBarge

Date: August 13, 1992