



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

December 16, 1993

Docket Nos. 50-327
and 50-328

Tennessee Valley Authority
ATTN: Dr. Mark O. Medford, Vice President
Technical Support
3B Lookout Place
1101 Market Street
Chattanooga, Tennessee 37402-2801

Dear Dr. Medford:

SUBJECT: EXEMPTION TO APPENDIX J OF 10 CFR PART 50, SCHEDULAR
REQUIREMENTS FOR TYPE B AND C LOCAL LEAK RATE TESTS
SEQUOYAH NUCLEAR PLANT UNIT 2 (TAC NO. M87802)

By letter dated September 27, 1993, the Tennessee Valley Authority (TVA) requested an exemption for the Sequoyah Nuclear Plant (SQN), Unit 2, from the requirements of 10 CFR 50, Appendix J, Sections III.D.2(a) and III.D.3. These sections require performance of the Primary Containment Types B and C local leak rate tests at intervals no greater than 2 years. TVA indicated that the exemption to exceed the 2-year interval is needed to support the Unit 2 Cycle 6 refueling outage.

Between March 1, 1993, and October 19, 1993, Unit 2 was shut down. Due to the length of the shutdown, TVA has rescheduled the start of the Unit 2 Cycle 6 refueling outage from September 1993 to April 1994. As a result, the expiration of the 2-year time interval for some Type B and Type C tests occurs before the outage starts. To perform the tests in accordance with the requirement would force the unit to shut down in March 1994. To prevent this, the proposed exemption would allow a one-time deferment of the Appendix J interval requirement from March 15, 1994, until the shutdown on April 2, 1994, a total of approximately 18 days.

200084

NRC FILE CENTER COPY

9312230165 931216
PDR ADOCK 05000327
P PDR

DFD
1
CP-3

Dr. Mark O. Medford

- 2 -

Enclosed is the Exemption for Unit 2 from the requirements of 10 CFR 50, Appendix J, Sections III.D.2(a) and III.D.3 that require performance of the Primary Containment Types B and C local leak rate tests at intervals no greater than 2 years. The Exemption recognizes that the tests will be performed during the Cycle 6 refueling outage.

Sincerely,

Original signed by

Frederick J. Hebdon, Director
Project Directorate II-4
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Enclosure:
Exemption to 10 CFR 50

cc: See next page

PDII4/LA	PDII-4/LA	SCSB	OGC	PDII-4/D	AD/RII	D/DRPE
BC/Larson	DLaBarge	RBarrett	Cmarco	FHebdon	GLainas	SVarga
11/8/93	11/9/93	11/15/93	11/16/93	12/13/93	12/13/93	12/13/93

DOCUMENT NAME: 87802.EX

↑ make
sure
as
you
go
first.

Done
11/23/93

Tennessee Valley Authority
ATTN: Dr. Mark O. Medford

cc:

Mr. Craven Crowell, Chairman
Tennessee Valley Authority
ET 12A
400 West Summit Hill Drive
Knoxville, TN 37902

Mr. W. H. Kenney, Director
Tennessee Valley Authority
ET 12A
400 West Summit Hill Drive
Knoxville, TN 37902

Mr. Johnny H. Hayes, Director
Tennessee Valley Authority
ET 12A
400 West Summit Hill Drive
Knoxville, TN 37902

Mr. Robert Fenech
Site Vice President
Sequoyah Nuclear Plant
Tennessee Valley Authority
P.O. Box 2000
Soddy, Daisy, TN 37379

Mr. R. M. Eytchison, Vice President
Nuclear Operations
Tennessee Valley Authority
3B Lookout Place
1101 Market Street
Chattanooga, TN 37402-2801

Mr. B. S. Schofield, Manager
Nuclear Licensing and Regulatory Affairs
Tennessee Valley Authority
4G Blue Ridge
1101 Market Street
Chattanooga, TN 37402-2801

Mr. Ralph H. Shell
Site Licensing Manager
Sequoyah Nuclear Plant
Tennessee Valley Authority
P.O. Box 2000
Soddy Daisy, TN 37379

SEQUOYAH NUCLEAR PLANT

TVA Representative
Tennessee Valley Authority
11921 Rockville Pike
Suite 402
Rockville, MD 20852

General Counsel
Tennessee Valley Authority
ET 11H
400 West Summit Hill Drive
Knoxville, TN 37902

Mr. Michael H. Mobley, Director
Division of Radiological Health
3rd Floor, L and C Annex
401 Church Street
Nashville, TN 37243-1532

County Judge
Hamilton County Courthouse
Chattanooga, TN 37402

Regional Administrator
U.S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW., Suite 2900
Atlanta, GA 30323

Mr. William E. Holland
Senior Resident Inspector
Sequoyah Nuclear Plant
U.S. Nuclear Regulatory Commission
2600 Igou Ferry Road
Soddy Daisy, TN 37379

Mr. D. E. Nunn, Vice President
Tennessee Valley Authority
3B Lookout Place
1101 Market Street
Chattanooga, TN 37402-2801



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555
December 16, 1993

Docket File
D. LaBarge
Sqn Rdg. File
B. Clayton

DOCKET NOS 50-327, 50-328

MEMORANDUM FOR:

Regulatory Publications Branch
Division of Freedom of Information and Publications Services
Office of Administration and Resources Management

FROM:

Office of Nuclear Reactor Regulation

SUBJECT:

LOCAL LEAK RATE TESTS

One signed original of the *Federal Register* Notice identified below is enclosed for your transmittal to the Office of the Federal Register for publication. Additional conformed copies (5) of the Notice are enclosed for your use.

- ☐ Notice of Receipt of Application for Construction Permit(s) and Operating License(s).
- ☐ Notice of Receipt of Partial Application for Construction Permit(s) and Facility License(s); Time for Submission of Views on Antitrust Matters.
- ☐ Notice of Consideration of Issuance of Amendment to Facility Operating License. (Call with ____ -day insert date).
- ☐ Notice of Receipt of Application for Facility License(s); Notice of Availability of Applicant's Environmental Report; and Notice of Consideration of Issuance of Facility License(s) and Notice of Opportunity for Hearing.
- ☐ Notice of Availability of NRC Draft/Final Environmental Statement.
- ☐ Notice of Limited Work Authorization.
- ☐ Notice of Availability of Safety Evaluation Report.
- ☐ Notice of Issuance of Construction Permit(s).
- ☐ Notice of Issuance of Facility Operating License(s) or Amendment(s).
- ☐ Order.
- ☒ Exemption.
- ☐ Notice of Granting Exemption.
- ☐ Environmental Assessment.
- ☐ Notice of Preparation of Environmental Assessment.
- ☐ Receipt of Petition for Director's Decision Under 10 CFR 2.206.
- ☐ Issuance of Final Director's Decision Under 10 CFR 2.206.
- ☐ Other: _____

Enclosure:
As stated

Project Directorate II-4

Contact: A. Sanders
Phone: 504-2024

OFFICE	PRD-4						
SURNAME	dw						
DATE	12/17/93						

Distribution

Docket File

NRC & Local PDRS

SQN Rdg. File

T. Murley/F. Miraglia 12-G-18

L. Callan 12-G-18

E. Rossi 9-A-2

J. Lieberman 7-H-5

S. Varga

G. Lainas

L. Dodley

F. Hebdon

B. Clayton

D. LaBarge

OGC 15-B-18

E. Jordan MNBB-3701

G. Hill (4) P1-37

ACRS(10)

OPA

OC/LFDCB

EDO Contact for RII 17-G-21

R. Barrett 8-H-7

E. Merschoff RII

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

In the Matter of)	
)	
TENNESSEE VALLEY AUTHORITY)	Docket No. 50-328
)	
Sequoyah Nuclear Plant, Unit 2))	

EXEMPTION

I.

The Tennessee Valley Authority (TVA) is the holder of Facility Operating License No. DPR-79, which authorizes operation of the Sequoyah Nuclear Plant, Unit 2 (the facility, Unit 2). The license provides, among other things, that the facility is subject to all rules, regulations, and orders of the Nuclear Regulatory Commission (the Commission) now or hereafter in effect.

The facility consists of a pressurized water reactor located on TVA's Sequoyah site in Hamilton County, Tennessee.

II.

Sections III.D.2(a) and III.D.3 of Appendix J to 10 CFR Part 50 require that Types B and C local leak rate tests be performed during reactor shutdown for refueling, or other convenient intervals, but in no case at intervals greater than 2 years.

On March 15, 1992, SQN Unit 2 started the Cycle 5 refueling outage. All Type B and Type C local leak rate tests were performed during the outage and the unit was returned to service on May 17, 1992. Between March 1, 1993, and October 19, 1993, Unit 2 was shut down. Due to the length of the shutdown, TVA has postponed the start of the Unit 2 Cycle 6 refueling outage from September 1993 to April 2, 1994. As a result, the expiration of the 2-year time interval for some Type B and Type C tests occurs before the outage starts. To perform the tests in accordance with the requirement would force the unit to shut down in March 1994. To prevent this, the licensee has requested an exemption that would allow a one-time deferment of the Appendix J interval requirement from March 15, 1994 until the shutdown for the refueling outage starting on April 2, 1994, a total of approximately 18 days.

The extension would affect 20 Electrical Penetrations, 164 Isolation Valves, 2 Flanges, 1 hydrogen analyzer, and 1 containment spray header valve, since they were tested during the Unit 2 Cycle 5 refueling outage before April 2, 1992. These valves and components, which represent approximately 53 percent of the leak rate test program, are considered by the licensee to be leak tight and in good condition, which was verified by the leak rate tests performed during the Cycle 5 refueling outage. Based on the present containment leak rate that accounts for less than 80 percent of the applicable limit, the licensee believes that the remaining margin is sufficient to ensure that any incremental increase in leakage because of the extension, will not result in unacceptable as-found test results. Also, based on historical data, the licensee believes that any incremental increase in leakage from these components because of the extension would be small. In addition, many of the

components were included in the boundary for the last Type A test that was performed in April 1992, and have been subjected to improved maintenance practices that provides increased assurance that the components will be capable of performing their intended safety function.

III.

Pursuant to 10 CFR 50.12, the Commission may, upon application by any interested person or upon its own initiative, grant exemptions from the requirements of 10 CFR Part 50 when (1) the exemptions are authorized by law, will not present an undue risk to public health or safety, and are consistent with the common defense and security; and (2) when special circumstances are present. Special circumstances are present whenever, according to 10 CFR 50.12(a)(2)(ii), "Application of the regulation in the particular circumstances would not serve the underlying purpose of the rule or is not necessary to achieve the underlying purpose of the rule..."

The underlying purpose of the requirement to perform Type B and Type C containment leak rate tests at intervals not to exceed 2 years, is to ensure that any potential leakage pathways through the containment boundary are identified within a time span that prevents significant degradation from continuing or being unknown, and long enough to allow the tests to be conducted during scheduled refueling outages. This interval was originally published in Appendix J when refueling cycles were conducted at approximately annual intervals and has not been changed to reflect 18-month or 2-year operating cycles. It is not the intent of the regulation to require a plant shutdown solely for the purpose of conducting the periodic leak rate tests. Based on historical data at SQN, any incremental increase in leakage because

of the extension would be small. Improved maintenance practices implemented during the Unit 2 Cycle 5 outage and improved testing techniques of containment isolation valves to detect any degraded performance indications, provide increased assurance that these components will perform their safety function. In addition, on the average, as-left leak rates are less than 25 percent of the established reference leak rates. Therefore, since the maximum extension is relatively short (18 days) compared to the two-year test interval requirement, it is unlikely that substantial degradation of the containment components leading to the failure of the containment to perform its safety function would occur. As a result, the application of the regulation in the particular circumstances is not necessary to achieve the underlying purpose of the rule.

IV.

For the foregoing reasons, the NRC staff has concluded that the licensee's proposed increase of the 2-year time interval for performing Type B and Type C Containment Leak Rate Tests until the Cycle 6 refueling outage will not present an undue risk to public health and safety and is consistent with the common defense and security. The NRC staff has determined that there are special circumstances present, as specified in 10 CFR 50.12(a)(2), such that application of 10 CFR Part 50, Appendix J, Sections III.D.2(a) and III.D.3 are not necessary in order to achieve the underlying purpose of this regulation.

Accordingly, the Commission has determined that, pursuant to 10 CFR 50.12(a), an exemption is authorized by law, will not endanger life or property or common defense and security, and is, otherwise, in the public interest. Therefore, the Commission hereby grants the Tennessee Valley

of Appendix J to 10 CFR Part 50 as requested in the submittal.

Pursuant to 10 CFR 51.32, the Commission has determined that the granting of this exemption will not result in any significant adverse environmental impact (58 FR 60470).

This exemption is effective upon issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

Original signed by

Steven A. Varga, Director
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Dated at Rockville, Maryland,
this 16th day of December, 1993

OFC:	PDII-4/LA	PDII-4/PM	PDII-4/D	OGC	AD:RII	DRPE:D
NAME:	BClayton	DLaBarge	FHebbon	Carne	GKainas	SVarga
DATE:	12/2/93	12/2/93	12/13/93	12/7/93	12/13/93	12/16/93

DOCUMENT NAME: 87802.EX