

MAY 30 '91 06:10

NRC TLR TMI UNIT 1

P01

P21 91068
Publicly Available

①

It was recently identified at TMI-1, that a number of Yarway Figure 5615B 1500# Class globe valves (CS and SST), purchased IAW the requirements of ASME III less 'N' stamp, had been tagged improperly by Yarway. The Pressure and Temperature ratings of the subject valves, as identified on the manufacturers nameplate (affixed to the valve bonnet), reflected the "Special Class" rating as identified in ANSI B16.34-1977. Discussions with Yarway representatives identified that incorrect nameplates had been installed on the subject valves. The ratings identified on the nameplates corresponded to the ratings specified in 1977 Ed. and earlier editions of ASME Sect. III and not to the ratings specified in ANSI B16.34-1977 as required by later editions of the code. Actions are under way with Yarway to have the proper tags installed on all applicable valves in TMI-1 stock.

The effect of the improper tagging information had no safety impact at TMI-1, but other end users who selected applications based directly on the manufacturers tagged Press./Temp. ratings may want to verify that the information is correct. It has been reported that Yarway is currently developing a program to notify their customers of this situation. Any inquiries relative to this issue should be directed to Yarway.

MAY 30 '91 06:11

NRC TLR TMI UNIT 1

P02

Material Nonconformance Report May 10, 1991
MNCR

Response to MNCR 912016

Page 1 of 12

1.0 BACKGROUND

- 1.1 As identified on MNCR 912016, the A182 F316L SST Yarway 5615B Class 1500globe valves received and accepted into TMI-1 under EER 90-1072, were found to be improperly tagged from the standpoint of their Pressure-Temperature (P-T) rating at 100 F, during the evaluation of several 1/2" valves for use in the MU system.

The subject SST valves were initially procured by Oyster Creek under P.O. OP-030084 to the requirements of GPUN Specification SP-9000-12-009 Rev. 2. The valves were purchased to comply with ASME Class 2 requirements - less the N stamp. During the technical evaluation of these valves for use in the modified MU seal injection piping system, Gilberts contacted Yarway to obtain information pertaining to the P/T rating of the valves.

The Yarway name plate information, affixed to the bonnet of the valves, indicates that the valves are rated for 3345 PSIG at 100 F which, per ANSI B16.34-1977, corresponds to the "special class" rating for the 316L material; unfortunately, as identified by Yarway personnel, the valves were not designed to meet the "special class" rating. An investigation by Yarway found that incorrect name plates had been installed on the subject valves.

- 1.2 In conjunction with the review of the subject SST Yarway valves, located in Stores, R.G. Stoehr performed a walkdown on several of the Yarway Fig. 5615B CS globe valve installations in the Turbine Building. As was the case with the SST valves, these CS Yarway valves were initially purchased by Oyster Creek under P.O. OP #030084 and evaluated for use in TMI applications under EER's 88-037-E and 89-199-M. An inspection of several of these valves found that they were also tagged improperly; actual name plate P/T 3750 PSIG @ 100 F versus 3705 PSIG @ 100 F as specified in ANSI B16.34-1977. Yarway confirmed that these name plates were also incorrect.
- 1.3 A follow up inspection was completed of the CS Yarway 5615B valves contained in the Warehouse, to determine if any of the O.C. valves remained in stock. All of the CS Yarway valves in stock appear to have been purchased under TMI P.O. TP-078501 to the requirements of GPUN Spec. SP-9000-12-009, unfortunately, the P/T ratings on these valves also reflect the improper "special class" rating.

MAY 30 '91 06:11

NRC TLR TMI UNIT 1

P03

③

Page 2 of 12

MNCR 912016

Summation

As identified above, the response and evaluation presented herein has been expanded to encompass the CS Yarway 5615B valves installed in the plant as well as those in stock (ref. OC P.O. OP-030084 and TMI P.O. TP-078501). Each of these items will be addressed and evaluated separately.

2.0 EVALUATION2.1 Oyster Creek SST Yarway Valves

As identified earlier, there were a total of 54 various sized Yarway Fig. 5615B A182 F316L globe valves evaluated for use at TMI-1 under EER 90-1072. These valves were originally purchased for Oyster Creek under P.O. #OP-030084. A review of the subject P.O. found that the valves were initially order 2Xas ASME III Class I components, but C/N 002 to the P.O. identifies that, due to the inability to obtain a thermal transient analysis, the valves would be designed to ASME III Class 2.

In accordance with the QA requirements, the latest edition or addenda of ASME III at the time of the order was to apply. Based on the 10/03/85 date of the original P.O. and a review of several of the subvendor certifications, it appears that the 1980 Ed. through the Winter 1983 Addenda of Section III was invoked. The reason for presenting this information is that it defines the basis for the Pressure and Temperature rating of the subject valves.

The P-T rating on the name plate of the A182 F316L valves is 3345 PSIG @ 100 F; this corresponds to the "special class" rating as defined in ANSI B16.34-1977. A review of Section NB-3531 "Pressure-Temperature Ratings and Hydrostatic Tests" of ASME III 1983 Ed., see Attachment I, identifies that valves designed IAW NB-3541 may be used IAW the P-T ratings in ANSI B16.34. Information provided by Debbie Knoble, Yarway Engineering (215-825-2100 X340), identified that the subject valves were not designed to comply with the "special class" ANSI rating and that the wrong manufacturers name plate tags had been installed.

Based on subsequent investigations and discussions with Yarway personnel, it appears that the wrong name plate drawing had been specified for these valves. Yarway apparently has two separate series of these drawings; Pre-1977 Ed. ASME III and Post-1977 Ed. ASME III. The difference being that the P-T ratings in the 1977 and earlier editions, which were contained directly in the body of the code, corresponded to the current "special class" ratings of ANSI B16.34 for the 316L material (see Attachments II), while the Summer 1977 Addenda of ASME

①

MNCR 912016

Page 3 of 12

III was revised to refer to the P-T ratings contained in ANSI B16.34 (ref. Attachment III). Using the latter code, which is the correct for the subject 316L valves, the P-T rating would be 3000 PSIG @ 100 F.

Yarway has provided an assurance that there were no changes in the design or manufacture of their valves. The valves manufactured to the requirements of the 1977 Ed. of ASME III would have been physically identical to those constructed to the 1980 Ed. of ASME III - the only difference between the valves is their P-T rating.

In order to resolve the tagging issue on these SST Yarway valves, Plant Engineering recommended to Yarway QA Representative Frank Peszka (215-825-2100 X379) that Yarway personnel come to TMI-1 and install new name plates, with the correct P-T rating, on all of the subject SST valves that are in stock under the following SSN's:

- 1/2" SSN 000-429-0300-1 15 On Hand*
- 3/4" SSN 000-429-0318-1 14 On Hand*
- 1" SSN 000-429-0326-1 15 On Hand*
- 1 1/2" SSN 000-429-0334-1 5 On Hand*
- 2" SSN 000-434-8440-1 5 On Hand*

*Constitutes the entire quantity of SST Yarway 5615B valves received and accepted from O.C. under EER 80-1072; none of these valves were installed in any TMI-1 application.

2.2 Oyster Creek CS Yarway Valves

In addition to the SST Yarway valves identified above, TMI-1 Plant Engineering had previously, on two separate occasions, evaluated and accepted a number of ASTM A105 CS Yarway valves ordered under OC P.O. #OP-030084 as ASME Class 2 components (less 'N' Stamp) for TMI-1 use; 17 Yarway valves were evaluated under EER 88-037-E and 19 were evaluated under EER 89-199-M. These valves were used as replacements for a number of Hancock 5500W valves in various MS/FW applications; the installation of these valves was controlled and documented under CMR 88-039 and CMR 88-138.

After the issue with respect to the P-T rating on the manufacturers name plate was identified for the SST Yarway valves, a walkdown was performed on several of the CS Yarway installations completed under the aforementioned CMR's. The results of this walkdown identified that, like the SST valves, the P-T ratings on the manufacturers name plates affixed to the CS valves reflected the "special class" ANSI rating of 3750 PSIG @ 100 F versus the correct "standard class" rating of 3705 PSIG @ 100 F.

→

no due date
daily
- verbally from
Yarway on 1/27/91
- code changed
but yarway did not

hydro performed by
Yarway on 1/27/91
3346 #
377
3000 #

hydro to new
codes

installed

5

MNCR 912016

Unlike the SST valves that are still in the Warehouse, the CS valves that were obtained from O.C. are installed in various locations throughout TMI-1 in the MS, FW, EFW, HD and NI systems; however, the vast majority of these valves were installed in the MS and FW systems. The problem with these valves is that it would be extremely difficult and time consuming to install new manufacturers name plates having the correct P-T rating. And, based on the following justification, Plant Engineering does not feel that retagging of the installed valves is required.

*Why "Extremely Difficult"
Documents A
Hold Tags on 316L
on Carbon Steels*

*RCS 2500 class valve
Send me 1500 class valve
You indicated but there
hold by...*

-- The P-T rating of the CS Yarway valves is essentially the same regardless of whether or not they are "special class".

The applications in which the 1500 Class CS Yarway valves were installed, previously contained 600 Class bolted bonnet Hancock 5500W valves, hence the P-T rating of "standard class" Yarway valves easily envelopes the design conditions of the individual system applications.

- MS - 1050 PSIG @ 600 F
- FW - 1700 PSIG @ 475 F from FWP's to Control Valves
- 1150 PSIG @ 400 F for OTSG Skin Valves
- EFW - 1100 PSIG @ 110 F
- HD - 890 PSIG @ 400 F
- NI - 600 PSIG @ 500 F 2nd Stage Feed Htr. conditions

A comparison of the above conditions to the ANSI B16.34-1977 Ratings for the A105 material (see Attachment III), found that the subject valves, regardless of the deviation in the Yarway name plate rating, are well within their P-T design capabilities. In fact, there are no secondary plant applications at TMI-1 where the "standard class" rating of the 1500 Class CS Yarway valves would not be suitable.

2.3 TMI-1 CS Yarway Valves

In addition to the CS Yarway valves which were ordered under O.C. P.O. #OP- 030084 and evaluated for use at TMI-1 by EER's 88- 037-E and 89-199-M, a quantity of CS Yarway valves were ordered by TMI-1 under P.O. #TP-078501. Based on a review of the QA requirements associated with this P.O., these valves were purchased IAW SP-9000-12-009 and were to ASME Class 2 less the "N" stamp.

As was the case with the OC valves (SST and CS), an inspection of the Yarway valves in stock that were purchased under P.O. #TP-078501, found them to have the improper P-T rating on their name plates. From the

MAY 30 '91 06:13

NRC TLR TMI UNIT 1

P06

(6)

MNCR 912016

Page 5 of 12

information contained in the original P.O. package, TP-078501 ordered the following quantities of A105 CS Yarway 5615B valves:

- 1/2"	SSN 000-395-6086-1;	10 valves purchased
- 3/4"	SSN 000-395-6101-1;	30 valves purchased (C/N 1)
- 1"	SSN 000-395-6440-1;	70 valves purchased (C/N 1)
- 1 1/2"	SSN 000-395-6474-1;	35 valves purchased (C/N 1)
- 2"	SSN 000-395-6482-1;	10 valves purchased

Of the original quantities that were ordered/received, the following is a tabulation of the valves that remain in the Warehouse:

- 1/2"	5 in stock
- 3/4"	12 in stock
- 1"	31 in stock
- 1 1/2"	22 in stock
- 2"	9 in stock

In order to correct the P-T rating of these valves, new manufacturers name plates will need to be installed prior to the use/release of any more of these valves. As in the case of the SST Yarway valves, Plant Engineering is working with Frank Paszka, Yarway QA, to have Yarway personnel come to TMI-1 to install new name plates having the correct 3705 PSIG @ 100 P rating.

The difference in quantities between those ordered and those remaining in stock constitutes the number of Yarway valves that were installed during the SR Outage, either as direct replacements for installed plant components, as identified in Section 2.2, or as new plant components. Regardless of their end use, the subject A105 CS Yarway valves have an allowable "standard class" rating that would envelope any and all TMI-1 secondary plant applications. Based on the justification presented in Section 2.2, Plant Engineering does not feel that action to re-tag the installed valves, purchased under P.O. #TP-078501, is warranted.

3.0 CONCLUSION

Plant Engineering concludes, based on the information presented herein, that all of the Yarway valves, traceable to either OC P.O. #OP-030084 or TMI P.O. #TP-078501, that remain in the Warehouse (54 SST valves and 79 CS valves) should have new manufacturers name plates installed to reflect their correct "standard class" P-T rating.

The removal and installation of new name plates, when scheduled, will be performed by Yarway personnel in the QA Receipt/Hold area of Warehouse I with QA/QC Receipt

Hold T-2
No Hold T-2 since work in low pressure

7

MNCR 912016

Page 6 of 12

Inspection witnessing the retagging and verifying that the new name plates are correct IAW ANSI B16.34 P-T ratings.

- Material History
- Paper work is correct
- U/L tagging is wrong
- QA receipt resp. will verify P.T. rating

No follow up action is required to retag or provide any further evaluation for any of the CS Yarway 5615B globe valves, purchased under either of the above P.O.'s, that were installed in either the 7R or 8R Outages. The information presented herein provides sufficient justification and technical bases to allow these valves to remain installed in their respective applications.

10CFR21 REPORTABILITY DETERMINATION

The determination was made by Max Nelson and Courtney Smyth that, for the TMI-1 applications, the installation of manufacturers name plates having incorrect P-T rating information did not constitute a 10CFR21 reportable condition. The basis for this position included the following:

- There was no physical change in the valve itself; the P-T rating change resulted from a revision to ASME III.
- The subject valves were not degraded from a physical standpoint.
- The SST Yarway valves were not installed in any TMI-1 application, and, as identified in the above text, the CS valves that were installed in the plant have been found to be fully suitable for the TMI-1 applications.

Based on the above information, it was determined that although the manufacturers nameplates affixed to the subject Yarway valves reflected the incorrect P-T rating, the valves themselves did not constitute a safety concern at TMI-1. And, as such, these discrepancies were determined not to be reportable under the criteria of 10CFR21.

Information Release Under Nuclear Network

Although the tagging of the Yarway valves was not reported under 10CFR21, Plant Engineering did prepare a summary of this issue for release under Nuclear Network. This summary was turned over to the Nuclear Network Coordinator on 5/16/91.

Supplier Corrective Action Request (SCAR) Release

In conjunction with the action completed by TMI personnel relative to this MNCR, Dennis Kierpa, Surveillance & Control & Technical Functions, has prepared a Supplier Corrective Action Request No. 91-002 that will be forwarded to Yarway through the Acquisitions Dept.. This request, which references MNCR 912016, requires that Yarway provide disposition, cause and corrective action responses relative

Attachment I

Page 5 of 13

NB-3524, NB-3531.2

SECTION III. DIVISION 1 — SUBSECTION NB

1983 Edition

9

accelerations acting at the centers of gravity of the extended masses.

Appendix F may be used in evaluating those loadings independently of other loadings.

NB-3525 Level A and B Service Limits

The design rules of NB-3512 and NB-3513 apply to loadings for which Level A or B Limits are designated except that when evaluating Level B Limits during operation of relief or safety valves (a) and (b) below shall be met.

(a) The service pressure may exceed the Design Pressures defined by the pressure-temperature ratings of ANSI B16.34 by no more than 10%.

(b) The rules of NB-3540 apply using allowable stress intensity values of 110% of those listed in Appendix I.

NB-3530 GENERAL RULES

NB-3531 Pressure-Temperature Ratings and Hydrostatic Tests

NB-3531.1 Pressure-Temperature Ratings. A valve designed in accordance with NB-3541 may be used in accordance with the pressure-temperature ratings in ANSI B16.34, Tables 2-1.1A to 2-2.7A (Standard Class) for flanged end or welding end (including socket welding end) valves, and ANSI B16.34, Tables 2-1.1B to 2-2.7B (Special Class) for welding end (including socket welding end) valves, provided the Design Pressure and Design Temperature are used. When a single valve has a flanged and a welding end, the flanged end requirements shall be used. The materials¹⁷ listed in ANSI B16.34, Table 1, may be used if listed in Tables I-1.0, subject to the temperature limitations therein, and as defined in NCA-1220.

NB-3531.2 Hydrostatic Tests

(a) Valves designed in accordance with NB-3541 shall be subjected to the shell hydrostatic test pressures required by ANSI B16.34 and in accordance with other appropriate rules of NB-6000. Valves with a primary pressure rating less than Class 150 shall be subjected to the required test pressure for Class 150 rated valves.

(b) The shell hydrostatic test shall be made with the valve in the partially open position. Stem leakage during this test is permissible. End closure seals for retaining fluid at test pressure in welding end valves may be positioned in the welding end transitions, as defined in NB-3544.8(b), in reasonable proximity to the end plane of the valve so as to ensure safe application of the test pressure.

(c) After the shell hydrostatic test, a valve closure test shall also be performed with the valve in the fully closed position with a test pressure across the valve disk no less than 110% of the 100°F pressure rating. For valves that are designed for Service Conditions that have the pressure differential across the closure member limited to values less than the 100°F pressure

NB-3526 Level C Service Limits

If the Design Specifications specify any loadings for which Level C Limits are designated, the rules used in evaluating these loadings shall be those of NB-3512 and NB-3513, except as modified by the following subparagraphs.

NB-3526.1 Pressure-Temperature Ratings. The pressure permissible for loadings for which Level C Limits are designated shall not exceed 120% of that permitted for Level A Limits.

NB-3526.2 Pipe Reaction Stress. Pipe reaction stresses shall be computed in accordance with the equations of NB-3545.2(b)(1), and the allowable value considered individually is $1.8S_m$ for the valve body material at 500°F. In performing these calculations, the value of S shall be taken as 1.2 times the yield strength at 500°F of the material of the connected pipe, or 36.0 ksi when the pipe material is not defined in the Design Specifications.

NB-3526.3 Primary Stress and Secondary Stress. The equation of NB-3545.2 shall be satisfied using C_p equal to 1.5, P_m computed in accordance with NB-3526.2, and Q_T equal to 0, and the calculated value shall be limited to $2.25S_m$.

NB-3526.4 Secondary and Peak Stresses. The requirements of NB-3545 and NB-3550 need not be met.

NB-3527 Level D Service Limits

If the Design Specifications specify any loadings for which Level D Limits are designated, the guidelines of

¹⁷Special features such as wear surfaces or seating surfaces may demand special alloys or proprietary treatments. The absence of such materials from Tables I-1.0 shall not be construed to prohibit their use and such materials do not require approval under Appendix IV (NB-3121).

Attachment II (p. 1 of 2)
NB-3000 — DESIGN

Page 10 of 13
NB-3523-NB-3631.1

(10)

NB-3523 Severe Duty Applications

A severe duty application of a valve is one which does not satisfy the requirements of NB-3522 and it may therefore become necessary to apply the alternative rules of NB-3512.2.¹⁵

NB-3524 Earthquake

The rules of this Subarticle consider that under earthquake loadings the piping system, not the valve, will be limiting, and that the integrity of the valve pressure retaining body is adequately considered under the piping requirements of NB-3600. Where valves are provided with operators having extended structures and these structures are essential to maintaining pressure integrity, an analysis, when required by the Design Specifications, may be performed based on static forces resulting from equivalent earthquake accelerations acting at the centers of gravity of the extended masses.

NB-3525 Level A and B Service Limits

The design rules of NB-3512 and NB-3513 apply to loadings for which Level A or B Limits are designated except that when evaluating Level B Limits during operation of relief or safety valves (a) and (b) below shall be met.

(a) The service pressure may exceed the Design Pressures defined by the pressure-temperature ratings of Tables NB-3531-1 through NB-3531-7 by no more than 10%.

(b) The rules of NB-3540 apply using allowable stress intensity values of 110% of those listed in Appendix I.

NB-3526 Level C Service Limits

(a) If valve function is not required during any loading for which Level C Limits are designated in the Design Specifications, the rules used in evaluating these loadings shall be those of NB-3512 and NB-3513, except as modified by the following subparagraphs for valves having a piping connection larger than 4 in. nominal pipe size.

(b) If valve function must be assured during loading for which Level C Limits are designated, this requirement shall be included in the Design Speci-

¹⁵The severity and frequency of specified fluid temperature variations may be such that the period of calculated pressure integrity is less than plant design life. In such cases it is the responsibility of the Certificate Holder to state these conditions in the Design Report (NB-3560).

fications, and the specified Service Loadings shall be considered as though Level A Limits were designated for the valve.

NB-3526.1 Pressure-Temperature Ratings. The pressure permissible for loadings for which Level C Limits are designated shall not exceed 120% of that permitted for Level A Limits.

NB-3526.2 Pipe Reaction Stress. Pipe reaction stresses shall be computed in accordance with the equations of NB-3545.2(b)(1) and the allowable value considered individually is $1.8 S_m$ for the valve body material at 500 F (260 C). In performing these calculations, the value of S shall be taken as 1.2 times the yield strength of the material of the connected pipe or 36.0 ksi (248 MPa) when the pipe material is not defined in the Design Specifications.

NB-3526.3 Primary Stress and Secondary Stress. The equation of NB-3545.2 shall be satisfied using C_p equal to 1.5, P_m computed in accordance with NB-3526.2, Q_p equals 0, and the calculated value shall be limited to $2.25 S_m$.

NB-3526.4 Secondary and Peak Stresses. The requirements of NB-3545 and NB-3550 need not be met.

NB-3527 Level D Service Limits

If the Design Specifications specify any loadings for which Level D Limits are designated the guidelines of Appendix F may be used in evaluating these loadings independently of other loadings. If valve function must be assured during loadings for which Level D Limits are designated, this requirement shall be included in the Design Specifications, and the specified loadings for which Level D Limits are designated shall be considered as though Level A Limits were designated for the valve.

NB-3530 SPECIAL DESIGN RULES

NB-3531 Pressure-Temperature Ratings and Hydrostatic Tests

NB-3531.1 Pressure-Temperature Ratings. A valve designed in accordance with NB-3541 may be applied in accordance with the pressure-temperature ratings of Tables NB-3531-1 to NB-3531-7 provided the Design Pressure and Design Temperature are used. The ratings for flanged end valves, larger than 4 in. nominal pipe size, are different from those for welding end valves. When such a single valve has a

Attachment II (Pg 2 of 2)
 NB-3000 — DESIGN

Page 11 of 13
 Table NB-3531-6

pre 1977

TABLE NB-3531-6
 CLASS 1500 PRESSURE-TEMPERATURE RATINGS
 All Pressures are in Pounds per Square Inch Gage-psig

Service Temp. F	Material											
	Ferritic Steel					Austenitic Steel						
	Carbon Steel (Low Temp)	Carbon Moly	1 Cr- 1/4 Mo	1 1/2 Cr- 1/4 Mo	2 1/4 Cr- 1 Mo	Types	304	307	316	310	304L	316L
100	3750	3470	3750	3750	3750	3750	3750	3750	3750	3750	3750	3750
200	3750	3470	3750	3750	3750	3750	3400	3365	3405	3430	3430	3430
300	3750	3470	3750	3750	3750	3750	3020	2935	3170	3045	3280	2850
400	3750	3470	3750	3750	3750	3750	2760	2615	3065	2850	3170	2935
500	3750	3470	3750	3750	3750	3750	2560	2415	2895	2655	3015	2185
600	3560	3470	3750	3750	3750	3750	2420	2315	2745	2520	2850	2075
650	3495	3470	3600	3600	3750	3750	2380	2270	2680	2465	2785	2035
700	3470	3470	3450	3450	3750	3750	2335	2250	2610	2420	2720	1995
750							2315	2225	2570	2380	2680	1970
800							2295	2185	2545	2355	2595	1930
100	3600	3470	3600	3600	3600	3600	3600	3600	3600	3600	3600	3600
200	3500	3470	3500	3500	3500	3500	3400	3365	3405	3430	3430	3430
300	3415	3415	3415	3415	3415	3415	3020	2970	3170	3045	3280	2195
400	3330	3330	3330	3330	3330	3330	2760	2645	3065	2850	3170	1810
500	3125	3125	3125	3125	3125	3125	2560	2495	2885	2655	3000	1600
600	2770	2770	2770	2770	2770	2770	2420	2310	2730	2520	2770	1900
650	2580	2580	2580	2580	2580	2580	2380	2345	2580	2465	2580	1615
700	2350	2350	2350	2350	2350	2350	2335	2275	2465	2420	2455	1400
750							2315	2210	2355	2355	2325	1365
800							2240	2145	2240	2240	2200	1235

NOTE:
 (1) The primary pressure rating of 1500, on the basis of which this nominal pressure class is designated, applies to service temperatures (primary rating temperatures, dependent on the material under consideration) which are in excess of the temperatures permitted by this Subsection for most of the materials listed in this table.

Attachment III
(Pg. 1 of 2)

AMERICAN NATIONAL STANDARD
STEEL VALVES, FLANGED AND BUTTWELDING END

ANSI B16.34-1977

TABLE 2-2.3 RATINGS FOR GROUP 2.3 MATERIALS

A182-F316L A240-316L A479-316L A312-TP316L
A182-F304L A240-304L(1) A479-304L(1) A312-TP304L(1)

12
Make Y System
P = 3050
Design

TABLE 2-2.3A STANDARD CLASS VALVES, FLANGED AND BUTTWELDING END

STANDARD CLASS	TEMPERATURE IN °F	WORKING PRESSURE IN psig BY CLASSES							
		150	300	400	500	600	1500	2500	4500
	-20 TO 100	100	200	267	333	400	1000	1667	3000
	100	100	200	267	333	400	1000	1667	3000
	200	175	350	467	578	700	1750	2833	5000
	300	175	350	467	578	700	1750	2833	5000
	400	165	330	440	550	660	1650	2750	4900
	500	145	290	387	484	580	1450	2367	4300
	600	140	280	373	466	556	1400	2267	4100
	650	135	270	357	445	530	1350	2167	3900
	700	110	220	293	366	440	1100	1767	3200
	750	95	190	253	316	380	950	1533	2800
	800	85	170	223	278	336	850	1367	2500
	850	85	170	223	278	336	850	1367	2500

316
3600 @ 15
3750 @ 15

TABLE 2-2.3B SPECIAL CLASS BUTTWELDING END VALVES ONLY

SPECIAL CLASS	TEMPERATURE IN °F	WORKING PRESSURE IN psig BY CLASSES							
		150	300	400	500	600	1500	2500	4500
	-20 TO 100	100	200	267	333	400	1000	1667	3000
	100	100	200	267	333	400	1000	1667	3000
	200	175	350	467	578	700	1750	2833	5000
	300	175	350	467	578	700	1750	2833	5000
	400	175	350	467	578	700	1750	2833	5000
	500	165	330	440	550	660	1650	2750	4900
	600	145	290	387	484	580	1450	2367	4300
	650	140	280	373	466	556	1400	2267	4100
	700	135	270	357	445	530	1350	2167	3900
	750	110	220	293	366	440	1100	1767	3200
	800	95	190	253	316	380	950	1533	2800
	850	85	170	223	278	336	850	1367	2500

Notes:
(1) not to be used over 8000F.

→ only 2 orders for Yarrow
- DXPS Purchasing System
- Find out purchase orders for Yarrow. From these orders look up end use

3050 @ 2000F

This sourced material
SA-182
316 SS size 316L

min system does it use 316L (lower press rating) or 316 (High press rating)

36

IF it uses 36 and we installed 316L valves we are not conservative
Remember the computer says 316 (higher rating) but the valves really were 316L
different problem?

Handwritten @ 316
The modification looked at purchase order that said 316L but "L" doesn't meet design.

AMERICAN NATIONAL STANDARD
STEEL VALVES, FLANGED AND BUTTWELDING END (Part 2 of 2)

ANSI B16.34-1977
Page 13 of 13

Post 1977

TABLE 2-1.1 RATINGS FOR GROUP 1.1 MATERIALS

A105(a)
A105(b)
A105(c)

A515-70(a)
A515-70(b)(1)
A515-KCP70(a)

A135-KCP70(a)
A135-KCP70(b)

TABLE 2-1.1A STANDARD CLASS VALVES, FLANGED AND BUTTWELDING END

TEMPERATURE IN °F	WORKING PRESSURE IN psi BY CLASS						
	150	300	400	600	900	1500	2500
-20 TO	200	250	300	400	500	600	700
100	250	300	350	450	550	650	750
200	300	350	400	500	600	700	800
300	350	400	450	550	650	750	850
400	400	450	500	600	700	800	900
500	450	500	550	650	750	850	950
600	500	550	600	700	800	900	1000
700	550	600	650	750	850	950	1050
800	600	650	700	800	900	1000	1100
900	650	700	750	850	950	1050	1150
1000	700	750	800	900	1000	1100	1200

TABLE 2-1.1B SPECIAL CLASS BUTTWELDING END VALVES ONLY

TEMPERATURE IN °F	WORKING PRESSURE IN psi BY CLASS						
	150	300	400	600	900	1500	2500
-20 TO	200	250	300	400	500	600	700
100	250	300	350	450	550	650	750
200	300	350	400	500	600	700	800
300	350	400	450	550	650	750	850
400	400	450	500	600	700	800	900
500	450	500	550	650	750	850	950
600	500	550	600	700	800	900	1000
700	550	600	650	750	850	950	1050
800	600	650	700	800	900	1000	1100
900	650	700	750	850	950	1050	1150
1000	700	750	800	900	1000	1100	1200

Notes:

- (a) — permissible, but not recommended for prolonged usage above about 800° F.
- (b) — not to be used over 650° F.
- (c) — not to be used over 700° F.
- (d) — not to be used over 800° F.

Joseph Wartschen
Kenneth Eichenlaub