Florida Power & Light Company, 6501 South Ocean Drive, Jensen Beach, FL 34957



November 21, 2001

L-2001-251 10 CFR § 50.73

U. S. Nuclear Regulatory Commission Attn: Document Control Desk Washington, D. C. 20555

Re: St. Lucie Unit 1 Docket No. 50-335 Reportable Event: 2001-008-00 Date of Event: June 11, 2001 Operation With Concurrent Inoperable EDG and <u>Opposite Train Feature Prohibited by TS</u>

The attached Licensee Event Report 2001-008 is being submitted pursuant to the requirements of 10 CFR § 50.73 to provide notification of the subject event.

NRC Regulatory Issue Summary 2001-05 waived the requirements that multiple copies of documents be submitted to the NRC. Therefore, hard copies usually sent to the Regional Administrator and Senior Resident Inspector will not be sent.

Very truly yours,

Donald E. Jerhigan

Vice President St. Lucie Nuclear Plant

DEJ/KWF Attachment



NRC FORM 366 U.S. NUCLEAR REGULATORY COMMISSION						APPROVED BY OMB NO. 3150-0104 EXPIRES 6-30-2001								
(1-2001) LICENSEE EVENT REPORT (LER) (See reverse for required number of digits/characters for each block)							Estimated burden per response to comply with this mandatory information collection request: 50 hrs. Reported lessons learned are incorporated into the licensing process and fed back to industry. Forward comments regarding burden estimate to the Records Management Branch (T-6 F33), U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, and to the Paperwork Reduction Project (3150-0104), Office of Management and Budget, Washington, DC 20503. It an information collection does not display a currently valid OMB control number, the NRC may not conduct or sponsor, and a person is not required to respond to, the information collection.							
FACILITY NAME (1)						DOCKET NUMBER (2) PAGE (3)								
St. Lucie Unit 1								05000335				Page	1 of 3	
TITLE (4)														
Operatio	on With	Concurren	t Inoperal	ble	EDG an	d Opp	osi	te '	Ira	in Fea	ture Proh	ibited	l by T	S
EVENT D	ATE (5)		UMBER (6)		REPC	DRT DAT	E (7)		FAC		OTHER FACIL	ITIES INV		8) ER
MONTH DAY	YEAR	YEAR N		BER	MONTH	DAY	YEA	R	FAC				DOCKET NUMBER	
06 11	2001	2001 -	008 - 0	0		21	200	)1						
	1			BMIT	TED PURS		) TH	EREC	QUIF	REMENTS	OF 10 CFR §:	(Check o	ne or mo	re) (11)
		20.2201(0	<u>7</u>		20.2203(a)	)(4)				50 73(2)(	د)(II)(D) D)(III)		50.73(a	λζλ(ik)(A) (2)(γ)
LEVEL (10)	100	20.2201(0	)(1)		50.36(c)(1)(i)(A)					50.73(a)(2	2)(iv)(A)		73.71(a	)(4)
	1	20.2203(a	20.2203(a)(2)(i)			50.36(c)(1)(ii)(A)				50.73(a)(2	2)(v)(A)		73.71(a)(5)	
		20.2203(a	)(2)(ii)		50.36(c)(2	)				50.73(a)(2	2)(v)(B)		OTHER	
		20.2203(a	)(2)(iii)		50.46(a)(3	i)(ii)				50.73(a)(2	2)(v)(C)	Sp	Specify in Abstract below or in	
		20.2203(a	1)(2)(iv)	<b>.</b>	50.73(a)(2	?)(i)(A)			50.73(a)(2)(V)(D)					
		20.2203(a	)(2)(v) )(2)(vi)	<b>^</b>	50.73(a)(2	)(i)(D) (i)(C)			50.73(a)(2)(VII)					
		20.2203(a	)(3)(i)	+	50.73(a)(2	2)(ii)(A)			50.73(a)(2)(viii)(B)					
			<u> </u>	ICE	NSEE CON	TACT FC	)R TI	HIS L	ER (	(12)				
NAME									TEL	EPHONE NUM	BER (Include Area	Code)	-	
I	(enneth	W. Frehaf	er, Licen	sin	g Engin	eer					(561)	467 -	7748	
		COMPLETE	ONE LINE FO	REA	CH COMPC	DNENT F	AILU	IRE D	DESC	CRIBED IN	THIS REPOR	Г (13)		
CAUSE	SYSTEM	COMPONENT	MANUFACTUR	ER	REPORTAB TO EPIX		Cł	AUSE	SYSTEM COMPONENT MA		MANUFA	NUFACTURER REPORTABLE TO EPIX		
x	EK	NA	NA		No			-						
	S	JPPLEMENTA	REPORT EXP	PEC	TED (14)					EXP	ECTED	MONTH	DAY	YEAR
(If yes, o	complete EXF	PECTED SUBM	ISSION DATE)			x	NC	)		SUBI DA	MISSION FE (15)			
ABSTRACT	(Limit to 1400	) spaces, i.e., a	pproximately 15	sing	gle-spaced ty	ypewritte	n line	s) (1	6)			•	•	
On Ju the p leak 2001 monit 3.8.1 safet On Oc agree requ: subje subm: Spec: with featu safet inte: the p	the 11, in performants Concurs	2001, St. nce of a s B EDG was rrent wit ystem (RV not enter ed system , 2001, F he documes with an id not su TS change n (STS) w ent EDG ( erability ion. Bec on of the	Lucie Un surveillan declared h the EDG LMS) was ed because . This T PL was in nted St. 1 inoperable pport FPL to align ording. T subject te , as long ause the s	it out out fouce fouce the to as TS,	1 was in run of t of ser operabl of ser PL did n osition med, vi ie TS p DG. Th interpre e St. L CE STS he EDG the in amendme this e	n Mode the 1 rvice lity, vice 3 not co was 6 a the osilic e NRC etation wordin allow operal nt al vent 1	e 1 1B 1 and the and cons doce te: be con. TS ng ed ble ble ble ble	at EDG, d re Not Act Leph rega To V vith clea out s op no	10 tu A" cr Re hardd ct hardd ct hardd ct hardd ct im	0 perc he EDG inned t channe on b of VLMS t d in C he, tha ling op t that correct the CE y allo time) are doe cation mpact o	ent react develope o service l reactor Technica o be a re ondition t the NRC posite tr the liter this con Standard ws contin and oppo s not pro comparabl n the hea	or pow d a ra on Ju vesse l Spec quired Report Staff ain ve al wor dition Techni ued op site t vide a e to F lth ar	er. diato ne 17 l lev ifica crit 01-1 did crific ding , FPL cal verati rain crit PL's d saf	During r el tion ical 237. not ation of the on ical former ety of

**...** 

NRC FORM 366A

#### LICENSEE EVENT REPORT (LER) TEXT CONTINUATION

FACILITY NAME (1)	DOCKET NUMBER (2)	LER NUMBER (6)			PAGE (3)		
	05000005	YEAR	SEQUENTIAL NUMBER	REVISION NUMBER			
St. Lucie Unit 1	05000335	2001	- 008 -	00	Page 2 OL 3		

TEXT (If more space is required, use additional copies of NRC Form 366A) (17)

#### Description of the Event

On June 11, 2001, St. Lucie Unit 1 was in Mode 1 at 100 percent reactor power. The "A" channel reactor vessel level monitoring system (RVLMS) was out of service (OOS), and the 30 day special report required by TS 3.3.8 Action 4 was submitted by FPL by letter L-2001-128 on May 31, 2001. The 1B emergency diesel generator (EDG) also had a degraded radiator on the 12-cylinder engine. As part of the operability assessment-directed compensatory measures, the monthly Technical Specification (TS) EDG surveillance was being performed on a bi-weekly frequency. During the performance of the 1B EDG augmented surveillance run on June 11, 2001, the 12 cylinder 1B2 EDG developed a radiator leak. The 1B EDG was declared OOS pending replacement of the EDG radiator cores. Replacement cores were not available on site and were procured in an expedited manner. On June 15, replacement cores for the 1B2 EDG radiator were received on site, the cores were replaced, and the 1B EDG was returned to service on June 17, 2001. Although the opposite train RVLMS was OOS concurrent with the 1B EDG, St. Lucie Unit 1 did not enter TS 3.8.1.1 Action b because FPL did not consider RVLMS to be a required critical safety-related system. This TS position was documented in St. Lucie Condition Report 01-1237.

On October 9, 2001, FPL was informed via telephone that the NRC Staff did not agree with the documented St. Lucie TS position regarding opposite train verification requirements with an inoperable EDG. The LER "discovery" clock for the June event was started at this time.

#### Cause of the Event

The cause of this event was that the literal wording of the subject TS did not support FPL's interpretation that "required" implied a critical safety-related system whose loss would result in the system's TS requiring a shutdown. FPL submitted a TS change to align the St. Lucie TS with the Combustion Engineering (CE) Standard Technical Specification (STS) wording. The CE STS wording clearly allows continued operation with an inoperable EDG (subject to the EDG allowed outage time) and inoperable opposite train features that do not provide critical safety functions.

#### Analysis of the Event

This condition is reportable under 10 CFR 50.73(a)(2)(i)(B) as operation prohibited by the facilities' TS.

### Analysis of Safety Significance

TS 3.8.1.1 Action b states in part that:

"With one diesel generator of 3.8.1.1.b inoperable... verify within 2 hours or be in HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours that:

1. all required systems, subsystems, trains, components and devices that depend on the remaining OPERABLE diesel generator as a source of emergency power are also OPERABLE... "

A literal interpretation of the subject TS did not support FPL's interpretation. The CE STS wording clearly allows continued operation with concurrent EDG (subject to the EDG allowed outage time) and opposite train feature inoperability, as long as the inoperable feature does not provide a critical safety function. FPL submitted a proposed TS amendment to implement the CE STS wording for opposite train feature

NRC FORM 366A (1-2001)

\_\_\_\_\_\_

### U.S. NUCLEAR REGULATORY COMMISSION

# LICENSEE EVENT REPORT (LER) TEXT CONTINUATION

FACILITY NAME (1)	DOCKET NUMBER (2)	LER NUMBER (6)			PAGE (3)	
St. Lucio Unit 1	05000005	YEAR	SEQUENTIAL NUMBER	REVISION NUMBER		
St. Lacie Unit I	05000335	2001	- 008 -	00	Fage 3 OI 3	

TEXT (If more space is required, use additional copies of NRC Form 366A) (17)

requirements with an inoperable EDG. Because the TS amendment will allow operation comparable to FPL's former interpretation of the current TS, this event had no impact on the health and safety of the public.

#### Corrective Actions

1. FPL submitted proposed St. Lucie TS amendments on October 17, 2001 via FPL letter L-2001-230.

## Additional Information

Failed Components Identified

None

Similar Events

None