

May 24, 1994

Docket Nos. 50-327
and 50-328

Tennessee Valley Authority
ATTN: Dr. Mark O. Medford, Vice President
Technical Support
3B Lookout Place
1101 Market Street
Chattanooga, Tennessee 37402-2801

Dear Dr. Medford:

SUBJECT: ISSUANCE OF AMENDMENTS (TAC NOS. M87872 AND M87873) (TS 93-09)

The Commission has issued the enclosed Amendment No. 182 to Facility Operating License No. DPR-77 and Amendment No. 174 to Facility Operating License No. DPR-79 for the Sequoyah Nuclear Plant, Units 1 and 2, respectively. These amendments are in response to your application dated October 1, 1993, which was supplemented by letter dated March 29, 1994.

The amendments revise the setpoints and time delays for the auxiliary feedwater loss of power and 6.9 kv shutdown board loss-of-voltage and degraded-voltage instrumentation. In addition, the description, total number of channels, channels to trip, minimum channels operable, actions, trip setpoints, allowable values, channel checks, and channel functional test requirements for loss-of-power instrumentation have been revised.

A copy of the Safety Evaluation is also enclosed. Notice of Issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

Original signed:

David E. LaBarge, Sr. Project Manager
Project Directorate II-4
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

9406070273 940524
PDR ADOCK 05000327
P PDR

Enclosures:

1. Amendment No. 182 to License No. DPR-77
2. Amendment No. 174 to License No. DPR-79
3. Safety Evaluation

cc w/enclosures:
See next page

NAME:	PDII-4/LA <i>LA</i>	PDII-4/PM <i>PM</i>	OGC <i>OGC</i>	PDII-4/D <i>DE</i>
OFFICE:	BC <i>BC</i>	DLaBarge	R. Bachmann	FHebdon
DATE:	5/14/94	5/14/94	5/10/94	5/12/94

DOCUMENT NAME: G:\SQN\87872.AMM

0500085

WIDE FILE CENTER COPY

DF01
1/1

AMENDMENT NO. 182 FOR SEQUOYAH UNIT NO. 1 - DOCKET NO. 50-327 and
AMENDMENT NO. 174 FOR SEQUOYAH UNIT NO. 2 - DOCKET NO. 50-328
DATED: May 24, 1994

DISTRIBUTION:

Docket Files

NRC & Local PDRs

SNR Reading File

S. Varga 14-E-4

F. Hebdon

B. Clayton

D. LaBarge

J. Johnson, Acting RII

M. Lesser RII

OGC 15-B-18

D. Hagan MNBB-3206

G. Hill T5-C-3 (2 per docket)

C. Grimes 11-E-22

J. Wermiel

C. Berlinger

S. Mitra

ACRS(10)

OPA 2-G-5

OC/LFDCB MNBB-9112

cc: Plant Service List



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

TENNESSEE VALLEY AUTHORITY

DOCKET NO. 50-327

SEQUOYAH NUCLEAR PLANT, UNIT 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 182
License No. DPR-77

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Tennessee Valley Authority (the licensee) dated October 1, 1993, and supplemented by letter dated March 29, 1994, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C.(2) of Facility Operating License No. DPR-77 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 182, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance, to be implemented upon completion of the related plant modifications during the Unit 2 Cycle 6 refueling outage.

FOR THE NUCLEAR REGULATORY COMMISSION

David C. Trumble for

Frederick J. Hebdon, Director
Project Directorate II-4
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: May 24, 1994

ATTACHMENT TO LICENSE AMENDMENT NO. 182

FACILITY OPERATING LICENSE NO. DPR-77

DOCKET NO. 50-327

Revise the Appendix A Technical Specifications by removing the pages identified below and inserting the enclosed pages. The revised pages are identified by the captioned amendment number and contain marginal lines indicating the area of change.

REMOVE

3/4 3-20
3/4 3-21
3/4 3-22
3/4 3-23
3/4 3-23a
3/4 3-27a
3/4 3-27b
3/4 3-32
3/4 3-33a
3/4 3-37
3/4 3-37a
3/4 3-38
B3/4 7-2a

INSERT

3/4 3-20
3/4 3-21
3/4 3-22
3/4 3-23
3/4 3-23a
3/4 3-27a
3/4 3-27b
3/4 3-32
3/4 3-33a
3/4 3-37
3/4 3-37a
3/4 3-38
B3/4 7-2a

TABLE 3.3-3 (Continued)

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION

FUNCTIONAL UNIT	TOTAL NO. OF CHANNELS	CHANNELS TO TRIP	MINIMUM CHANNELS OPERABLE	APPLICABLE MODES	ACTION
e. Loss of Power Start					
1. Voltage Sensors	3/shutdown board**	2/shutdown board**	3/shutdown board**	1, 2, 3	35
2. Load Shed Timer	2/shutdown board**	1/shutdown board**	2/shutdown board**	1, 2, 3	35
f. Trip of Main Feedwater Pumps Start Motor-Driven Pumps and Turbine Driven Pump	1/pump	1/pump	1/pump	1, 2	20*
g. Auxiliary Feedwater Suction Pressure-Low	3/pump	2/pump	3/pump	1, 2, 3	21*
h. Auxiliary Feedwater Suction Transfer Time Delays					
1. Motor-Driven Pump	1/pump	1/pump	1/pump	1, 2, 3	21*
2. Turbine-Driven Pump	2/pump	1/pump	2/pump	1, 2, 3	21*

**Unit 1 Shutdown Boards Only

TABLE 3.3-3 (Continued)
ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION

<u>FUNCTIONAL UNIT</u>	<u>TOTAL NO. OF CHANNELS</u>	<u>CHANNELS TO TRIP</u>	<u>MINIMUM CHANNELS OPERABLE</u>	<u>APPLICABLE MODES</u>	<u>ACTION</u>
7. LOSS OF POWER					
a. 6.9 kv Shutdown Board --Loss of Voltage					
1. Voltage Sensors	3/shutdown board	2/shutdown board	3/shutdown board	1, 2, 3, 4, 5####, 6####	34
2. Diesel Generator Start and Load Shed Timer	2/shutdown board	1/shutdown board	2/shutdown board	1, 2, 3, 4 5####, 6####	34
b. 6.9 kv Shutdown Board Degraded Voltage					
1. Voltage Sensors	3/shutdown board	2/shutdown board	3/shutdown board	1, 2, 3, 4 5####, 6####	34
2. Diesel Generator Start and Load Shed Timer	2/shutdown board	1/shutdown board	2/shutdown board	1, 2, 3, 4 5####, 6####	34
3. SI/Degraded Voltage Logic Enable Timer	2/shutdown board	1/shutdown board	2/shutdown board	1, 2, 3, 4	34
8. ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INTERLOCKS					
a. Pressurizer Pressure - P-11/Not P-11	3	2	2	1, 2, 3	22a
b. Deleted					
c. Steam Generator Level P-14	3/loop	2/loop any loop	3/loop	1, 2	22c

TABLE 3.3-3 (Continued)

TABLE NOTATION

- #Trip function may be bypassed in this MODE below P-11 (Pressurizer Pressure Block of Safety Injection) setpoint.
##Trip function automatically blocked above P-11 and may be blocked below P-11 when Safety Injection on Steam Line Pressure-Low is not blocked.
###The channel(s) associated with the protective functions derived from the out of service Reactor Coolant Loop shall be placed in the tripped mode.
####When Associated Diesel Generator is required to be OPERABLE By LCO 3.8.1.2, "AC Sources-Shutdown." The Provisions of Specification 3.0.4 are not applicable.
*The provisions of Specification 3.0.4 are not applicable.

ACTION STATEMENTS

- ACTION 15 - With the number of OPERABLE Channels one less than the Total Number of Channels, be in at least HOT STANDBY within 12 hours and in COLD SHUTDOWN within the following 30 hours; however, one channel may be bypassed for up to 4 hours for surveillance testing per Specification 4.3.2.1.1 provided the other channel is OPERABLE.
- ACTION 16 - Deleted.
- ACTION 17 - With the number of OPERABLE Channels one less than the Total Number of Channels, STARTUP and/or POWER OPERATION may proceed provided the following conditions are satisfied:
- The inoperable channel is placed in the tripped condition within 6 hours.
 - The Minimum Channels OPERABLE requirements is met; however, the inoperable channel may be bypassed for up to 4 hours for surveillance testing of other channels per Specification 4.3.2.1.1.
- ACTION 18 - With the number of OPERABLE Channels one less than the Total Number of Channels, operation may proceed provided the inoperable channel is placed in the bypassed condition and the Minimum Channels OPERABLE requirement is met; one additional channel may be bypassed for up to 4 hours for surveillance testing per Specification 4.3.2.1.1.
- ACTION 19 - With less than the Minimum Channels OPERABLE, operation may continue provided the containment purge supply and exhaust valves are maintained closed.
- ACTION 20 - With the number of OPERABLE Channels one less than the Total Number of Channels, restore the inoperable channel to OPERABLE status within 48 hours or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

TABLE 3.3-3 (Continued)

- ACTION 21 - With less than the Minimum Number of Channels OPERABLE, declare the associated auxiliary feedwater pump inoperable, and comply with the ACTION requirements of Specification 3.7.1.2.
- ACTION 22 - With less than the Minimum Number of Channels OPERABLE, declare the interlock inoperable and verify that all affected channels of the functions listed below are OPERABLE or apply the appropriate ACTION statement(s) for those functions. Functions to be evaluated are:
- a. Safety Injection
 - Pressurizer Pressure
 - Steam Line Pressure
 - Negative Steam Line Pressure Rate
 - b. Deleted
 - c. Turbine Trip
 - Steam Generator Level High-High
 - Feedwater Isolation
 - Steam Generator Level High-High
- ACTION 23 - With the number of OPERABLE channels one less than the Total Number of Channels, be in at least HOT STANDBY within 6 hours and in at least HOT SHUTDOWN within the following 6 hours; however, one channel may be bypassed for up to 2 hours for surveillance testing per Specification 4.3.2.1.1.
- ACTION 24 - With the number of OPERABLE channels one less than the Total Number of Channels, restore the inoperable channel to OPERABLE status within 48 hours or be in at least HOT STANDBY within 6 hours and in at least HOT SHUTDOWN within the following 6 hours.
- ACTION 25 - With the number of OPERABLE channels one less than the Total Number of Channels, restore the inoperable channel to OPERABLE status within 48 hours or declare the associated valve inoperable and take the ACTION required by Specification 3.7.1.5.
- ACTION 34 -
- a. With the number of OPERABLE channels one less than the Total Number of Channels, restore the inoperable channel to OPERABLE status within 6 hours or enter applicable Limiting Condition(s) For Operation and Action(s) for the associated diesel generator set made inoperable by the channel.
 - b. With the number of OPERABLE channels less than the Total Number of Channels by more than one, restore all but one channel to OPERABLE status within 1 hour or enter applicable Limiting Condition(s) for Operation and Action(s) for the associated diesel generator set made inoperable by the channels.

TABLE 3.3-3 (Continued)

- ACTION 35 -
- a. With the number of OPERABLE channels one less than the Total Number of Channels, restore the inoperable channel to OPERABLE status within 6 hours or enter applicable Limiting Condition(s) For Operation and Action(s) for the associated auxiliary feedwater pump made inoperable by the channel.
 - b. With the number of OPERABLE channels less than the Total Number of Channels by more than one, restore all but one channel to OPERABLE status within 1 hour or enter applicable Limiting Condition(s) For Operation and Action(s) for the associated auxiliary feedwater pump made inoperable by the channel.
- ACTION 36 - With the number of OPERABLE channels one less than the Total Number of Channels, STARTUP and/or POWER OPERATION may proceed provided the following conditions are satisfied:
- a. The inoperable channel is placed in the tripped condition within 6 hours.
 - b. For the affected protection set, the Trip Time Delay for one affected steam generator (T_s) is adjusted to match the Trip Time Delay for multiple affected steam generators (T_M) within 4 hours.
 - c. The Minimum Channels OPERABLE requirement is met; however, the inoperable channel may be bypassed for up to 4 hours for surveillance testing of other channels per Specification 4.3.2.1.1.
- ACTION 37 - With the number of OPERABLE channels one less than the Total Number of Channels, STARTUP and/or POWER OPERATION may proceed provided that within 6 hours, for the affected protection set, the Trip Time Delays (T_s and T_M) threshold power level for zero seconds time delay is adjusted to 0% RTP.
- ACTION 38 - With the number of OPERABLE channels one less than the Total Number of Channels, STARTUP and/or POWER OPERATION may proceed provided that within 6 hours, for the affected protection set, the Steam Generator Water Level - Low-Low (EAM) channels trip setpoint is adjusted to the same value as Steam Generator Water Level - Low-Low (Adverse).

TABLE 3.3-4 (Continued)

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION TRIP SETPOINTS

<u>FUNCTIONAL UNIT</u>	<u>TRIP SETPOINT</u>	<u>ALLOWABLE VALUES</u>
ii. RCS Loop ΔT Equivalent to Power > 50% RTP		
Coincident with Steam Generator Water Level--Low-Low (Adverse) and Containment Pressure (EAM) or Steam Generator Water Level--Low-Low (EAM)	$\geq 15.0\%$ of narrow range instrument span ≤ 0.5 psig $\geq 10.7\%$ of narrow range instrument span	$\geq 14.4\%$ of narrow range instrument span ≤ 0.6 psig $\geq 10.1\%$ of narrow range instrument span
d. S.I.	See 1 above (all SI Setpoints)	
e. Loss of Power Start		
1. Voltage Sensors	≥ 5520 volts	≥ 5472 volts
2. Load Shed Timer	1.25 seconds	1.25 ± 0.09 seconds
f. Trip of Main Feedwater Pumps	N.A.	N.A.
g. Auxiliary Feedwater Suction Pressure-Low	≥ 2 psig (motor driven pump) ≥ 13.9 psig (turbine driven pump)	≥ 1 psig (motor driven pump) ≥ 12 psig (turbine driven pump)
h. Auxiliary Feedwater Suction Transfer Time Delays	4 seconds (motor driven pump) 5.5 seconds (turbine driven pump)	4 seconds ± 0.4 seconds (motor driven pump) 5.5 seconds ± 0.55 seconds (turbine driven pump)

TABLE 3.3-4 (Continued)

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION TRIP SETPOINTS

<u>FUNCTIONAL UNIT</u>	<u>TRIP SETPOINT</u>	<u>ALLOWABLE VALUES</u>
7. LOSS OF POWER		
a. 6.9 kv Shutdown Board Undervoltage		
Loss of Voltage		
1. Voltage Sensors	≥ 5520 volts	≥ 5472 volts
2. Diesel Generator Start and Load Shed Timer	1.25 seconds	1.25 \pm 0.09 seconds
b. 6.9 kv Shutdown Board-Degraded Voltage		
1. Voltage Sensors	6456 volts	≥ 6403.5 volts (dropout) ≤ 6626.5 volts (reset)
2. Diesel Generator Start and Load Shed Timer	≤ 300 seconds	≤ 321 seconds
3. SI/Degraded Voltage Logic Enable Timer	10 seconds	10 seconds \pm 0.75 seconds
8. ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INTERLOCKS		
a. Pressurizer Pressure		
1. Not P-11, Automatic Unblock of Safety Injection on Increasing Pressure	≤ 1970 psig	≤ 1975.2 psig
2. P-11, Enable Manual Block of Safety Injection on Decreasing Pressure	≥ 1962 psig	≥ 1956.8 psig

TABLE 3.3-5 (Continued)
ENGINEERED SAFETY FEATURES RESPONSE TIMES

<u>INITIATING SIGNAL AND FUNCTION</u>	<u>RESPONSE TIME IN SECONDS</u>
10. <u>Loss of Power Start</u>	
a. Auxiliary Feedwater Pumps	$\leq 60^{(11)}$
11. <u>Trip of Main Feedwater Pumps</u>	
a. Auxiliary Feedwater Pumps	$\leq 60^{(11)}$
12. <u>Loss of Power</u>	
a. 6.9 kv Shutdown Board - Degraded Voltage or Loss of Voltage	$\leq 10^{(10)}$
13. <u>RWST Level-Low Coincident with Containment Sump Level-High and Safety Injection</u>	
a. Automatic Switchover to Containment Sump	≤ 250
14. <u>Containment Purge Air Exhaust Radioactivity - High</u>	
a. Containment Ventilation Isolation	$\leq 10^{(6)}$

INSTRUMENTATION

TABLE 3.3-5 (Continued)

TABLE NOTATION

- (7) Diesel generator starting and sequence loading delays not included. Offsite power available. Response time limit includes opening and closing of valves to establish SI path and attainment of discharge pressure for centrifugal charging pumps.
- (8) Diesel generator starting and sequence loading delays not included. Response time limit includes operating time of valves.
- (9) Diesel generator starting and sequence loading delays included. Response time limit includes operating time of valves.
- (10) The response time for loss of voltage is measured from the time the load shedding and diesel generator start signal is generated from the loss of voltage timer until the time full voltage is restored by the diesel. The response time for degraded voltage is measured from the time the load shedding signal is generated, either from the degraded voltage or the SI enable timer, to the time full voltage is restored by the diesel. The response time of the timers is covered by the requirements on their setpoints.
- (11) The provisions of Specification 4.0.4 are not applicable for entry into MODE 3 for the turbine-driven Auxiliary Feedwater Pump.
- (12) The following valves are exceptions to the response times shown in the Table and will have the values listed in seconds for the initiating signals and the function indicated:
 - Valves: FCV-67-89, -90, -105, -106
 - Response times: 7.b, 75⁽⁸⁾/85⁽⁹⁾
 - Valve: FCV-70-141
 - Response times: 7.b, 70⁽⁸⁾/80⁽⁹⁾
- (13) Containment purge valves only. Containment radiation monitor valves have a response time of 6.5 seconds or less.
- (14) Does not include Trip Time Delays. Response times noted include the transmitters, Eagle-21 process protection cabinets, solid state protection cabinets, and actuation devices (up to and including pumps). This reflects the response times necessary for THERMAL POWER in excess of 50% RTP.

TABLE 4.3-2 (Continued)

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>FUNCTIONAL UNIT</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL CALIBRATION</u>	<u>CHANNEL FUNCTIONAL TEST</u>	<u>MODES FOR WHICH SURVEILLANCE REQUIRED</u>
c. Main Steam Generator Water Level--Low-Low				
1. Steam Generator Water Level--Low-Low (Adverse)	S	R	Q	1, 2, 3
2. Steam Generator Water Level--Low-Low (EAM)	S	R	Q	1, 2, 3
3. RCS Loop ΔT	S	R	Q	1, 2, 3
4. Containment Pressure (EAM)	S	R	Q	1, 2, 3
d. S.I.	See 1 above (all SI surveillance requirements)			
e. Loss of Power Start				
1. Voltage Sensors	N.A.	R	M	1, 2, 3
2. Load Shed Timer	N.A.	R	N.A.	1, 2, 3
f. Trip of Main Feedwater Pumps	N.A.	N.A.	R	1, 2
g. Auxiliary Feedwater Suction Pressure-Low	N.A.	R	M	1, 2, 3
h. Auxiliary Feedwater Suction Transfer Time Delays	N.A.	R	N.A.	1, 2, 3
7. LOSS OF POWER				
a. 6.9 kv Shutdown Board - Loss of Voltage				
1. Voltage Sensors	N.A.	R	M	1, 2, 3, 4, 5#, 6#
2. Diesel Generator Start and Load Shed Timer	N.A.	R	N.A.	1, 2, 3, 4, 5#, 6#

TABLE 4.3-2 (Continued)

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION
SURVEILLANCE REQUIREMENTS

<u>FUNCTIONAL UNIT</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL CALIBRATION</u>	<u>CHANNEL FUNCTIONAL TEST</u>	<u>MODES FOR WHICH SURVEILLANCE REQUIRED</u>
b. 6.9 kv Shutdown Board - Degraded Voltage				
1. Voltage sensors	N.A.	R	M	1, 2, 3, 4, 5#, 6#
2. Diesel Generators Start and Load Shed Timer	N.A.	R	N.A.	1, 2, 3, 4, 5#, 6#
3. SI/Degraded Voltage Logic Enable Timer	N.A.	R	N.A.	1, 2, 3, 4
8. ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INTERLOCKS				
a. Pressurizer Pressure, P-11/Not P-11	N.A.	R(2)	N.A.	1, 2, 3
b. Deleted				
c. Steam Generator Level, P-14	N.A.	R(2)	N.A.	1, 2
9. AUTOMATIC SWITCHOVER TO CONTAINMENT SUMP				
a. RSWT Level - Low	S	R	Q	1, 2, 3, 4
COINCIDENT WITH Containment Sump Level - High AND Safety Injection	S	R	Q	1, 2, 3, 4
	(See 1 above for all Safety Injection Surveillance Requirements)			
b. Automatic Actuation Logic	N.A.	N.A.	M(1)	1, 2, 3, 4

TABLE 4.3-2 (Continued)

TABLE NOTATION

- # When associated diesel generator is required to be OPERABLE by LCO 3.8.1.2, "AC Sources - Shutdown."
- (1) Each train or logic channel shall be tested at least every 62 days on a STAGGERED TEST BASIS.
- (2) The total interlock function shall be demonstrated OPERABLE during CHANNEL CALIBRATION testing of each channel affected by interlock operation.

PLANT SYSTEMS

BASES

because of a main steam line or feedwater line break and a single failure of the B-train motor driven AFW pump. The two redundant sources must be aligned such that No. 1 steam generator source is open and operable and the No. 4 steam generator source is closed and operable.

For instances where one train of emergency raw cooling water (ERCW) is declared inoperable in accordance with technical specifications, the AFW turbine-driven pump is considered operable since it is supplied by both trains of ERCW. Similarly, the AFW turbine-driven pump is considered operable when one train of the AFW loss of power start function is declared inoperable in accordance with technical specifications because both 6.9 kilovolt shutdown board logic trains supply this function. This position is consistent with American National Standards Institute/ANS 58.9 requirements (i.e., postulation of the failure of the opposite train is not required while relying on the TS limiting condition for operation).

3/4.7.1.3 CONDENSATE STORAGE TANK

The OPERABILITY of the condensate storage tank with the minimum water volume ensures that sufficient water is available to maintain the RCS at HOT STANDBY conditions for 2 hours with steam discharge to the atmosphere concurrent with total loss of off-site power. The contained water volume limit includes an allowance for water not useable because of tank discharge line location or other physical characteristics.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

TENNESSEE VALLEY AUTHORITY

DOCKET NO. 50-328

SEQUOYAH NUCLEAR PLANT, UNIT 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 174
License No. DPR-79

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Tennessee Valley Authority (the licensee) dated October 1, 1993, and supplemented by letter dated March 29, 1994, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C.(2) of Facility Operating License No. DPR-79 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 174, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance, to be implemented upon completion of the related plant modifications during the Unit 2 Cycle 6 refueling outage.

FOR THE NUCLEAR REGULATORY COMMISSION

David P. Tunick for

Frederick J. Hebdon, Director
Project Directorate II-4
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: May 24, 1994

ATTACHMENT TO LICENSE AMENDMENT NO. 174

FACILITY OPERATING LICENSE NO. DPR-79

DOCKET NO. 50-328

Revise the Appendix A Technical Specifications by removing the pages identified below and inserting the enclosed pages. The revised pages are identified by the captioned amendment number and contain marginal lines indicating the area of change.

REMOVE

3/4 3-20
3/4 3-21
3/4 3-22
3/4 3-23
3/4 3-23a
3/4 3-27a
3/4 3-27b
3/4 3-32
3/4 3-33a
3/4 3-37
3/4 3-38
3/4 3-39
B3/4 7-2a

INSERT

3/4 3-20
3/4 3-21
3/4 3-22
3/4 3-23
3/4 3-23a
3/4 3-27a
3/4 3-27b
3/4 3-32
3/4 3-33a
3/4 3-37
3/4 3-38
3/4 3-39
B3/4 7-2a

TABLE 3.3-3 (Continued)

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION

<u>FUNCTIONAL UNIT</u>	<u>TOTAL NO. OF CHANNELS</u>	<u>CHANNELS TO TRIP</u>	<u>MINIMUM CHANNELS OPERABLE</u>	<u>APPLICABLE MODES</u>	<u>ACTION</u>
e. Loss of Power Start					
1. Voltage Sensors	3/shutdown board**	2/shutdown board**	3/shutdown board**	1, 2, 3	35
2. Load Shed Timer	2/shutdown board**	1/shutdown board**	2/shutdown board**	1, 2, 3	35
f. Trip of Main Feedwater Pumps Start Motor-Driven Pumps and Turbine Driven Pump	1/pump	1/pump	1/pump	1, 2	20*
g. Auxiliary Feedwater Suction Pressure-Low	3/pump	2/pump	3/pump	1, 2, 3	21*
h. Auxiliary Feedwater Suction Transfer Time Delays					
1. Motor-Driven Pump	1/pump	1/pump	1/pump	1, 2, 3	21*
2. Turbine-Driven Pump	2/pump	1/pump	2/pump	1, 2, 3	21*

**Unit 2 Shutdown Boards Only

TABLE 3.3-3 (Continued)

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION

<u>FUNCTIONAL UNIT</u>	<u>TOTAL NO. OF CHANNELS</u>	<u>CHANNELS TO TRIP</u>	<u>MINIMUM CHANNELS OPERABLE</u>	<u>APPLICABLE MODES</u>	<u>ACTION</u>
7. LOSS OF POWER					
a. 6.9 kv Shutdown Board --Loss of Voltage					
1. Voltage Sensors	3/shutdown board	2/shutdown board	3/shutdown board	1, 2, 3, 4, 5####, 6####	34
2. Diesel Generator Start and Load Shed Timer	2/shutdown board	1/shutdown board	2/shutdown board	1, 2, 3, 4 5####, 6####	34
b. 6.9 kv Shutdown Board Degraded Voltage					
1. Voltage Sensors	3/shutdown board	2/shutdown board	3/shutdown board	1, 2, 3, 4 5####, 6####	34
2. Diesel Generator Start and Load Shed Timer	2/shutdown board	1/shutdown board	2/shutdown board	1, 2, 3, 4 5####, 6####	34
3. SI/Degraded Voltage Logic Enable Timer	2/shutdown board	1/shutdown board	2/shutdown board	1, 2, 3, 4	34

TABLE 3.3-3 (Continued)

TABLE NOTATION

- #Trip function may be bypassed in this MODE below P-11 (Pressurizer Pressure Block of Safety Injection) setpoint.
##Trip function automatically blocked above P-11 and may be blocked below P-11 when Safety Injection on Steam Line Pressure-Low is not blocked.
###The channel(s) associated with the protective functions derived from the out of service Reactor Coolant Loop shall be placed in the tripped mode.
####When Associated Diesel Generator is required to be OPERABLE By LCO 3.8.1.2, "AC Sources-Shutdown." The Provisions of Specification 3.0.4 are not applicable.
*The provisions of Specification 3.0.4 are not applicable.

ACTION STATEMENTS

- ACTION 15 - With the number of OPERABLE Channels one less than the Total Number of Channels, be in HOT STANDBY within 12 hours and in COLD SHUTDOWN within the following 30 hours; however, one channel may be bypassed for up to 4 hours for surveillance testing per Specification 4.3.2.1.1 provided the other channel is OPERABLE.
- ACTION 16 - Deleted.
- ACTION 17 - With the number of OPERABLE Channels one less than the Total Number of Channels, STARTUP and/or POWER OPERATION may proceed provided the following conditions are satisfied:
- The inoperable channel is placed in the tripped condition within 6 hours.
 - The Minimum Channels OPERABLE requirements is met; however, the inoperable channel may be bypassed for up to 4 hours for surveillance testing of other channels per Specification 4.3.2.1.1.
- ACTION 18 - With the number of OPERABLE Channels one less than the Total Number of Channels, operation may proceed provided the inoperable channel is placed in the bypassed condition and the Minimum Channels OPERABLE requirement is met; one additional channel may be bypassed for up to 4 hours for surveillance testing per Specification 4.3.2.1.1.
- ACTION 19 - With less than the Minimum Channels OPERABLE, operation may continue provided the containment purge supply and exhaust valves are maintained closed.
- ACTION 20 - With the number of OPERABLE Channels one less than the Total Number of Channels, restore the inoperable channel to OPERABLE status within 48 hours or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

TABLE 3.3-3 (Continued)

- ACTION 21 - With less than the Minimum Number of Channels OPERABLE, declare the associated auxiliary feedwater pump inoperable, and comply with the ACTION requirements of Specification 3.7.1.2.
- ACTION 22 - With less than the Minimum Number of Channels OPERABLE, declare the interlock inoperable and verify that all affected channels of the functions listed below are OPERABLE or apply the appropriate ACTION statement(s) for those functions. Functions to be evaluated are:
- a. Safety Injection
 - Pressurizer Pressure
 - Steam Line Pressure
 - Negative Steam Line Pressure Rate
 - b. Deleted
 - c. Turbine Trip
 - Steam Generator Level High-High
 - Feedwater Isolation
 - Steam Generator Level High-High
- ACTION 23 - With the number of OPERABLE channels one less than the Total Number of Channels, be in at least HOT STANDBY within 6 hours and in at least HOT SHUTDOWN within the following 6 hours; however, one channel may be bypassed for up to 2 hours for surveillance testing per Specification 4.3.2.1.1.
- ACTION 24 - With the number of OPERABLE channels one less than the Total Number of Channels, restore the inoperable channel to OPERABLE status within 48 hours or be in at least HOT STANDBY within 6 hours and in at least HOT SHUTDOWN within the following 6 hours.
- ACTION 25 - With the number of OPERABLE channels one less than the Total Number of Channels, restore the inoperable channel to OPERABLE status within 48 hours or declare the associated valve inoperable and take the ACTION required by Specification 3.7.1.5.
- ACTION 34 -
- a. With the number of OPERABLE channels one less than the Total Number of Channels, restore the inoperable channel to OPERABLE status within 6 hours or enter applicable Limiting Condition(s) For Operation and Action(s) for the associated diesel generator set made inoperable by the channel.
 - b. With the number of OPERABLE channels less than the Total Number of Channels by more than one, restore all but one channel to OPERABLE status within 1 hour or enter applicable Limiting Condition(s) for Operation and Action(s) for the associated diesel generator set made inoperable by the channels.

TABLE 3.3-3 (Continued)

- ACTION 35 -
- a. With the number of OPERABLE channels one less than the Total Number of Channels, restore the inoperable channel to OPERABLE status within 6 hours or enter applicable Limiting Condition(s) For Operation and Action(s) for the associated auxiliary feedwater pump made inoperable by the channel.
 - b. With the number of OPERABLE channels less than the Total Number of Channels by more than one, restore all but one channel to OPERABLE status within 1 hour or enter applicable Limiting Condition(s) For Operation and Action(s) for the associated auxiliary feedwater pump made inoperable by the channel.
- ACTION 36 - With the number of OPERABLE channels one less than the Total Number of Channels, STARTUP and/or POWER OPERATION may proceed provided the following conditions are satisfied:
- a. The inoperable channel is placed in the tripped condition within 6 hours.
 - b. For the affected protection set, the Trip Time Delay for one affected steam generator (T_s) is adjusted to match the Trip Time Delay for multiple affected steam generators (T_M) within 4 hours.
 - c. The Minimum Channels OPERABLE requirement is met; however, the inoperable channel may be bypassed for up to 4 hours for surveillance testing of other channels per Specification 4.3.2.1.1.
- ACTION 37 - With the number of OPERABLE channels one less than the Total Number of Channels, STARTUP and/or POWER OPERATION may proceed provided that within 6 hours, for the affected protection set, the Trip Time Delays (T_s and T_M) threshold power level for zero seconds time delay is adjusted to 0% RTP.
- ACTION 38 - With the number of OPERABLE channels one less than the Total Number of Channels, STARTUP and/or POWER OPERATION may proceed provided that within 6 hours, for the affected protection set, the Steam Generator Water Level - Low-Low (EAM) channels trip setpoint is adjusted to the same value as Steam Generator Water Level - Low-Low (Adverse).

TABLE 3.3-4 (Continued)

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION TRIP SETPOINTS

<u>FUNCTIONAL UNIT</u>	<u>TRIP SETPOINT</u>	<u>ALLOWABLE VALUES</u>
ii. RCS Loop ΔT Equivalent to Power > 50% RTP		
Coincident with Steam Generator Water Level--Low-Low (Adverse) and Containment Pressure (EAM) or Steam Generator Water Level--Low-Low (EAM)	$\geq 15.0\%$ of narrow range instrument span	$\geq 14.4\%$ of narrow range instrument span
	≤ 0.5 psig	≤ 0.6 psig
	$\geq 10.7\%$ of narrow range instrument span	$\geq 10.1\%$ of narrow range instrument span
d. S.I.	See 1 above (all SI Setpoints)	
e. Loss of Power Start		
1. Voltage Sensors	≥ 5520 volts	≥ 5472 volts
2. Load Shed Timer	1.25 seconds	1.25 ± 0.09 seconds
f. Trip of Main Feedwater Pumps	N.A.	N.A.
g. Auxiliary Feedwater Suction Pressure--Low	≥ 2 psig (motor driven pump) ≥ 13.9 psig (turbine driven pump)	≥ 1 psig (motor driven pump) ≥ 12 psig (turbine driven pump)
h. Auxiliary Feedwater Suction Transfer Time Delays	4 seconds (motor driven pump) 5.5 seconds (turbine driven pump)	4 seconds ± 0.4 seconds (motor driven pump) 5.5 seconds ± 0.55 seconds (turbine driven pump)

TABLE 3.3-4 (Continued)

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION TRIP SETPOINTS

FUNCTIONAL UNIT	TRIP SETPOINT	ALLOWABLE VALUES
7. LOSS OF POWER		
a. 6.9 kv Shutdown Board Undervoltage Loss of Voltage		
1. Voltage Sensors	≥ 5520 volts	≥ 5472 volts
2. Diesel Generator Start and Load Shed Timer	1.25 seconds	1.25 ± 0.09 seconds
b. 6.9 kv Shutdown Board-Degraded Voltage		
1. Voltage Sensors	6456 volts	≥ 6403.5 volts (dropout) ≤ 6626.5 volts (reset)
2. Diesel Generator Start and Load Shed Timer	≤ 300 seconds	≤ 321 seconds
3. SI/Degraded Voltage Logic Enable Timer	10 seconds	10 seconds \pm 0.75 seconds
8. ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INTERLOCKS		
a. Pressurizer Pressure		
1. Not P-11, Automatic Unblock of Safety Injection on Increasing Pressure	≤ 1970 psig	≤ 1975.2 psig
2. P-11, Enable Manual Block of Safety Injection on Decreasing Pressure	≥ 1962 psig	≥ 1956.8 psig

TABLE 3.3-5 (Continued)
ENGINEERED SAFETY FEATURES RESPONSE TIMES

<u>INITIATING SIGNAL AND FUNCTION</u>	<u>RESPONSE TIME IN SECONDS</u>
10. <u>Loss of Power Start</u>	
a. Auxiliary Feedwater Pumps	$\leq 60^{(11)}$
11. <u>Trip of Main Feedwater Pumps</u>	
a. Auxiliary Feedwater Pumps	$\leq 60^{(11)}$
12. <u>Loss of Power</u>	
a. 6.9 kv Shutdown Board - Degraded Voltage or Loss of Voltage	$\leq 10^{(10)}$
13. <u>RWST Level-Low Coincident with Containment Sump Level-High and Safety Injection</u>	
a. Automatic Switchover to Containment Sump	≤ 250
14. <u>Containment Purge Air Exhaust Radioactivity - High</u>	
a. Containment Ventilation Isolation	$\leq 10^{(6)}$

INSTRUMENTATION

TABLE 3.3-5 (Continued)

TABLE NOTATION

- (7) Diesel generator starting and sequence loading delays not included. Offsite power available. Response time limit includes opening and closing of valves to establish SI path and attainment of discharge pressure for centrifugal charging pumps.
- (8) Diesel generator starting and sequence loading delays not included. Response time limit includes operating time of valves.
- (9) Diesel generator starting and sequence loading delays included. Response time limit includes operating time of valves.
- (10) The response time for loss of voltage is measured from the time the load shedding and diesel generator start signal is generated from the loss of voltage timer until the time full voltage is restored by the diesel. The response time for degraded voltage is measured from the time the load shedding signal is generated, either from the degraded voltage or the SI enable timer, to the time full voltage is restored by the diesel. The response time of the timers is covered by the requirements on their setpoints.
- (11) The provisions of Specification 4.0.4 are not applicable for entry into MODE 3 for the turbine-driven Auxiliary Feedwater Pump.
- (12) The following valves are exceptions to the response times shown in the Table and will have the values listed in seconds for the initiating signals and the function indicated:
 - Valves: FCV-67-89, -90, -105, -106
 - Response times: 7.b, 75⁽⁸⁾/85⁽⁹⁾
 - Valve: FCV-70-141
 - Response times: 7.b, 70⁽⁸⁾/80⁽⁹⁾
- (13) Containment purge valves only. Containment radiation monitor valves have a response time of 6.5 seconds or less.
- (14) Does not include Trip Time Delays. Response times noted include the transmitters, Eagle-21 process protection cabinets, solid state protection cabinets, and actuation devices (up to and including pumps). This reflects the response times necessary for THERMAL POWER in excess of 50% RTP.

TABLE 4.3-2 (Continued)

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>FUNCTIONAL UNIT</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL CALIBRATION</u>	<u>CHANNEL FUNCTIONAL TEST</u>	<u>MODES FOR WHICH SURVEILLANCE REQUIRED</u>
c. Main Steam Generator Water Level--Low-Low				
1. Steam Generator Water Level--Low-Low (Adverse)	S	R	Q	1, 2, 3
2. Steam Generator Water Level--Low-Low (EAM)	S	R	Q	1, 2, 3
3. RCS Loop ΔT	S	R	Q	1, 2, 3
4. Containment Pressure (EAM)	S	R	Q	1, 2, 3
d. S.I.	See 1 above (all SI surveillance requirements)			
e. Loss of Power Start				
1. Voltage Sensors	N.A.	R	M	1, 2, 3
2. Load Shed Timer	N.A.	R	N.A.	1, 2, 3
f. Trip of Main Feedwater Pumps	N.A.	N.A.	R	1, 2
g. Auxiliary Feedwater Suction Pressure-Low	N.A.	R	M	1, 2, 3
h. Auxiliary Feedwater Suction Transfer Time Delays	N.A.	R	N.A.	1, 2, 3
7. LOSS OF POWER				
a. 6.9 kv Shutdown Board - Loss of Voltage				
1. Voltage Sensors	N.A.	R	M	1, 2, 3, 4, 5#, 6#
2. Diesel Generator Start and Load Shed Timer	N.A.	R	N.A.	1, 2, 3, 4, 5#, 6#

TABLE 4.3-2 (Continued)

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION
SURVEILLANCE REQUIREMENTS

<u>FUNCTIONAL UNIT</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL CALIBRATION</u>	<u>CHANNEL FUNCTIONAL TEST</u>	<u>MODES FOR WHICH SURVEILLANCE REQUIRED</u>
b. 6.9 kv Shutdown Board - Degraded Voltage				
1. Voltage sensors	N.A.	R	M	1, 2, 3, 4, 5#, 6#
2. Diesel Generators Start and Load Shed Timer	N.A.	R	N.A.	1, 2, 3, 4, 5#, 6#
3. SI/Degraded Voltage Logic Enable Timer	N.A.	R	N.A.	1, 2, 3, 4
8. ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INTERLOCKS				
a. Pressurizer Pressure, P-11/Not P-11	N.A.	R(2)	N.A.	1, 2, 3
b. Deleted				
c. Steam Generator Level, P-14	N.A.	R(2)	N.A.	1, 2
9. AUTOMATIC SWITCHOVER TO CONTAINMENT SUMP				
a. RSWT Level - Low COINCIDENT WITH Containment Sump Level - High AND Safety Injection	S S (See 1 above for all Safety Injection Surveillance Requirements)	R R	Q Q	1, 2, 3, 4 1, 2, 3, 4
b. Automatic Actuation Logic	N.A.	N.A.	M(1)	1, 2, 3, 4

TABLE 4.3-2 (Continued)

TABLE NOTATION

- # When associated diesel generator is required to be OPERABLE by LCO
3.8.1.2, "AC Sources - Shutdown."
- (1) Each train or logic channel shall be tested at least every 62 days on a
STAGGERED TEST BASIS.
- (2) The total interlock function shall be demonstrated OPERABLE during CHANNEL
CALIBRATION testing of each channel affected by interlock operation.

PLANT SYSTEMS

BASES

AUXILIARY FEEDWATER SYSTEM (continued)

because of a main steam line or feedwater line break and a single failure of the B-train motor driven AFW pump. The two redundant sources must be aligned such that No. 1 steam generator source is open and operable and the No. 4 steam generator source is closed and operable.

For instances where one train of emergency raw cooling water (ERCW) is declared inoperable in accordance with technical specifications, the AFW turbine-driven pump is considered operable since it is supplied by both trains of ERCW. Similarly, the AFW turbine-driven pump is considered operable when one train of the AFW loss of power start function is declared inoperable in accordance with technical specifications because both 6.9 kilovolt shutdown board logic trains supply this function. This position is consistent with American National Standards Institute/ANS 58.9 requirements (i.e., postulation of the failure of the opposite train is not required while relying on the TS limiting condition for operation).

3/4.7.1.3 CONDENSATE STORAGE TANK

The OPERABILITY of the condensate storage tank with the minimum water volume ensures that sufficient water is available to maintain the RCS at HOT STANDBY conditions for 2 hours with steam discharge to the atmosphere concurrent with total loss of off-site power. The contained water volume limit includes an allowance for water not useable because of tank discharge line location or other physical characteristics.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

ENCLOSURE 3

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION
RELATED TO AMENDMENT NO. 182 TO FACILITY OPERATING LICENSE NO. DPR-77
AND AMENDMENT NO. 174 TO FACILITY OPERATING LICENSE NO. DPR-79
TENNESSEE VALLEY AUTHORITY
SEQUOYAH NUCLEAR PLANT, UNITS 1 AND 2
DOCKET NOS. 50-327 AND 50-328

1.0 BACKGROUND

By application dated October 1, 1993, the Tennessee Valley Authority (TVA or the licensee) proposed amendments to the Technical Specifications (TS) for Sequoyah Nuclear Plant (SQN) Units 1 and 2. The proposed changes would revise the setpoints and time delays for the auxiliary feedwater (AFW) loss of power and 6.9 kv shutdown board loss-of-voltage and degraded-voltage instrumentation. These proposed changes also revise the description, total number of channels, channels to trip, minimum channels operable, actions, trip setpoints, allowable values, channel checks, and channel functional test requirements for loss-of-power instrumentation.

In the supplemental letter dated March 28, 1994, the licensee supplied clarifying information that did not change the initial proposed no significant hazards consideration determination.

2.0 INTRODUCTION

The loss-of-voltage and degraded-voltage protection are provided to 6900-volt shutdown boards to ensure adequate voltage is available to the safety-related loads. A loss-of-voltage or a sustained degraded-voltage condition will start the emergency diesel generator (EDG) that will be connected to the shutdown board after tripping normal and alternate feeders and shedding the major loads. After the EDG has been tied to the shutdown board, the loss-of-voltage relays continue to provide the load-shed functions and subsequent resequencing of the loads onto the EDG if necessary.

After the EDG has connected to the shutdown board and the load sequencing interval has been achieved, the loss-of-voltage, load-shed function on the 6.9 kv shutdown board initiates a motor-driven AFW pump start. In addition, the load-shed actuation immediately activates a turbine-driven AFW pump start. The reactor coolant pumps would not be available to provide forced coolant flow in the event of loss of voltage, but the turbine-driven AFW pumps start to initiate natural circulation and heat removal in the reactor coolant system via the steam generators. The AFW pumps provide sufficient heat-removal capability to prevent the pressurizer from filling during design-basis accidents.

TVA has been working with the Electrical Distribution System (EDS) Clearinghouse to establish guidelines for degraded-voltage analyses. The guidelines were developed by the EDS by reviewing all inspection findings and enforcement actions from the Electrical Distribution System Functional Inspections (EDSFIs) that were conducted by the NRC at the operating plants. The guidelines established by this effort have been applied to the SQN loss-of-power and degraded-voltage analysis and have led to changes of loss-of-power and degraded-voltage instrumentation. The purpose of these proposed changes is to ensure that the adequate voltage is available to the safety-related loads.

3.0 EVALUATION

The following proposed changes pertain to both Unit 1 and 2 TS unless otherwise stated.

Change 1: Item 6.e of TS Table 3.3-3 would be revised to reflect the use of a 2-out-of-3 voltage sensor logic for detecting loss of power. These sensors initiate load-shedding and subsequent AFW pump start through two separate timing relays with a one-out-of-two logic scheme. In addition, the Functional Unit column heading would be changed from "Station Blackout ..." to "Loss of Power Start" to avoid confusion with the "station blackout" terminology associated with the 10 CFR 50.63 requirements. Also, new action requirement would be incorporated and a footnote added to clarify that this requirement only applies to shutdown board instrumentation on the same unit.

Change 2: Item 7.a of TS Table 3.3-3 would be revised to reflect the use of a two-out-of-three voltage sensor logic for detecting loss of voltage on the 6.9 kv shutdown boards. These sensors start the EDG and initiate load-shedding through two separate timing relays with one-out-of-two logic scheme. This would be accomplished by having one requirement for the voltage sensors and another requirement for the timers. The applicable modes would also be expanded to indicate that the associated EDG is required to be operable in Modes 5 and 6. The applicable action requirement would be revised to correspond with this design change and the exclusion of the provisions to TS 3.0.4 would be deleted.

The major changes would remove the normal feeder loss-of-voltage relays on the 6.9 kv shutdown board and modify the load-shedding and EDG start relays on the 6.9 kv shutdown board to a two-out-of-three logic scheme. This requires installing three new solid-state voltage sensors on the shutdown board bus and two electronic-timing relays to actuate load-shedding and EDG start for loss-of-voltage conditions. The loss-of-power start requirements for the AFW pumps would be altered because the same instrumentation for load-shedding performs this function. In addition, the load-shed actuation immediately initiates a turbine-driven AFW pump start. The proposed change that makes the "Minimum Channels Operable" column the same as "Total Number of Channels" column has been incorporated to clarify that operability of all channels is required for continued power operation.

The addition of the footnotes described in Change 1 would clarify that only the conditions for the shutdown boards associated with the same unit apply to

the operability of this instrumentation. This clarification removes the potential to declare the AFW loss-of-power start instrumentation inoperable for a given unit when only the instrumentation of the opposite unit is inoperable.

The addition of Modes 5 and 6 described in Change 2 to the applicable modes for operability would specify the conditions when these functions are required to support safety functions. The footnote addition to the Modes 5 and 6 requirement would clarify that the loss-of-power instrumentation associated with a 6.9 kv shutdown board is required to be operable when the affected EDG is required to be operable. The TS 3.0.4 exclusion would be included to allow changes between Modes 5 and 6 when the action does not require a shutdown and would allow indefinite operation in these modes.

These proposed changes are consistent with the guidance in Generic Letter (GL) 87-09 and the latest version of the improved TS (NUREG-1431). Therefore, they are acceptable. In addition, the editorial changes associated with these changes are acceptable.

Change 3: Items 7.b.1 and 7.b.2 of TS Table 3.3-3 would be revised to include Modes 5 and 6 as applicable modes when the associated EDG is required to be operable. In addition, Items 7.b.2 and 7.b.3 would be revised to reflect consistent instrumentation descriptions and the minimum channels operable would be revised to be consistent with the action requirements.

Change 4: Table notation footnotes for TS Table 3.3-3 would be updated to reflect the conditions when the loss-of-power instrumentation is required to be operable in Modes 5 and 6. An exclusion to the provisions of TS 3.0.4 was also proposed.

These changes are similar in nature to Change 1 and Change 2 and for the same reason are acceptable.

Change 5: Action 34 of TS Table 3.3-3 would be revised to provide an interval that has a low probability for requiring an EDG start and that will allow for repairs. Action 34 requires entry into the actions for an inoperable EDG if instrumentation is not restored within this interval.

Presently, Action 34 requires SQN station to enter a 48-hour EDG TS action for one inoperable channel and an 8-hour shutdown board TS action for more than one inoperable channel. Also, existing Action 35, which is being amended in this TS amendment, applies a requirement to enter a 72-hour EDG TS action for one or more inoperable channels. Since Action 34 is more restrictive than the actions associated with the inoperability of the EDG itself, it has been revised to apply the appropriate actions to take for loss-of-power instrumentation inoperability.

The proposed Action 34 allows 6 hours to repair one inoperable channel and 1 hour to repair more than one inoperable channel, after which the associated EDG actions for inoperability must be entered. This action allows sufficient time to make most repairs of failures and takes into account the low probability of an event requiring an EDG start during this time interval. For

one inoperable channel, the loss-of-power instrumentation functions remain fully operable. These actions for the loss-of-power instrumentation, are consistent with the latest version of the improved TS (NUREG-1431) and, therefore, are acceptable.

Change 6: Action 35 of TS Table 3.3-3 would be revised to provide the same basis and time intervals for loss-of-power instrumentation inoperability associated with AFW pump start as are required for load-shedding and EDG start in Action 34. Action 35 requires entry into the actions for an inoperable AFW pump if instrumentation is not restored within this interval.

Proposed Action 35 provides similar changes for the AFW loss-of-power start function as Action 34 described in Change 5 with the exception that the associated AFW pump is declared inoperable instead of the EDG. The loss of load-shed function is not worse than the loss of the associated AFW pump. The present action for the AFW loss-of-power instrumentation allows 48 hours to repair a single inoperable channel; however, no provision exists for maintenance activities to restore the inoperable channels if more than one channel are inoperable. This would require possible unit shutdown and unnecessary entries into TS 3.0.3, and would not be consistent with the actions associated with load-shed functions that utilize the same relays. Therefore, this action is acceptable.

Change 7: Item 6.e of TS Table 3.3-4 would be revised to reflect the design changes and functional unit description change described in Change 1 for Item 6.e of TS 3.3-3. New trip setpoints and allowable values have also been proposed.

Change 8: Item 7.a of TS Table 3.3-4 would be revised to reflect the design changes described in Change 2 for Item 7.a of TS Table 3.3-3. New trip setpoints and allowable values have also been proposed.

Change 9: Item 7.b of TS Table 3.3-4 would be revised to reflect the trip setpoints and allowable values for the design changes to the degraded-voltage instrumentation.

The present design utilizes (1) two undervoltage relays set at 70 percent of nominal voltage to initiate the motor-driven AFW pump start after the EDG has tied to the shutdown board after 1.5 seconds and (2) two additional relays also set at 70 percent of nominal voltage to initiate load-shedding after 5 seconds and start the turbine-driven AFW pump for loss-of-voltage protection. Both sets of relays work on a one-out-of-two logic for actuation. Degraded-voltage protection is provided by three voltage sensors set at 95 percent of nominal voltage in a two-out-of-three logic arrangement that feeds two 5-minute, two 10-second, and two 30-second timers. These timer sets are arranged in a one-out-of-two logic with the 5-minute timers providing EDG start and load-shed initiation, the 10-second timers providing load-shedding if a safety-injection signal is active, and the 30-second timers providing a degraded-voltage annunciation in the main control room. These functions will also operate regardless of the power feed (normal, alternate, or emergency) to the shutdown board.

An additional undervoltage scheme is presently provided on the supply side of the normal-feeder breaker to the 6.9 kv shutdown board. This scheme utilizes three voltage sensors set at 80 percent of nominal voltage in a two-out-of-three logic arrangement and feeds two 0.5-second timers in a one-out-of-two logic scheme. This relaying trips the normal feeder breaker if it is closed.

In the proposed changes for the degraded-voltage scheme, the numbers and the actuation logic for the relays would not be changed; however, interlocks would be added, outputs revised, and the degraded voltage-sensor setpoint would be reduced from 95 percent to approximately 93.5 percent of nominal voltage. The original calculations (95 percent degraded voltage setpoints) did not assume any load diversity factor and, therefore, were very conservative. Degraded voltage relays set at 95 percent may cause spurious plant trips. The licensee has performed new calculations using load diversity factors at the 480 volt shutdown boards. Based on new calculations, new setpoints were calculated to be a 93.5 percent. The staff has reviewed the new calculations and is satisfied that the new proposed setpoints are adequate for supplying all shutdown loads under degraded voltage conditions. For the degraded-voltage sensors, a 6456 volt (93.5 percent) setpoint is assigned with a minimum dropout voltage of 6403.5 volts and a maximum reset voltage of 6626.5 volts. The load-shedding function resulting from a degraded-voltage condition, would be disabled when the EDG is tied to the shutdown board without the normal or alternate feeder connected. The tripping function for the normal and alternate feeder during a degraded-voltage condition would still be generated by the load-shedding instrumentation, but would no longer include the additional trip actuation directly from the degraded voltage relay outputs. In addition, the degraded-voltage electro-pneumatic timers would be converted to electronic type.

The loss-of-voltage relaying on the 6.9 kv shutdown board would be converted from two pairs of undervoltage relays to three solid-state voltage sensors. They would be set at 80 percent of nominal voltage, in a two-out-of-three logic arrangement instead of the previous one-out-of-two logic. These sensors would feed two pairs of electronic timers with each pair using a one-out-of-two logic scheme. The timer would initiate the EDG and motor-driven AFW pump and load-shedding at 1.25 seconds. For loss-of-voltage relaying, a setpoint of 5520 volts (80 percent) or more with an allowable value of 5472 volts or more was assigned to the voltage sensors.

The staff has reviewed the licensee's calculations to determine if at the proposed trip values and allowable values for the undervoltage relay settings adequate voltage can be provided at the terminals of all engineered safety features (ESF) equipment to perform safety functions and time delay would not exceed the maximum time delay that is assumed in the accident analyses in the final safety analysis report (FSAR). The staff has concluded that the proposed trip values and time delays for the undervoltage relays will protect the Class 1E equipment from sustained degraded voltages under accident and other conditions and that the proposed scheme conforms to the Branch Technical Position (BTP) PSB-1. These changes are, therefore, acceptable.

Change 10: Item 10 of TS Table 3.3-5 would be revised to incorporate the functional unit description change described for Item 6.e of TS Table 3.3-3.

This change is editorial in nature and is, therefore, acceptable.

Change 11: Table notation 10 of TS Table 3.3-5 would be clarified to reflect the starting point of the response time measurement for the loss-of-voltage conditions.

The present wording can be misleading because it does not clearly indicate that the time delay for the loss-of-voltage EDG start relays is not applicable to this measurement. The relay time delay is accounted for in the safety analysis that is separate from the EDG start response requirement of 10 seconds or less. This relay time delay is not intended to be included in the EDG response and is verified by the setpoint requirements for the timer. This application of the relay time delay for the loss of voltage is the same consideration given to the degraded-voltage relay time delay in the same note. Therefore, the proposed changes in the note clarifies the intent of the EDG response time test measurement and are acceptable.

Change 12: Item 6.e of TS Table 4.3-2 would be revised to reflect the design changes and functional unit description change described in Change 1 for TS Table 3.3-3. In addition, proposed changes to the applicable surveillance requirements (SRs) have been included.

Change 13: Item 7.a of TS Table 4.3-2 would be revised to reflect the design changes described in Change 2 for Item 7.a of TS Table 3.3-3. The applicable modes for loss-of-voltage instrumentation SRs would be expanded to include Modes 5 and 6 when the associated EDG is required to be operable and the channel check requirements removed.

Change 14: Items 7.b.2 and 7.b.3 of TS Table 4.3-2 would be revised to reflect consistent instrumentation descriptions and Items 7.b.1 and 7.b.2 would be revised to expand the applicable modes as described in Change 3 for Item 7.a of this table. The channel check requirement would be removed for Item 7.b.1.

Change 15: Table notation footnotes for TS Table 4.3-2 would be updated to reflect the conditions under which the loss-of-power instrumentation SRs must be complied with in Modes 5 and 6.

These changes are consistent with the previous changes discussed in Change 1, Change 2, Change 3, and Change 4 and, therefore, are acceptable. The SR changes are acceptable.

Change 16: Bases Section 3/4.7.1.2, "Auxiliary Feedwater System," would be revised to add a statement indicating that the turbine-driven AFW pump continues to be considered operable when only one train of AFW loss-of-power start function is inoperable because both 6.9 kv shutdown board logic trains supply this function.

The revision to the AFW system bases would implement information regarding the impact of one channel of loss-of-power instrumentation on the turbine-driven AFW pump. The turbine-driven AFW pump receives two independent start signals for a loss-of-power condition through the load-shed relaying. Each train of

instrumentation for the associated shutdown boards sends one of these signals. If either instrumentation train is lost, the turbine-driven AFW pump continues to have an independent and redundant train of instrumentation available for start initiation. Therefore, the turbine-driven AFW pump should not be considered inoperable as long as one complete train of loss-of-power instrumentation is available. On this basis, the staff finds the proposed change acceptable.

In a conference call with the NRC staff the licensee clarified the following points:

- (1) The proposed undervoltage relay scheme will relocate the degraded voltage protection from the supply side of the normal feeder to the 6.9 kv shutdown board bus, so that degraded voltage protection will be available regardless of the supply source (normal and alternate). It will support the licensee's use of alternate feeder, which has not been allowed with the present voltage protection design.
- (2) The licensee's calculations for the degraded voltage value has been analyzed down to the 120 volt bus level. The safety-related 120 volt distribution system is powered from the vital inverters, and calculations ensure that the input voltage to the inverters is within the required range when the safety-related boards are at the minimum allowable steady-state operating voltage (i.e., 6400 volts at the 6.9 kv shutdown boards). The voltage to the 120 volt components, powered from motor control center control power transformers (CPTs), has been calculated to ensure that the CPT fuses could carry the starter in-rush current during degraded voltage conditions for the accident time delay limit (11.5 seconds).
- (3) The electrical load management system for alternating current software, used to perform the voltage analysis, had been previously validated by test in accordance with NRC Branch Technical Position PSB-1.
- (4) To control future modification to the bus load, the licensee adheres to Site Standard Practice 9.3, "Plant Modification and Design Change Control," which requires that any loading modification to the plant will be evaluated and the degraded voltage relaying setpoints will be revised, if necessary, to ensure sufficient voltage to all engineered safety features.

4.0 SUMMARY

The proposed changes provide appropriate loss-of-power instrumentation requirements for setpoints, actions, applicable modes, response-time measurements, and surveillance requirements. In addition, proposed changes to the instrumentation logic reflect the new relay design configuration that supports the methodology. The addition of Mode 5 and 6 requirements and deletion of the TS 3.0.4 exclusion for Modes 1 through 4 will enhance the understanding of when loss-of-power instrumentation is required to be operable and when mode changes can be made. The revision to the footnote and bases for the AFW loss-of-power instrumentation implements reasonable criteria for the operability of this instrumentation and AFW pumps based on the system design.

The staff has determined that the proposed changes are consistent with a conservative methodology and are acceptable from the standpoint of nuclear safety. Additionally, the staff has found that the licensee has adequately addressed the concerns raised by the staff and demonstrated that the proposed changes will not involve a significant increase in the probability or consequences of an accident previously evaluated. Therefore, the staff finds the revised setpoints and time delays for the loss-of-power and degraded voltage protection instrumentation acceptable.

5.0 STATE CONSULTATION

In accordance with the Commission's regulations, the Tennessee State official was notified of the proposed issuance of the amendments. The State official had no comments.

6.0 ENVIRONMENTAL CONSIDERATION

The amendments change a requirement with respect to installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20 and to the surveillance requirements. The NRC staff has determined that the amendments involve no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that the amendments involve no significant hazards consideration, and there has been no public comment on such finding (59 FR 4947). Accordingly, the amendments meet the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b) no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendments.

7.0 CONCLUSION

The Commission has concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of the amendments will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributor: Sikhindra K. Mitra

Dated: May 24, 1994

Mr. Oliver D. Kingsley, Jr.
Tennessee Valley Authority

cc:

Mr. Craven Crowell, Chairman
Tennessee Valley Authority
ET 12A
400 West Summit Hill Drive
Knoxville, TN 37902

Mr. W. H. Kennoy, Director
Tennessee Valley Authority
ET 12A
400 West Summit Hill Drive
Knoxville, TN 37902

Mr. Johnny H. Hayes, Director
Tennessee Valley Authority
ET 12A
400 West Summit Hill Drive
Knoxville, TN 37902

Mr. O. J. Zeringue, Sr. Vice President
Nuclear Operations
Tennessee Valley Authority
3B Lookout Place
1101 Market Street
Chattanooga, TN 37402-2801

Dr. Mark O. Medford, Vice President
Technical Support
Tennessee Valley Authority
3B Lookout Place
1101 Market Street
Chattanooga, TN 37402-2801

Mr. D. E. Nunn, Vice President
Nuclear Projects
Tennessee Valley Authority
3B Lookout Place
1101 Market Street
Chattanooga, TN 37402-2801

Site Vice President
Sequoyah Nuclear Plant
Tennessee Valley Authority
P.O. Box 2000
Soddy, Daisy, TN 37379

General Counsel
Tennessee Valley Authority
ET 11H
400 West Summit Hill Drive
Knoxville, TN 37902

SEQUOYAH NUCLEAR PLANT

Mr. B. S. Schofield, Manager
Nuclear Licensing and
Regulatory Affairs
Tennessee Valley Authority
4G Blue Ridge
1101 Market Street
Chattanooga, TN 37402-2801

Mr. Ralph H. Shell
Site Licensing Manager
Sequoyah Nuclear Plant
Tennessee Valley Authority
P.O. Box 2000
Soddy Daisy, TN 37379

Mr. Roger W. Huston
Tennessee Valley Authority
11921 Rockville Pike
Suite 402
Rockville, MD 20852

Regional Administrator
U.S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW., Suite 2900
Atlanta, GA 30323

Mr. William E. Holland
Senior Resident Inspector
Sequoyah Nuclear Plant
U.S. Nuclear Regulatory Commission
2600 Igou Ferry Road
Soddy Daisy, TN 37379

Mr. Michael H. Mobley, Director
Division of Radiological Health
3rd Floor, L and C Annex
401 Church Street
Nashville, TN 37243-1532

County Judge
Hamilton County Courthouse
Chattanooga, TN 37402