

March 29, 1994

Docket No. 50-328

Mr. Oliver D. Kingsley, Jr.  
President, TVA Nuclear and  
Chief Nuclear Officer  
Tennessee Valley Authority  
6A Lookout Place  
1101 Market Street  
Chattanooga, Tennessee 37402-2801

Dear Mr. Kingsley:

SUBJECT: CORRECTION TO AMENDMENT NO. 167 - SEQUOYAH NUCLEAR PLANT UNIT 2  
(TAC NO. M85974)

By letter dated February 10, 1994, the Commission issued Amendment No. 167 to Facility Operating License No. DPR-79 for the Sequoyah Nuclear Plant, Unit 2. The amendment was in response to your application dated March 10, 1993, which was amended by letter dated January 31, 1994.

Following issuance, it was discovered that some information on Table 3.6-2 on page 3/4 6-23 that was unrelated to the amendment was inadvertently changed when the approved change was made. This resulted in the Maximum Isolation Times for the four valves in Section D being changed from 25, 25, 25 and 12 to 2, 2, 2 and 1 respectively. The corrected page is attached. We regret any inconvenience this may have caused.

Sincerely,

Original signed by

David E. LaBarge, Sr. Project Manager  
Project Directorate II-4  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Enclosure:  
Unit 2 Technical Specification  
Page 3/4 6-23

cc w/enclosure:  
See next page

OFC:	PDII-4/LA	PDII-4/PM	PDII-4/D
NAME:	BClayton	DLaBarge	FHebdon
DATE:	3/28/94	3/29/94	3/29/94

DOCUMENT NAME: G:\SQN\85974.COR

310046

9404050111 940329  
PDR ADDCK 05000328  
P PDR

INFO FILE CENTER COPY

DF01 1/2

TABLE 3.6-2 (Continued)  
CONTAINMENT ISOLATION VALVES

<u>VALVE NUMBER</u>	<u>FUNCTION</u>	<u>MAXIMUM ISOLATION TIME (Seconds)</u>
C. PHASE "A" CONTAINMENT VENT ISOLATION (Cont.)		
13. FCV-30-50	Upper Compt Purge Air Exh	4*
14. FCV-30-51	Upper Compt Purge Air Exh	4*
15. FCV-30-52	Upper Compt Purge Air Exh	4*
16. FCV-30-53	Upper Compt Purge Air Exh	4*
17. FCV-30-56	Lower Compt Purge Air Exh	4*
18. FCV-30-57	Lower Compt Purge Air Exh	4*
19. FCV-30-58	Inst Room Purge Air Exh	4*
20. FCV-30-59	Inst Room Purge Air Exh	4*
21. FCV-90-107	Cntmt Bldg LWR Compt Air Mon	5*
22. FCV-90-108	Cntmt Bldg LWR Compt Air Mon	5*
23. FCV-90-109	Cntmt Bldg LWR Compt Air Mon	5*
24. FCV-90-110	Cntmt Bldg LWR Compt Air Mon	5*
25. FCV-90-111	Cntmt Bldg LWR Compt Air Mon	5*
26. FCV-90-113	Cntmt Bldg UPR Compt Air Mon	5*
27. FCV-90-114	Cntmt Bldg UPR Compt Air Mon	5*
28. FCV-90-115	Cntmt Bldg UPR Compt Air Mon	5*
29. FCV-90-116	Cntmt Bldg UPR Compt Air Mon	5*
30. FCV-90-117	Cntmt Bldg UPR Compt Air Mon	5*
D. OTHER		
1. FCV-30-46	Vacuum Relief Isolation Valve	25
2. FCV-30-47	Vacuum Relief Isolation Valve	25
3. FCV-30-48	Vacuum Relief Isolation Valve	25
4. FCV-62-90	Normal Charging Isolation Valve	12

\*Provisions of LCO 3.0.4 are not applicable if valve is secured in its isolated position with power removed and leakage limits of Specification 4.6.1.1.c are satisfied. For purge valves, leakage limits under surveillance Requirement 4.6.1.9.3 must also be satisfied.

#Provisions of LCO 3.0.4 are not applicable if valve is secured in its isolated position with power removed and either FCV-62-73 or FCV-62-74 is maintained operable.

\*\*This valve is required after completion of the associated modification.

7404050120 740329  
PDR ADDCK 05000328  
PDR

3/4 6-23

Amendment No. 29,62,73,90, 167

SEQUOYAH - UNIT 2

Mr. Oliver D. Kingsley, Jr.  
Tennessee Valley Authority

cc:

Mr. Craven Crowell, Chairman  
Tennessee Valley Authority  
ET 12A  
400 West Summit Hill Drive  
Knoxville, TN 37902

Mr. W. H. Kennoy, Director  
Tennessee Valley Authority  
ET 12A  
400 West Summit Hill Drive  
Knoxville, TN 37902

Mr. Johnny H. Hayes, Director  
Tennessee Valley Authority  
ET 12A  
400 West Summit Hill Drive  
Knoxville, TN 37902

Mr. O. J. Zeringue, Sr. Vice President  
Nuclear Operations  
Tennessee Valley Authority  
3B Lookout Place  
1101 Market Street  
Chattanooga, TN 37402-2801

Dr. Mark O. Medford, Vice President  
Technical Support  
Tennessee Valley Authority  
3B Lookout Place  
1101 Market Street  
Chattanooga, TN 37402-2801

Mr. D. E. Nunn, Vice President  
Nuclear Projects  
Tennessee Valley Authority  
3B Lookout Place  
1101 Market Street  
Chattanooga, TN 37402-2801

Site Vice President  
Sequoyah Nuclear Plant  
Tennessee Valley Authority  
P.O. Box 2000  
Soddy, Daisy, TN 37379

General Counsel  
Tennessee Valley Authority  
ET 11H  
400 West Summit Hill Drive  
Knoxville, TN 37902

## SEQUOYAH NUCLEAR PLANT

Mr. B. S. Schofield, Manager  
Nuclear Licensing and  
Regulatory Affairs  
Tennessee Valley Authority  
4G Blue Ridge  
1101 Market Street  
Chattanooga, TN 37402-2801

Mr. Ralph H. Shell  
Site Licensing Manager  
Sequoyah Nuclear Plant  
Tennessee Valley Authority  
P.O. Box 2000  
Soddy Daisy, TN 37379

Mr. Roger W. Huston  
Tennessee Valley Authority  
11921 Rockville Pike  
Suite 402  
Rockville, MD 20852

Regional Administrator  
U.S. Nuclear Regulatory Commission  
Region II  
101 Marietta Street, NW., Suite 2900  
Atlanta, GA 30323

Mr. William E. Holland  
Senior Resident Inspector  
Sequoyah Nuclear Plant  
U.S. Nuclear Regulatory Commission  
2600 Igou Ferry Road  
Soddy Daisy, TN 37379

Mr. Michael H. Mobley, Director  
Division of Radiological Health  
3rd Floor, L and C Annex  
401 Church Street  
Nashville, TN 37243-1532

County Judge  
Hamilton County Courthouse  
Chattanooga, TN 37402

Distribution

Docket File

NRC & Local PDRs

SQL Reading

S. Varga

G. Lainas

F. Hebdon

B. Clayton

D. LaBarge

OGC

ACRS (10)

J. Johnson, RII

M. Lesser, RII

J. Jaudon, RII