

MAR 7 1975

Dockets Nos. 50-250 ✓  
and 50-251

Florida Power & Light Company  
ATTN: Dr. Robert E. Uhrig  
Vice President  
P. O. Box 013100  
Miami, Florida 33101

Gentlemen:

The Commission has filed the enclosed Notice of Proposed Issuance of Amendments to Facility Operating Licenses with the Office of the Federal Register for publication. The proposed amendments would revise provisions in the Technical Specifications relating to:  
(1) reactor coolant radioisotopic analysis, (2) reactor coolant oxygen concentration, (3) surveillance interval definitions, and (4) minimum frequencies for equipment and sampling tests, and are in accordance with your request dated September 19, 1974.

Sincerely,

George Lear, Chief  
Operating Reactors Branch #3  
Division of Reactor Licensing

Enclosure:  
Notice of Proposed Issuance of  
Amendments to Facility Operating  
Licenses

cc: See next page

DISTRIBUTION:  
NRC PDR  
Local PDR  
ORB#3 rdg  
OELD  
OI&E  
NDube  
BJones (w/8 encls)  
RVollmer  
~~SATeets~~ RK Ingram  
JSaltzman (w/o encls)  
~~DJaffe~~ Elliott  
GLear  
SKari (w/o TS)  
WOMiller  
BScharf (15)  
TJCarter  
PCollins

SVarga  
CHEbron  
ACRS (12)  
extra cps  
gray file  
Buchanan  
Abernathy

CP  
(1)

OFFICE >	ORB#3 <i>ni</i>	ORB#3 <i>DL</i>	ORB#3	OELD <i>JS</i>	L:AD/ORS
SURNAME >	<i>RK INGRAM</i> <del>SATeets</del>	Elliott/dg	GLear <i>GL</i>	<i>J.F. SCANTO</i>	KGoller <i>K.G</i>
DATE >	1/31/75	2/3/75	2/3/75	3/3/75	3/4/75

Dr. Robert E. Uhrig

-2-

cc: Jack R. Newman, Esquire  
Lowenstein, Newman, Reis & Axelrad  
1025 Connecticut Avenue, N. W.  
Washington, D. C. 20036

Honorable Ray Goode  
County Manager of Metropolitan  
Dade County  
Miami, Florida 33130

Mr. Ed Maroney  
Bureau of Intergovernmental  
Relations  
725 South Bronough Street  
Tallahassee, Florida 32304

Mrs. Fred T. Suber, Librarian  
Lily Lawrence Row Public Library  
212 N. W. First Avenue  
Homestead, Florida 33030

OFFICE ➤

SURNAME ➤

DATE ➤

UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

MAR 7 1975


Dockets Nos. 50-250  
and 50-251

Florida Power & Light Company  
ATTN: Dr. Robert E. Uhrig  
Vice President  
P. O. Box 013100  
Miami, Florida 33101

Gentlemen:

The Commission has filed the enclosed Notice of Proposed Issuance of Amendments to Facility Operating Licenses with the Office of the Federal Register for publication. The proposed amendments would revise provisions in the Technical Specifications relating to: (1) reactor coolant radioisotopic analysis, (2) reactor coolant oxygen concentration, (3) surveillance interval definitions, and (4) minimum frequencies for equipment and sampling tests, and are in accordance with your request dated September 19, 1974.

Sincerely,



George Lear, Chief  
Operating Reactors Branch #3  
Division of Reactor Licensing

Enclosure:  
Notice of Proposed Issuance of  
Amendments to Facility Operating  
Licenses

cc: See next page



Dr. Robert E. Uhrig

-2-

cc: Jack R. Newman, Esquire  
Lowenstein, Newman, Reis & Axelrad  
1025 Connecticut Avenue, N. W.  
Washington, D. C. 20036

Honorable Ray Goode  
County Manager of Metropolitan  
Dade County  
Miami, Florida 33130

Mr. Ed Maroney  
Bureau of Intergovernmental  
Relations  
725 South Bronough Street  
Tallahassee, Florida 32304

Mrs. Fred T. Suber, Librarian  
Lily Lawrence Row Public Library  
212 N. W. First Avenue  
Homestead, Florida 33030

UNITED STATES NUCLEAR REGULATORY COMMISSION

DOCKETS NOS. 50-250 AND 50-251

FLORIDA POWER AND LIGHT COMPANY

NOTICE OF PROPOSED ISSUANCE OF AMENDMENTS  
TO FACILITY OPERATING LICENSES

The Nuclear Regulatory Commission (the Commission) is considering issuance of amendments to Facility Operating Licenses Nos. DPR-31 and DPR-41 issued to Florida Power and Light Company (the licensee) for operation of the Turkey Point Nuclear Generating Units 3 and 4 located in Dade County, Florida.

The license amendments under consideration would revise the provisions in the Technical Specifications in accordance with the licensee's application for amendments dated September 19, 1974, to: (1) relax the requirement for performing reactor coolant radioisotope determinations; (2) remove the restriction on reactor coolant oxygen concentration when the reactor coolant is below 250°F; (3) redefine surveillance intervals so that they are applicable to all surveillance tests; and (4) make several changes to Technical Specification Table 4.1-2 "Minimum Frequencies for Equipment and Sampling Tests," to maintain consistency with the above proposed changes or to clarify explanatory statements.

Prior to issuance of the proposed license amendments, the Commission will have made the findings required by the Atomic Energy Act of 1954, as amended, and the Commission's rules and regulations.

Within thirty days from the date of publication of this notice in the FEDERAL REGISTER, any person whose interest may be affected by the proceeding may file a request for a hearing in the form of a petition for leave to intervene with respect to the issuance of the amendments to the subject

facility operating licenses. Petitions for leave to intervene must be filed under oath or affirmation in accordance with the provisions of Section 2.714 of 10 CFR Part 2 of the Commission's regulations. A petition for leave to intervene must set forth the interest of the petitioner in the proceeding, how that interest may be affected by the results of the proceeding, and the petitioner's contentions with respect to the proposed licensing action. Such petitions must be filed in accordance with the provisions of this FEDERAL REGISTER notice and Section 2.714, and must be filed with the Secretary of the Commission, U. S. Nuclear Regulatory Commission, Washington D. C. 20555, Attention: Docketing and Service Section, by April 14, 1975. A copy of the petition and/or request for a hearing should be sent to the Chief Hearing Counsel, Office of the Executive Legal Director, U. S. Nuclear Regulatory Commission, Washington, D. C. 20555, and to Jack R. Newman, Esquire, Lowenstein, Newman, Reis and Axelrad, 1025 Connecticut Avenue, N. W., Washington, D. C. 20036, attorney for the licensee.

A petition for leave to intervene must be accompanied by a supporting affidavit which identifies the specific aspect or aspects of the proceeding as to which intervention is desired and specifies with particularity the facts on which the petitioner relies as to both his interest and his contentions with regard to each aspect on which intervention is requested. Petitions stating contentions relating only to matters outside the Commission's jurisdiction will be denied.

All petitions will be acted upon by the Commission or an Atomic Safety and Licensing Board designated by the Commission or by the Chairman of the Atomic Safety and Licensing Board Panel. Timely petitions will be considered to determine whether a hearing should


be noticed or another appropriate order issued regarding the disposition of the petitions.

In the event that a hearing is held and a person is permitted to intervene, he becomes a party to the proceeding and has a right to participate fully in the conduct of the hearing. For example, he may present evidence and examine and cross-examine witnesses.

For further details with respect to this action, see the application for amendments dated September 19, 1974, which is available for public inspection at the Commission's Public Document Room, 1717 H Street, N. W., Washington, D. C. and at the Lily Lawrence Row Public Library, 212 N. W. First Avenue, Homestead, Florida. As they become available, the Commission's related Safety Evaluation, license amendments and attachments may be inspected at the above locations. A copy of the license amendments and attachments and the Safety Evaluation, when available, may be obtained upon request addressed to the U. S. Nuclear Regulatory Commission, Washington, D. C. 20555, Attention: Director, Division of Reactor Licensing.

Dated at Bethesda, Maryland, this 5<sup>th</sup> day of March 1975.

FOR THE NUCLEAR REGULATORY COMMISSION

  
George Lear, Chief  
Operating Reactors Branch #3  
Division of Reactor Licensing