

OCT 2 4 1975

Docket Nos: 50-250
and 50-251

Florida Power and Light Company
ATTN: Dr. Robert E. Uhrig
Vice President
P. O. Box 013100
Miami, Florida 33101

- DISTRIBUTION:
- Docket (2)
 - NRC PDR (2)
 - Local PDR
 - ORB-3 Reading
 - Attorney, OELD
 - OI&E (3)
 - KR Goller
 - TJCarter
 - JMcGough
 - Glear
 - DElliott
 - CParrish
 - DEisenhut
 - SVarga
 - ACRS (16)
 - CMiles
 - TBAbernathy, DTIE

Gentlemen:

The Commission has requested the Office of the Federal Register to publish the enclosed Notice of Proposed Issuance of Amendments to the Facility Operating Licenses for Turkey Point Nuclear Generating Units 3 and 4. The proposed amendments would revise the Technical Specifications to modify the operating limits to allow operation of Turkey Point Unit 3, following refueling, at 2100 psia until the extended fuel residence time is reached. The operating limits for Unit 4 set forth in its Technical Specifications will remain unchanged although the Technical Specifications will be modified to reflect the revision of the Unit 3 Technical Specifications.

The action proposed is in accordance with your application for amendments dated September 9, 1975.

Sincerely,

151

George Lear, Chief
Operating Reactors Branch #3
Division of Reactor Licensing

Enclosure:
Federal Register Notice

cc w/encl:
See next page

[Handwritten signature] *Corstl*

OFFICE →	RL:ORB-3	RL:ORB-3 <i>DE</i>	OELD <i>DE</i>	RL:ORB-3		
x7872 SURNAME →	CParrish <i>ep</i>	DElliott	LA. STRIDIRON	Glear <i>for WLP</i>		
DATE →	9/29/75	9/29/75	10/20/75	10/2/75		

Florida Power & Light Company - -

cc:

Mr. Jack R. Newman, Esquire
Lowenstein, Newman, Reis & Axelrad
1025 Connecticut Avenue, N. W.
Suite 1214
Washington, D. C. 20036

Environmental & Urban Affairs Library
Florida International University
Miami, Florida 33199

Mr. Ed Maroney
Bureau of Intergovernmental Relations
725 South Bronough Street
Tallahassee, Florida 32304