

AUG 5 1975

Distribution:

Docket
ORB#3
NRC PDR
Local PDR
OI&E (3)
BJones (4)
JMcGough
DMElliott
RIngram

Dockets Nos. 50-250/251

Florida Power and Light Company
ATTN: Dr. Robert E. Uhrig
Vice President
P. O. Box 013100
Miami, Florida 33101

Gentlemen:

On June 5, 1975, the Commission issued Amendment No. 9 to Facility Operating License No. DPR-31 and Amendment No. 8 to Facility Operating License No. DPR-41 with Change No. 21 to the Technical Specifications for the Turkey Point Nuclear Generating Units 3/4. Revised page 2.3-3 was, however, inadvertently omitted from this change although it was considered at the time of the issuance.

Please replace page 2.3-3 of the Technical Specifications with the enclosed revised page.

Sincerely,

George Lear, Chief
Operating Reactors Branch #3
Division of Reactor Licensing

Enclosure:
Page 2.3-3

cc: See next page

C/P
1

| | | | | | | |
|-----------|------------|----------|--|--|--|--|
| OFFICE > | ORB#3 | ORB#3 | | | | |
| SURNAME > | RIngram/dg | GLear | | | | |
| DATE > | 8/ 8 /75 | 8/ 8 /75 | | | | |

Florida Power & Light Company

cc: w/enclosure

Jack R. Newman, Esquire
Lowenstein, Newman, Reis & Axelrad
1025 Connecticut Avenue, N. W.
Suite 1214
Washington, D. C. 20036

Mr. Ed Maroney
Bureau of Intergovernmental Relations
725 South Bronough Street
Tallahassee, Florida 32304

Honorable Ray Goode
County Manager of Metropolitan
Dade County
Miami, Florida 33130

Mr. Dave Hopkins
Environmental Protection Agency
Region IV Office
1421 Peachtree Street, N. E.
Atlanta, Georgia 30309

Environmental & Urban Affairs Library
Florida International University
Miami, Florida 33199

$$\text{Overpower } \Delta T \leq \Delta T_0 \left[1.09 - K_1 \frac{dT}{dt} - K_2 (T - T') - f(\Delta I) \right]$$

ΔT_0 = Indicated ΔT at rated power, F

T = Average temperature, F

T' = Indicated average temperature at nominal conditions and rated power, F

K_1 = 0 for decreasing average temperature,
0.2 sec./F for increasing average temperature

K_2 = 0.00134 for T equal to or more than T' ;
0 for T less than T'

$\frac{dT}{dt}$ = Rate of change of temperature, F/sec

$f(\Delta I)$ = As defined above

Pressurizer

Low Pressurizer pressure - equal to or greater than 1715 psig.

High Pressurizer pressure - equal to or less than 2385 psig.

High Pressurizer water level - equal to or less than 92% of full scale.

Reactor Coolant Flow

Low reactor coolant flow - equal to or greater than 90% of normal indicated flow

Low reactor coolant pump motor frequency - equal to or greater than 56.1 Hz

Under voltage on reactor coolant pump motor bus - equal to or greater than 60% of normal voltage

Steam Generators

Low-low steam generator water level - equal to or greater than 5% of narrow range instrument scale