NRC FORM 658		U.S. NUCLEAR REGULATORY COMMISSION						
	TRANSMITTAL OF ME IMMEDIATE PLACE	ETING HANDOUT MATERIALS FOR EMENT IN THE PUBLIC DOMAIN						
This form is to person who iss materials, will t circumstances Do not includ e	be filled out (typed or hand-print sued the meeting notice). The c be sent to the Document Control will this be done later than the v e proprietary materials.	ted) by the person who announced the meeting (i.e., the ompleted form, and the attached copy of meeting handout I Desk on the same day of the meeting; under no working day after the meeting.						
DATE OF MEETING 11/28/2001	The attached document(s), w in the public domain as soon near future. Following are ad	hich was/were handed out in this meeting, is/are to be placed as possible. The minutes of the meeting will be issued in the Iministrative details regarding this meeting:						
	Docket Number(s)	50-346						
	Plant/Facility Name	DAVIS-BESSE						
	TAC Number(s) (if available)	MB 2626						
	Reference Meeting Notice	ADAMS NO. ML013310537						
	Purpose of Meeting (copy from meeting notice)	To discuss information related to supplemental						
		information regardind inspection plans and						
		commitments for Davis-Besse in response to Bulletin 2001-01						
NAME OF PERSON WH	O ISSUED MEETING NOTICE	PROJECT MANAGER						
OFFICE NRR								
DIVISION								
DLPM								
BRANCH PD III-2								
Distribution of this Docket File/Centra PUBLIC	a form and attachments: al File	Dton						

Agenda

$\dot{\Sigma}$	Introduction/Background	Stev
\$	Deterministic Model	Dav
公	Probabilistic Risk Assessment	Ken
\$	Inspection Plans	Mar
\$	Closing Summary	Stev

Steve Moffitt

Dave Geisen

Ken Byrd

Mark McLaughlin

Steve Moffitt





Today's Objective

Provide Reasonable Assurance that Davis-Besse is safe to operate until February 16, 2002.

ាំង ហោយត្រាមស្រុក ដែល





Background:

- ☆ NRC Bulletin 2001-01 response provided
- ☆ Telephone call received on September 28
- ☆ Teleconference on October 3
- ☆ Brief drop by visit on October 11
- ☆ Meeting with NRR Staff on October 24
- ☆ NRR Staff and ACRS meetings on November 8 & 9

- ☆ Meeting with NRR Staff on November 13
- ☆ Teleconference on November 26





Deterministic Aspects

DBNPS's evaluation is based on visual inspections performed in 10, 11, and 12 RFO (May 1996, April 1998, and April 2000).

The inspection results afford us assurance that all but 4 nozzle penetrations were inspected in 1996, all but 19 inspected in 1998, and all but 24 penetrations inspected in 2000.

The limiting nozzle population is those nozzles that could not be inspected in 1998 or 2000.

It is conservatively assumed that for these penetrations, an axial through-weld flaw occurs immediately upon startup from 10 RFO (May 1996).





Initial Flaw Size

Initial flaw depth of 0.5 mm, 172° around the nozzle, is assumed to exist immediately upon achieving a full penetration axial flaw.

BASIS:

 $rac{1}{2}$ This is a conservative flaw initiation site size.

 $rac{1}{3}$ It is further conservatively assumed that multiple starting flaws could exist and that these would eventually link together.

It is conservative in that by assuming this starting point, we also are assuming that we have already had several years of flaw propagation axially through the Alloy 182 weld material.





Use of Modified Scott Model

The Modified Scott Model is still deemed credible as a mean curve for crack growth rates.

 \Rightarrow Data received to date does not negate the curve.

☆ Numerous curves have been developed and to a certain degree, they all rest on engineering judgement.

☆ The data from OTSGs for Alloy 600 is relevant for developing the CGR curves and in fact is conservative in that the Alloy properties are still relevant and because any cold-working of the tubes at the tube support sheet would increase the failure rate over non-worked Alloy 600, will make this conservative.





Risk-Informed Evaluation

☆ Davis-Besse risk assessment provides a bounding estimation of risk. Bounding or conservative assumptions were used to resolve uncertainties.

Studies of sensitivity was performed for all significant parameters.

☆ Results indicate incremental CDF would be bounded in the "small" category and expected to be "very small" per RG 1.174.

☆ Incremental LERF and Public health risk is expected to be negligible.





Risk-Informed Evaluation Nozzle Leak Frequency

The Davis-Besse plant specific PSA has used the method from the generic Framatome analysis which applies a constant leak initiation frequency.

The constant rate over predicts the number of leaks in early cycles.

☆ Impact of inspection on conditional probability of a leak at a future date is not quantified.





Risk-Informed Evaluation Nozzle Leak Frequency

Other approaches have assumed that the onset of leakage can be approximated by a two parameter Weibull cumulate probability distribution.

☆The Davis-Besse risk assessment was modified to apply a Weibull distribution.

☆Studies were performed to investigate the sensitivity to the Weibull scale and shape parameters.

☆The conditional probability of a leak by a future date given no leak now can be calculated if a nozzle has been inspected and no leakage detected.





Risk-Informed Evaluation Nozzle Leak Frequency

Predicted Leaks for various Weibull Leak Initiation Models

			Expected Number of Leaking CRDM Nozzles								
Davis- Besse Refueling Outage	Davis- Davis- BesseUpper (95%)BesseEFPY(95%)EFPYCorrected to 600FProjection 1.5 Shape Parameter		Upper (95%) Projection 1.5 Shape Parameter	Median Projection 1.5 Shape Parameter	EPRI MRP Weibull Model Projection	EPRI MRP Shape Parameter Modified Scale Parameter					
10	10.56	12.91	5.0	1.0	9.5×10^{-5}	0.02					
11	12.33	15.07	6.3	1.3	1.7×10^{-3}	0.36					
12	14.06	17.18	7.6	1.6	1.9×10^{-2}	4.00					
13	15.81	19.32	8.9	1.9	0.17	28.3					
_	16.37	20.00	9.3	2.0	0.32	43.7					





Risk-Informed Evaluation Past Inspections

☆ Inspections were assumed to have a failure probability of 1.00 if boron inhibited detection of nozzle leakage.

 $rac{1}{2}$ Inspections were assumed to have a failure probability of 0.05 if no boron was present.

Sensitivities were performed to investigate the effect of various leakage detection probabilities.





Risk-Informed Evaluation Probability of Circumferential Cracking

☆ Evidence from recent B&W plant inspections has indicated that not all axial cracks have resulted in initiation of circumferential cracking.

☆ B&W plants have experienced 27 axial cracks and 6 circumferential cracks.

☆ Probability of the initiation of a circumferential crack is estimated to be 0.22 based on B&W evidence.





Risk-Informed Evaluation Nozzle Failure Probability

☆ Probability of CRDM nozzle failure is determined by performing a Monte Carlo simulation on the Scott deterministic crack growth model.

☆ Conservative or bounding assumptions were used when data was not available.

13

Studies were performed to investigate the sensitivity to all significant inputs.





Risk-Informed Evaluation

Nozzle Failure Probability - Conservative Assumptions

☆ Initial crack size - Applied a uniform distribution from 0-180 degrees.

 $rac{1}{2}$ Stress Profile - Uses the worst case stresses.

☆ Crack Growth Rate Coefficient - Applies crack growth rate coefficient from heat 69.





Risk-Informed Evaluation Nozzle Failure Probability - Sensitivity Studies

- ☆ Initial crack size
- ☆ Initial crack depth
- ☆ Temperature
- Stress Profile
- ☆ Crack Growth Rate Coefficient





Risk-Informed Evaluation

Conditional Core Damage / Release Probability

☆ Davis-Besse conditional core damage probability for a 0.1 ft² medium LOCA is 2.7 x 10⁻³.

☆ Conditional large early release probability for a medium LOCA is about 4.0×10^{-6} .

☆ The conditional core damage probability for this analysis is less than applied in the PSA because the medium LOCA range in the PSA is 0.02 ft² - 0.5 ft².





Risk-Informed Evaluation Results

.

	Constant Frequ	Initiation uency	Upper Proje 1.5 S Para	(95%) ection hape meter	EPRI MRP Shape Parameter Modified Scale Parameter		
	Bounding	Best Estimate	Bounding	Best Estimate	Bounding	Best Estimate	
CDF	1.8 E-6	9.9 E-8	1.1 E-6	6.3 E-8	3.3 E-7	1.9 E-8	
LERF	2.6 E-9	1.5 E-10	1.7 E-9	9.4 E-11	4.9 E-10	2.8 E-11	
Person REM	0.16	9.2 E-3	.11	5.9 E-3	3.1 E-2	1.7 E-3	





Risk-Informed Evaluation

Unique Aspects of Davis-Besse Risk Assessment

☆ Inspection Information - Davis-Besse inspections do not indicate evidence a nozzle leaks.

Attended to the second second





Risk-Informed Evaluation Conclusions

rightarrow CDF - The plant specific risk assessment conservatively estimates a bounding incremental core damage frequency to be in the range which is categorized as "small" per RG 1.174. The actual incremental core damage frequency would be categorized as "very small" per RG 1.174.

☆ <u>LERF</u> - The plant specific risk assessment conservatively estimates a bounding incremental large early release frequency which is categorized as "very small" per RG 1.174. The actual incremental release frequency is negligible.

☆ <u>Public Health Risk</u> - The plant specific risk person rem per year is negligible.





Inspection Plans

☆ 13RFO:

☆ 100% qualified visual

☆ 100% NDE

☆ Flaw characterization if found.

 $rac{1}{3}$ Data will be made available for industry use.

☆ Vessel Head Replacement at first available opportunity

The second second





Davis-Besse Specific Features and Actions

 \Im Record of inspection from last three outages.

STREET BREAK

☆Only B&W plant with a continuous head vent which provides high confidence in temperature measurements.

☆Reduce reactor vessel head temperature from 605°F to 598°F.

21

☆Additional training for Operators on issues raised in Bulletin 2001-01.

☆Maximize availability of redundant critical safety systems.





Comparison of Inspection Dates

December 31st

- Two Shutdowns Required

(One Inspection, One Refuel)

- Approximately 30 REM additional exposure to employees.
- Limited NDE

February 16th

- Single Shutdown for inspection and refueling.
- Normal refueling outage dose.
- Full NDE and flaw characterization.

No significant difference in risk (incremental CDF).





Summary

Based on Conservative Analysis:

Davis-Besse is Safe to Operate until February 16, 2002.

23

ាម ប្រាស់ ត្រាប់ ស





Heat 69 Crack Growth - Constant Leak Initiation Frequency

Leak	Initiation	CRDM	Initiation	Nozzie		Probability	10 RFO	11 RFO	12 RFO	CDF	LERF	REM
Initiates	Frequency	in	Frequency	Failure	CCDP	Circ Crack	Insp.	Insp.	Insp.	(yr)	(yr)	(yr)
	(yr)	Group	(yr)	Probability			Fails	Fails	Fails			
13	1.1	4	6.38E-02	1.25E-05	2.70E-03	2.22E-01	NA	NA	NA	4.78E-10	7.08E-13	4.44E-05
12	1.1	4	6.38E-02	1.25E-05	2.70E-03	2.22E-01	NA	NA	1	4.78E-10	7.08E-13	4.44E-05
11	1.1	4	6.38E-02	9.65E-03	2.70E-03	2.22E-01	NA	1	1	3.69E-07	5.46E-10	3.43E-02
10	1.1	4	6.38E-02	4.43E-02	2.70E-03	2.22E-01	1	1	1	1.69E-06	2.51E-09	1.57E-01
										2.06E-06	3.05E-09	1.92E-01
13	1.1	15	2.39E-01	1.25E-05	2.70E-03	2.22E-01	NA	NA	NA	1.79E-09	2.65E-12	1.67E-04
12	1.1	15	2.39E-01	1.25E-05	2.70E-03	2.22E-01	NA	NA	1	1.79E-09	2.65E-12	1.67E-04
11	1.1	15	2.39E-01	9.65E-03	2.70E-03	2.22E-01	NA	1	1	1.38E-06	2.05E-09	1.29E-01
10	1.1	15	2.39E-01	4.43E-02	2.70E-03	2.22E-01	0.05	1	1	3.17E-07	4.70E-10	2.95E-02
										1.70E-06	2.52E-09	1.58E-01
13	1.1	5	7.97E-02	1.25E-05	2.70E-03	2.22E-01	NA	NA	NA	5.97E-10	8.85E-13	5.55E-05
12	1.1	5	7.97E-02	1.25E-05	2.70E-03	2.22E-01	NA	NA	1	5.97E-10	8.85E-13	5.55E-05
11	1.1	5	7.97E-02	9.65E-03	2.70E-03	2.22E-01	NA	0.05	1	2.31E-08	3.42E-11	2.14E-03
10	1.1	5	7.97E-02	4.43E-02	2.70E-03	2.22E-01	0.05	0.05	1	5.29E-09	7.83E-12	4.91E-04
										2.95E-08	4.38E-11	2.75E-03
13	1.1	45	7.17E-01	1.25E-05	2.70E-03	2.22E-01	NA	NA	NA	5.38E-09	7.96E-12	5.00E-04
12	1.1	45	7.17E-01	1.25E-05	2.70E-03	2.22E-01	NA	NA	0.05	2.69E-10	3.98E-13	2.50E-05
11	1.1	45	7.17E-01	9.65E-03	2.70E-03	2.22E-01	NA	0.05	0.05	1.04E-08	1.54E-11	9.64E-04
10	1.1	45	7.17E-01	4.43E-02	2.70E-03	2.22E-01	0.05	0.05	0.05	2.38E-09	3.52E-12	2.21E-04
										1.84E-08	2.73E-11	1.71E-03
										1.75E-06	2.60E-09	1.63E-01
TTM	·······					, I		l				





Heat 69 Crack Growth - Low Weibull Shape Factor

Leak	Initiation	CRDM	Initiation	Nozzle]	Probability	10 RFO	11 RFO	12 RFO	CDF	LERF	REM
Initiates	Frequency	in	Frequency	Failure	CCDP	Circ Crack	Insp.	Insp.	Insp.	(vr)	(vr)	(vr)
	(yr)	Group	(yr)	Probability			Fails	Fails	Fails	,		
13	4.39E-03	4	8.79E-03	1.25E-05	2.70E-03	2.20E-01	NA	NA	NA	6.53E-11	9.67E-14	6.07E-06
12	4.10E-03	4	8.19E-03	1.25E-05	2.70E-03	2.20E-01	NA	NA	1	6.08E-11	9.01E-14	5.66E-06
11	3.92E-03	4	7.84E-03	9.65E-03	2.70E-03	2.20E-01	NA	1	1	4.49E-08	6.66E-11	4.18E-03
10	1.51E-02	4	3.03E-02	4.43E-02	2.70E-03	2.20E-01	1	1	1	7.96E-07	1.18E-09	7.40E-02
										8.41E-07	1.25E-09	7.82E-02
13	4.50E-03	15	3.37E-02	1.25E-05	2.70E-03	2.20E-01	NA	NA	NA	2.51E-10	3.71E-13	2.33E-05
12	4.18E-03	15	3.13E-02	1.25E-05	2.70E-03	2.20E-01	NA	NA	1	2.33E-10	3.45E-13	2.16E-05
11	3.98E-03	15	2.99E-02	9.65E-03	2.70E-03	2.20E-01	NA	1	1	1.71E-07	2.53E-10	1.59E-02
10	1.51E-02	15	1.14E-01	4.43E-02	2.70E-03	2.20E-01	0.05	1	1	1.49E-07	2.21E-10	1.39E-02
										3.21E-07	4.75E-10	2.98E-02
13	4.50E-03	5	1.12E-02	1.25E-05	2.70E-03	2.20E-01	NA	NA	NA	8.35E-11	1.24E-13	7.76E-06
12	4.18E-03	5	1.04E-02	1.25E-05	2.70E-03	2.20E-01	NA	NA	1	7.75E-11	1.15E-13	7.21E-06
11	3.98E-03	5	9.95E-03	9.65E-03	2.70E-03	2.20E-01	NA	0.05	1	2.85E-09	4.22E-12	2.65E-04
10	1.51E-02	5	3.79E-02	4.43E-02	2.70E-03	2.20E-01	0.05	0.05	1	2.49E-09	3.69E-12	2.31E-04
										5.50E-09	8.15E-12	5.11E-04
13	4.50E-03	45	1.01E-01	1.25E-05	2.70E-03	2.20E-01	NA	NA	NA	7.52E-10	1.11E-12	6.99E-05
12	4.18E-03	45	9.40E-02	1.25E-05	2.70E-03	2.20E-01	NA	NA	0.05	3.49E-11	5.17E-14	3.24E-06
11	3.98E-03	45	8.96E-02	9.65E-03	2.70E-03	2.20E-01	NA	0.05	0.05	1.28E-09	1.90E-12	1.19E-04
10	1.51E-02	45	3.41E-01	4.43E-02	2.70E-03	2.20E-01	0.05	0.05	0.05	1.12E-09	1.66E-12	1.04E-04
										3.19E-09	4.73E-12	2.97E-04
										1.13E-06	1.67E-09	1.05E-01
12 11 10	4.18E-03 3.98E-03 1.51E-02	45 45 45	9.40E-02 8.96E-02 3.41E-01	1.25E-05 9.65E-03 4.43E-02	2.70E-03 2.70E-03 2.70E-03	2.20E-01 2.20E-01 2.20E-01	NA NA 0.05	NA 0.05 0.05	0.05 0.05 0.05	3.49E-11 1.28E-09 1.12E-09 3.19E-09 1.13E-06	5.17E-14 1.90E-12 1.66E-12 4.73E-12 1.67E-09	3.24E- 1.19E- 1.04E- 2.97E- 1.05E-

OPERAL



Heat 69 Crack Growth - High Weibull Shape Factor

Initiation	CRDM	Initiation	Nozzle		Probability	10 RFO	11 RFO	12 RFO	CDF	LERF	REM
Frequency	in	Frequency	Failure	CCDP	Circ Crack	insp.	Insp.	Insp.	(yr)	(yr)	(yr)
(yr)	Group	(yr)	Probability			Fails	Fails	Fails			L
3.52E-01	4	7.03E-01	1.25E-05	2.70E-03	2.20E-01	NA	NA	NA	5.22E-09	7.73E-12	4.85E-04
5.30E-02	4	1.06E-01	1.25E-05	2.70E-03	2.20E-01	NA	NA	1	7.86E-10	1.17E-12	7.31E-05
4.97E-03	4	9.94E-03	9.65E-03	2.70E-03	2.20E-01	NA	1	1	5.70E-08	8.44E-11	5.30E-03
3.00E-04	4	6.01E-04	4.43E-02	2.70E-03	2.20E-01	1	1	1	1.58E-08	2.34E-11	1.47E-03
									7.88E-08	1.17E-10	7.32E-03
3.73E-01	15	2.80E+00	1.25E-05	2.70E-03	2.20E-01	NA	NA	NA	2.08E-08	3.08E-11	1.93E-03
5.32E-02	15	3.99E-01	1.25E-05	2.70E-03	2.20E-01	NA	NA	1	2.96E-09	4.39E-12	2.76E-04
4.97E-03	15	3.73E-02	9.65E-03	2.70E-03	2.20E-01	NA	1	1	2.14E-07	3.17E-10	1.99E-02
3.00E-04	15	2.25E-03	4.43E-02	2.70E-03	2.20E-01	0.05	1	1	2.96E-09	4.39E-12	2.75E-04
									2.40E-07	3.56E-10	2.23E-02
3.73E-01	5	9.33E-01	1.25E-05	2.70E-03	2.20E-01	NA	NA	NA	6.93E-09	1.03E-11	6.44E-04
5.32E-02	5	1.33E-01	1.25E-05	2.70E-03	2.20E-01	NA	NA	1	9.88E-10	1.46E-12	9.19E-05
4.97E-03	5	1.24E-02	9.65E-03	2.70E-03	2.20E-01	NA	0.05	1	3.56E-09	5.28E-12	3.31E-04
3.00E-04	5	7.51E-04	4.43E-02	2.70E-03	2.20E-01	0.05	0.05	1	4.93E-11	7.31E-14	4.59E-06
									1.15E-08	1.71E-11	1.07E-03
3.73E-01	45	8.40E+00	1.25E-05	2.70E-03	2.20E-01	NA	NA	NA	6.24E-08	9.24E-11	5.80E-03
5.32E-02	45	1.20E+00	1.25E-05	2.70E-03	2.20E-01	NA	NA	0.05	4.45E-10	6.59E-13	4.13E-05
4.97E-03	45	1.12E-01	9.65E-03	2.70E-03	2.20E-01	NA	0.05	0.05	1.60E-09	2.37E-12	1.49E-04
3.00E-04	45	6.76E-03	4.43E-02	2.70E-03	2.20E-01	0.05	0.05	0.05	2.22E-11	3.29E-14	2.06E-06
									6.44E-08	9.55E-11	5.99E-03
									3.32E-07	4.92E-10	3.09E-02
	Initiation Frequency (yr) 3.52E-01 5.30E-02 4.97E-03 3.00E-04 3.73E-01 5.32E-02 4.97E-03 3.00E-04 5.32E-02 4.97E-03 3.00E-04 3.73E-01 5.32E-02 4.97E-03 3.00E-04	Initiation Frequency (yr) CRDM Group 3.52E-01 4 5.30E-02 4 4.97E-03 4 3.00E-04 4 3.00E-04 4 3.00E-04 4 3.73E-01 15 5.32E-02 15 4.97E-03 15 3.00E-04 15 3.00E-04 15 3.00E-04 15 3.00E-04 5 3.00E-04 5 3.73E-01 5 3.00E-04 5 3.00E-04 5 3.00E-04 5 3.73E-01 45 3.00E-04 45 3.00E-04 45 3.00E-04 45	Initiation CRDM in Initiation Frequency (yr) Group (yr) 3.52E-01 4 7.03E-01 5.30E-02 4 1.06E-01 4.97E-03 4 9.94E-03 3.00E-04 4 6.01E-04 3.00E-04 4 6.01E-04 3.00E-04 4 6.01E-04 3.73E-01 15 2.80E+00 5.32E-02 15 3.99E-01 4.97E-03 15 3.73E-02 3.00E-04 15 2.25E-03 3.00E-04 15 2.25E-03 3.73E-01 5 9.33E-01 5.32E-02 5 1.33E-01 4.97E-03 5 1.24E-02 3.00E-04 5 7.51E-04 4.97E-03 45 1.20E+00 5.32E-02 45 1.20E+00 3.73E-01 45 8.40E+00 5.32E-02 45 1.20E+00 4.97E-03 45 6.76E-03 3.00E-04	Initiation Frequency (yr) CRDM Group Initiation Frequency (yr) Nozzle Failure Probability 3.52E-01 4 7.03E-01 1.25E-05 5.30E-02 4 1.06E-01 1.25E-05 5.30E-02 4 9.94E-03 9.65E-03 4.97E-03 4 9.94E-03 9.65E-03 3.00E-04 4 6.01E-04 4.43E-02 3.00E-04 4 6.01E-04 4.43E-02 3.73E-01 15 2.80E+00 1.25E-05 5.32E-02 15 3.99E-01 1.25E-05 4.97E-03 15 3.73E-02 9.65E-03 3.00E-04 15 2.25E-03 4.43E-02 3.00E-04 15 2.25E-03 4.43E-02 3.73E-01 5 1.33E-01 1.25E-05 5.32E-02 5 1.33E-01 1.25E-05 3.00E-04 5 7.51E-04 4.43E-02 3.00E-04 5 7.51E-04 4.43E-02 3.73E-01 45 8.40E+00 1.25E-05 <	Initiation Frequency CRDM in Initiation Frequency Nozzle Failure Probability CCDP 3.52E-01 4 7.03E-01 1.25E-05 2.70E-03 5.30E-02 4 1.06E-01 1.25E-05 2.70E-03 4.97E-03 4 9.94E-03 9.65E-03 2.70E-03 3.00E-04 4 6.01E-04 4.43E-02 2.70E-03 3.00E-04 4 6.01E-04 4.43E-02 2.70E-03 3.00E-04 4 6.01E-04 4.43E-02 2.70E-03 3.73E-01 15 2.80E+00 1.25E-05 2.70E-03 5.32E-02 15 3.99E-01 1.25E-05 2.70E-03 4.97E-03 15 3.73E-02 9.65E-03 2.70E-03 3.00E-04 15 2.25E-03 4.43E-02 2.70E-03 3.00E-04 15 9.33E-01 1.25E-05 2.70E-03 3.73E-01 5 9.33E-01 1.25E-05 2.70E-03 3.00E-04 5 7.51E-04 4.43E-02 2.70E-03 <tr< td=""><td>Initiation Frequency (yr) CRDM Group Initiation Frequency (yr) Nozzle Failure Probability Probability CCDP 3.52E-01 4 7.03E-01 1.25E-05 2.70E-03 2.20E-01 5.30E-02 4 1.06E-01 1.25E-05 2.70E-03 2.20E-01 4.97E-03 4 9.94E-03 9.65E-03 2.70E-03 2.20E-01 3.00E-04 4 6.01E-04 4.43E-02 2.70E-03 2.20E-01 3.00E-04 4 6.01E-04 4.43E-02 2.70E-03 2.20E-01 3.00E-04 4 6.01E-04 1.25E-05 2.70E-03 2.20E-01 5.32E-02 15 3.99E-01 1.25E-05 2.70E-03 2.20E-01 4.97E-03 15 3.73E-02 9.65E-03 2.70E-03 2.20E-01 3.00E-04 15 2.25E-03 4.43E-02 2.70E-03 2.20E-01 3.00E-04 15 9.33E-01 1.25E-05 2.70E-03 2.20E-01 3.00E-04 5 7.51E-04 4.43E-02 2.70E-03 2.20E</td><td>Initiation Frequency (yr) CRDM Group Initiation (yr) Nozzle Failure Probability Probability CCDP Probability Circ Crack 10 RFO Insp. Fails 3.52E-01 4 7.03E-01 1.25E-05 2.70E-03 2.20E-01 NA 5.30E-02 4 1.06E-01 1.25E-05 2.70E-03 2.20E-01 NA 4.97E-03 4 9.94E-03 9.65E-03 2.70E-03 2.20E-01 NA 3.00E-04 4 6.01E-04 4.43E-02 2.70E-03 2.20E-01 NA 3.00E-04 4 6.01E-04 4.43E-02 2.70E-03 2.20E-01 NA 3.73E-01 15 2.80E+00 1.25E-05 2.70E-03 2.20E-01 NA 4.97E-03 15 3.73E-02 9.65E-03 2.70E-03 2.20E-01 NA 3.00E-04 15 2.25E-03 4.43E-02 2.70E-03 2.20E-01 NA 3.73E-01 5 1.33E-01 1.25E-05 2.70E-03 2.20E-01 NA 3.73E-01 5 1.34E-</td><td>Initiation Frequency (yr)Initiation Frequency (yr)Nozzle Failure ProbabilityProbabilityProbabilityProbability10 RFO Insp. Insp. Fails11 RFO Insp. Fails3.52E-0147.03E-011.25E-052.70E-032.20E-01NANA5.30E-0241.06E-011.25E-052.70E-032.20E-01NANA4.97E-0349.94E-039.65E-032.70E-032.20E-01NA13.00E-0446.01E-044.43E-022.70E-032.20E-01NA13.00E-0446.01E-044.43E-022.70E-032.20E-01NA13.00E-0446.01E-044.43E-022.70E-032.20E-01NA13.00E-04152.80E+001.25E-052.70E-032.20E-01NANA5.32E-02153.99E-011.25E-052.70E-032.20E-01NA13.00E-04152.25E-034.43E-022.70E-032.20E-01NA13.00E-04152.25E-034.43E-022.70E-032.20E-01NA13.73E-0159.33E-011.25E-052.70E-032.20E-01NANA5.32E-0251.33E-011.25E-052.70E-032.20E-01NANA4.97E-0351.24E-029.65E-032.70E-032.20E-01NANA5.32E-0251.33E-011.25E-052.70E-032.20E-01NANA<</td><td>Initiation Frequency (yr) CRDM in Group Initiation (yr) Nozzle Failure (yr) Probability Failure Probability Probability CCDP Probability Croc Crack 10.8FO Insp. Fails 12 RFO Insp. Fails 3.52E-01 4 7.03E-01 1.25E-05 2.70E-03 2.20E-01 NA NA NA 5.30E-02 4 1.06E-01 1.25E-05 2.70E-03 2.20E-01 NA NA 1 4.97E-03 4 9.94E-03 9.65E-03 2.70E-03 2.20E-01 NA 1 1 3.00E-04 4 6.01E-04 4.43E-02 2.70E-03 2.20E-01 NA 1 1 3.00E-04 4 6.01E-04 4.43E-02 2.70E-03 2.20E-01 NA NA NA 3.00E-04 15 2.80E+00 1.25E-05 2.70E-03 2.20E-01 NA NA 1 4.97E-03 15 3.73E-02 9.65E-03 2.70E-03 2.20E-01 NA 1 4.97E-03 15 2.37E-03 2.70E-03</td><td>Initiation Frequency (yr) CRDM Group Initiation Frequency (yr) Nozzle Failure Probability Probability CCDP 10 RFO 11 RFO 11 RFO Insp. 11 RFO Insp. 12 RFO (yr) CDF (yr) 3.52E-01 4 7.03E-01 1.25E-05 2.70E-03 2.20E-01 NA NA NA 5.22E-09 3.52E-02 4 1.06E-01 1.25E-05 2.70E-03 2.20E-01 NA NA 1 7.86E-00 4.97E-03 4 9.94E-03 9.65E-03 2.70E-03 2.20E-01 NA 1 1 1 5.70E-08 3.00E-04 4 6.01E-04 4.43E-02 2.70E-03 2.20E-01 NA NA NA 2.80E-08 3.00E-04 15 2.80E+00 1.25E-05 2.70E-03 2.20E-01 NA NA NA 2.96E-09 3.73E-01 15 3.73E-02 9.65E-03 2.70E-03 2.20E-01 NA NA 1 2.96E-09 3.00E-04 15 2.25E-03 4.43E-02 2.70E-03<!--</td--><td>Initiation Frequery (yr)Initiation Frequery (yr)Nozzle Fallurg ProbabilityProbability10 RFO (Freis)11 RFO (RSP)12 RFO (RSP)CDF (yr)LERF (yr)3.52e-0147.03e-011.25e-052.70e-032.20e-01NANANA5.22e-097.32e-125.30e-0241.06e-011.25e-052.70e-032.20e-01NANA17.86e-101.72e-124.97e-0349.94e-039.65e-032.70e-032.20e-01NANA115.70e-088.44e-113.00e-0446.01e-044.43e-022.70e-032.20e-01NA111.58e-082.34e-113.00e-0446.01e-044.43e-022.70e-032.20e-01NA111.58e-082.34e-113.00e-0446.01e-041.25e-052.70e-032.20e-01NANANA1.01.58e-082.34e-113.03e-04152.80e+001.25e-052.70e-032.20e-01NANANA2.08e-083.0e-115.32e-02153.90e-011.25e-052.70e-032.20e-01NANA12.96e-033.96e-013.03e-04152.35e-031.25e-032.70e-032.20e-01NANA12.96e-033.96e-013.03e-04152.35e-032.70e-032.20e-01NANA12.96e-033.96e-013.03e-04153.33e-031.</td></td></tr<>	Initiation Frequency (yr) CRDM Group Initiation Frequency (yr) Nozzle Failure Probability Probability CCDP 3.52E-01 4 7.03E-01 1.25E-05 2.70E-03 2.20E-01 5.30E-02 4 1.06E-01 1.25E-05 2.70E-03 2.20E-01 4.97E-03 4 9.94E-03 9.65E-03 2.70E-03 2.20E-01 3.00E-04 4 6.01E-04 4.43E-02 2.70E-03 2.20E-01 3.00E-04 4 6.01E-04 4.43E-02 2.70E-03 2.20E-01 3.00E-04 4 6.01E-04 1.25E-05 2.70E-03 2.20E-01 5.32E-02 15 3.99E-01 1.25E-05 2.70E-03 2.20E-01 4.97E-03 15 3.73E-02 9.65E-03 2.70E-03 2.20E-01 3.00E-04 15 2.25E-03 4.43E-02 2.70E-03 2.20E-01 3.00E-04 15 9.33E-01 1.25E-05 2.70E-03 2.20E-01 3.00E-04 5 7.51E-04 4.43E-02 2.70E-03 2.20E	Initiation Frequency (yr) CRDM Group Initiation (yr) Nozzle Failure Probability Probability CCDP Probability Circ Crack 10 RFO Insp. Fails 3.52E-01 4 7.03E-01 1.25E-05 2.70E-03 2.20E-01 NA 5.30E-02 4 1.06E-01 1.25E-05 2.70E-03 2.20E-01 NA 4.97E-03 4 9.94E-03 9.65E-03 2.70E-03 2.20E-01 NA 3.00E-04 4 6.01E-04 4.43E-02 2.70E-03 2.20E-01 NA 3.00E-04 4 6.01E-04 4.43E-02 2.70E-03 2.20E-01 NA 3.73E-01 15 2.80E+00 1.25E-05 2.70E-03 2.20E-01 NA 4.97E-03 15 3.73E-02 9.65E-03 2.70E-03 2.20E-01 NA 3.00E-04 15 2.25E-03 4.43E-02 2.70E-03 2.20E-01 NA 3.73E-01 5 1.33E-01 1.25E-05 2.70E-03 2.20E-01 NA 3.73E-01 5 1.34E-	Initiation Frequency (yr)Initiation Frequency (yr)Nozzle Failure ProbabilityProbabilityProbabilityProbability10 RFO Insp. Insp. Fails11 RFO Insp. Fails3.52E-0147.03E-011.25E-052.70E-032.20E-01NANA5.30E-0241.06E-011.25E-052.70E-032.20E-01NANA4.97E-0349.94E-039.65E-032.70E-032.20E-01NA13.00E-0446.01E-044.43E-022.70E-032.20E-01NA13.00E-0446.01E-044.43E-022.70E-032.20E-01NA13.00E-0446.01E-044.43E-022.70E-032.20E-01NA13.00E-04152.80E+001.25E-052.70E-032.20E-01NANA5.32E-02153.99E-011.25E-052.70E-032.20E-01NA13.00E-04152.25E-034.43E-022.70E-032.20E-01NA13.00E-04152.25E-034.43E-022.70E-032.20E-01NA13.73E-0159.33E-011.25E-052.70E-032.20E-01NANA5.32E-0251.33E-011.25E-052.70E-032.20E-01NANA4.97E-0351.24E-029.65E-032.70E-032.20E-01NANA5.32E-0251.33E-011.25E-052.70E-032.20E-01NANA<	Initiation Frequency (yr) CRDM in Group Initiation (yr) Nozzle Failure (yr) Probability Failure Probability Probability CCDP Probability Croc Crack 10.8FO Insp. Fails 12 RFO Insp. Fails 3.52E-01 4 7.03E-01 1.25E-05 2.70E-03 2.20E-01 NA NA NA 5.30E-02 4 1.06E-01 1.25E-05 2.70E-03 2.20E-01 NA NA 1 4.97E-03 4 9.94E-03 9.65E-03 2.70E-03 2.20E-01 NA 1 1 3.00E-04 4 6.01E-04 4.43E-02 2.70E-03 2.20E-01 NA 1 1 3.00E-04 4 6.01E-04 4.43E-02 2.70E-03 2.20E-01 NA NA NA 3.00E-04 15 2.80E+00 1.25E-05 2.70E-03 2.20E-01 NA NA 1 4.97E-03 15 3.73E-02 9.65E-03 2.70E-03 2.20E-01 NA 1 4.97E-03 15 2.37E-03 2.70E-03	Initiation Frequency (yr) CRDM Group Initiation Frequency (yr) Nozzle Failure Probability Probability CCDP 10 RFO 11 RFO 11 RFO Insp. 11 RFO Insp. 12 RFO (yr) CDF (yr) 3.52E-01 4 7.03E-01 1.25E-05 2.70E-03 2.20E-01 NA NA NA 5.22E-09 3.52E-02 4 1.06E-01 1.25E-05 2.70E-03 2.20E-01 NA NA 1 7.86E-00 4.97E-03 4 9.94E-03 9.65E-03 2.70E-03 2.20E-01 NA 1 1 1 5.70E-08 3.00E-04 4 6.01E-04 4.43E-02 2.70E-03 2.20E-01 NA NA NA 2.80E-08 3.00E-04 15 2.80E+00 1.25E-05 2.70E-03 2.20E-01 NA NA NA 2.96E-09 3.73E-01 15 3.73E-02 9.65E-03 2.70E-03 2.20E-01 NA NA 1 2.96E-09 3.00E-04 15 2.25E-03 4.43E-02 2.70E-03 </td <td>Initiation Frequery (yr)Initiation Frequery (yr)Nozzle Fallurg ProbabilityProbability10 RFO (Freis)11 RFO (RSP)12 RFO (RSP)CDF (yr)LERF (yr)3.52e-0147.03e-011.25e-052.70e-032.20e-01NANANA5.22e-097.32e-125.30e-0241.06e-011.25e-052.70e-032.20e-01NANA17.86e-101.72e-124.97e-0349.94e-039.65e-032.70e-032.20e-01NANA115.70e-088.44e-113.00e-0446.01e-044.43e-022.70e-032.20e-01NA111.58e-082.34e-113.00e-0446.01e-044.43e-022.70e-032.20e-01NA111.58e-082.34e-113.00e-0446.01e-041.25e-052.70e-032.20e-01NANANA1.01.58e-082.34e-113.03e-04152.80e+001.25e-052.70e-032.20e-01NANANA2.08e-083.0e-115.32e-02153.90e-011.25e-052.70e-032.20e-01NANA12.96e-033.96e-013.03e-04152.35e-031.25e-032.70e-032.20e-01NANA12.96e-033.96e-013.03e-04152.35e-032.70e-032.20e-01NANA12.96e-033.96e-013.03e-04153.33e-031.</td>	Initiation Frequery (yr)Initiation Frequery (yr)Nozzle Fallurg ProbabilityProbability10 RFO (Freis)11 RFO (RSP)12 RFO (RSP)CDF (yr)LERF (yr)3.52e-0147.03e-011.25e-052.70e-032.20e-01NANANA5.22e-097.32e-125.30e-0241.06e-011.25e-052.70e-032.20e-01NANA17.86e-101.72e-124.97e-0349.94e-039.65e-032.70e-032.20e-01NANA115.70e-088.44e-113.00e-0446.01e-044.43e-022.70e-032.20e-01NA111.58e-082.34e-113.00e-0446.01e-044.43e-022.70e-032.20e-01NA111.58e-082.34e-113.00e-0446.01e-041.25e-052.70e-032.20e-01NANANA1.01.58e-082.34e-113.03e-04152.80e+001.25e-052.70e-032.20e-01NANANA2.08e-083.0e-115.32e-02153.90e-011.25e-052.70e-032.20e-01NANA12.96e-033.96e-013.03e-04152.35e-031.25e-032.70e-032.20e-01NANA12.96e-033.96e-013.03e-04152.35e-032.70e-032.20e-01NANA12.96e-033.96e-013.03e-04153.33e-031.



FENOC