

Roche

MAY 06 1981

Docket Nos. 50-250
and 50-251

Dr. Robert E. Uhrig, Vice President
Advanced Systems and Technology
Florida Power and Light Company
Post Office Box 529100
Miami, Florida 33152

DISTRIBUTION:

- Dockets
- NRC PDR
- L PDR
- TERA
- NSIC
- ORB#1 Rdg
- OELD
- IE-4
- GDeegan-8
- BScharf-10
- JWetmore
- ACRS-10
- OPA
- RDiggs
- MGrotenhuis
- CParrish
- Gray File-4
- Chairman, ASLAB



Dear Dr. Uhrig:

The Commission has issued the enclosed Amendment No. ⁶⁵ to Facility Operating License No. DPR-31 and Amendment No. ⁵⁷ to Facility Operating License No. DPR-41 for the Turkey Point Plant, Unit Nos. 3 and 4, respectively. The amendments consist of changes to the Technical Specifications in response to your application transmitted by letter dated February 27, 1980 (L-80-62).

These amendments incorporate the requirement that control rods be maintained within ± 12 steps indicated and that the rod position indication system be verified to be accurate within 12 steps.

Copies of the Safety Evaluation and the Notice of Issuance are also enclosed.

Sincerely,

Original signed by:

Steven A. Varga, Chief
Operating Reactors Branch #1
Division of Licensing

Enclosures:

1. Amendment No. ⁶⁵ to DPR-31
2. Amendment No. ⁵⁷ to DPR-41
3. Safety Evaluation
4. Notice of Issuance

cc: w/enclosures
See next page

8105150 402

** See previous documents*

| | | | | | | |
|---------|----------|-------------|----------|----------|--------|---------------------|
| OFFICE | ORB#1:DL | ORB#1:DL | ORB#1:DL | AD/OR:DL | OELD | |
| SURNAME | H. Smith | MGrotenhuis | SVarga | TNovak | | ew |
| DATE | 5/ /81 | 5/6/81 | 5/ /81 | 5/ /81 | 5/ /81 | P. Wagner 5/6/81 |

Docket Nos. 50-250
and 50-251

Dr. Robert E. Uhrig, Vice President
Advanced Systems and Technology
Florida Power and Light Company
Post Office Box 529100
Miami, Florida 33152

Dear Dr. Uhrig:

The Commission has issued the enclosed Amendment No. to Facility Operating License No. DPR-31 and Amendment No. to Facility Operating License No. DPR-41 for the Turkey Point Plant Unit Nos. 3 and 4, respectively. The amendments consist of changes to the Technical Specifications in response to your application transmitted by letter ddated February 27, 1980 (L-80-62).

These amendments incorporate the requirement that control rods be maintained within +12 steps indicated and that the rod position indication system be verified to be accurate within 12 steps. In addition, the Table of Contents is updated to incorporate changes made by the Order dated October 24, 1980 and to correct typographical errors.

Copies of the Safety Evaluation and the Notice of Issuance are also enclosed.

Sincerely,

Steven A. Varga, Chief
Operating Reactors Branch #1
Division of Licensing

Enclosures:

1. Amendment No. to DPR-31
2. Amendment No. to DPR-41
3. Safety Evaluation
4. Notice of Issuance

cc: w/enclosures
See next page

| | | | | | | |
|-----------|--|--|--|--|--|--|
| OFFICE ▶ | | | | | | |
| SURNAME ▶ | | | | | | |
| DATE ▶ | | | | | | |

Distribution

Docket Files 50-250
 and 50-251
 NRC PDRs (2)
 Local PDR
 TERA
 NSIC
 NRR Reading
 ORB1 Reading
 H. Denton
 D. Eisenhut
 R. Purple
 R. Tedesco
 G. Lainas
 T. Novak
 S. Varga
 M. Grotenhuis

D. Chaney
 C. Parrish
 J. Roe
 J. Heltemes
 I&E (5)
 OELD
 B. Jones (8)
 ACRS (16)
 B. Scharf (10)
 C. Miles
 R. Diggs
 C. Stephens

FR NOTICE
 + AMENDMENT
 ↑

54A1-11

| | | | | | | |
|-----------|-------------------|-------------------|-----------|----------|----------|-----------------|
| OFFICE ▶ | DL:ORB1 <i>DL</i> | DL:ORB1 <i>MG</i> | DL:ORB1 | DL:ORB1 | DL:AD:OR | OELD <i>JD</i> |
| SURNAME ▶ | DChaney:jb | MGrotenhuis | CSParrish | SAVarga | TNovak | <i>JD</i> dbecg |
| DATE ▶ | 10/25/80 | 11/1/80 | 1/1/80 | 11/10/80 | 11/11/80 | 11/13/80 |



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

May 6, 1981

Dorhet

Docket Nos. 50-250
and 50-251

Dr. Robert E. Uhrig, Vice President
Advanced Systems and Technology
Florida Power and Light Company
Post Office Box 529100
Miami, Florida 33152

Dear Dr. Uhrig:

The Commission has issued the enclosed Amendment No. 65 to Facility Operating License No. DPR-31 and Amendment No. 57 to Facility Operating License No. DPR-41 for the Turkey Point Plant, Unit Nos. 3 and 4, respectively. The amendments consist of changes to the Technical Specifications in response to your application transmitted by letter dated February 27, 1980 (L-80-62).

These amendments incorporate the requirement that control rods be maintained within ± 12 steps indicated and that the rod position indication system be verified to be accurate within 12 steps.

Copies of the Safety Evaluation and the Notice of Issuance are also enclosed.

Sincerely,

A handwritten signature in black ink, appearing to read "Steven A. Varga".

Steven A. Varga, Chief
Operating Reactors Branch #1
Division of Licensing

Enclosures:

1. Amendment No. 65 to DPR-31
2. Amendment No. 57 to DPR-41
3. Safety Evaluation
4. Notice of Issuance

cc: w/enclosures
See next page

Robert E. Uhrig
Florida Power and Light Company

cc: Mr. Robert Lowenstein, Esquire
Lowenstein, Newman, Reis and Axelrad
1025 Connecticut Avenue, N.W.
Suite 1214
Washington, D. C. 20036

Environmental and Urban Affairs Library
Florida International University
Miami, Florida 33199

Mr. Norman A. Coll, Esquire
Steel, Hector and Davis
1400 Southeast First National
Bank Building
Miami, Florida 33131

Mr. Henry Yaeger, Plant Manager
Turkey Point Plant
Florida Power and Light Company
P. O. Box 013100
Miami, Florida 33101

Honorable Dewey Knight
County Manager of Metropolitan
Dade County
Miami, Florida 33130

Bureau of Intergovernmental Relations
650 Apalachee Parkway
Tallahassee, Florida 32304

Resident Inspector
Turkey Point Nuclear Generating Station
U. S. Nuclear Regulatory Commission
Post Office Box 1207
Homestead, Florida 33030

Director, Criteria and Standards Division
Office of Radiation Programs (ANR-460)
U. S. Environmental Protection Agency
Washington, D. C. 20460

U. S. Environmental Protection Agency
Region IV Office
ATTN: EIS COORDINATOR
345 Courtland Street, N.W.
Atlanta, Georgia 30308

Mr. Jack Shreve
Office of the Public Counsel
Room 4, Holland Building
Tallahassee, Florida 32304

Administrator
Department of Environmental
Regulation
Power Plant Siting Section
State of Florida
2600 Blair Stone Road
Tallahassee, Florida 32301



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

FLORIDA POWER AND LIGHT COMPANY

DOCKET NO. 50-250

TURKEY POINT PLANT UNIT NO. 3

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 65
License No. DPR-31

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Florida Power and Light Company (the licensee) dated February 27, 1980 (L-80-62), complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

8105150406

2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 3.B of Facility Operating License No. DPR-31 is hereby amended to read as follows:

(B) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 65, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Steven A. Varga, Chief
Operating Reactors Branch #1
Division of Licensing

Attachment:
Changes to the Technical
Specifications

Date of Issuance: May 6, 1981



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

FLORIDA POWER AND LIGHT COMPANY

DOCKET NO. 50-251

TURKEY POINT PLANT UNIT NO. 4

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 57
License No. DPR-41

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Florida Power and Light Company (the licensee) dated February 27, 1980 (L-80-62), complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 3.B of Facility Operating License No. DPR-41 is hereby amended to read as follows:

(B) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 57, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION


Steven A. Varga, Chief
Operating Reactors Branch #1
Division of Licensing

Attachment:
Changes to the Technical
Specifications

Date of Issuance: May 6, 1981

ATTACHMENT TO LICENSE AMENDMENT

AMENDMENT NO. 65 TO FACILITY OPERATING LICENSE NO. DPR-31
AMENDMENT NO. 57 TO FACILITY OPERATING LICENSE NO. DPR-41

DOCKET NOS. 50-250 AND 50-251

Revise Appendix A as follows:

Remove Pages

3.2-2
3.2-3
Table 4.1-1, Sheet 1

Insert Pages

3.2-2
3.2-3
Table 4.1-1 Sheet 1

- f. Except for low power physics tests, the shutdown margin with allowance for a stuck control rod shall exceed the applicable value shown on Figure 3.2-2 under all steady-state operating conditions from zero to full power, including effects of axial power distribution. The shutdown margin as used here is defined as the amount by which the reactor core would be subcritical at hot shutdown conditions (540°F) if all control rods were tripped, assuming that the highest worth control rod remained fully withdrawn, and assuming no changes in xenon, boron concentration or part-length rod position.
- g. During physics tests and control rod exercises, the insertion limits need not be met, but the required shutdown margin, Figure 3.2-2 must be maintained or exceeded.

2. MISALIGNED CONTROL ROD

If a part length* or full length control rod is more than 12 steps out of alignment with its bank, and is not corrected within 8 hours power shall be reduced so as not to exceed 75% of interim power for 3 loop or 45% of interim power for two loop operation, unless the hot channel factors are shown to be no greater than allowed by Section 6a of Specification 3.2.

3. ROD DROP TIME

The drop time of each control rod shall be no greater than 1.8 seconds at full flow and operating temperature from the beginning of rod motion to dashpot entry.

4. INOPERABLE CONTROL RODS

- a. No more than one inoperable control rod shall be permitted during sustained power operation, except it shall not be permitted if the rod has a potential

*Any reference to part-length rods no longer applies after the part-length rods are removed from the reactor.

reactivity insertion upon ejection greater than 0.3% k/k at rated power. Inoperable rod worth shall be determined within 4 weeks.

- b. A control rod shall be considered inoperable if
 - (a) the rod cannot be moved by the CRDM, or
 - (b) the rod is misaligned from its bank by more than 12 steps, or
 - (c) the rod drop time is not met.
- c. If a control rod cannot be moved by the drive mechanism, shutdown margin shall be increased by boron addition to compensate for the withdrawn worth of the inoperable rod.

5. CONTROL ROD POSITION INDICATION

If either the power range channel deviation alarm or the rod deviation monitor alarm are not operable, rod positions shall be logged once per shift and after a load change greater than 10% of rated power. If both alarms are inoperable for two hours or more, the nuclear overpower trip shall be reset to 93% of rated power.

6. POWER DISTRIBUTION LIMITS

- a. Hot channel factors:

With steam generator tube plugging $\leq 25\%$, the hot channel factors (defined in the basis) must meet the following limits at all times except during low power physics tests:

$$F_q(Z) \leq (1.93/P) \times K(Z), \text{ for } P > .5$$

$$F_q(Z) \leq (3.86) \times K(Z), \text{ for } P \leq .5$$

$$F_H^N \leq 1.55[1.0 + 0.2(1-P)]$$

Where P is the fraction of rated power at which the core is operating; K(Z) is the function given in Figure 3.2-3; Z is the core height location of

F_q .

If F_q , as predicted by approved physics calculations, exceeds 1.93, the power will be limited to the rated power multiplied by the ratio of 1.93 divided by the predicted F_q , or augmented surveillance of hot channel factors shall be implemented.

TABLE 4.1.1
MINIMUM FREQUENCIES FOR CHECKS, CALIBRATIONS AND
TEST OF INSTRUMENT CHANNELS

| <u>Channel Description</u> | <u>Check</u> | <u>Calibrate</u> | <u>Test</u> | <u>Remarks</u> |
|--|----------------|------------------|------------------|--|
| 1. Nuclear Power Range (Check, Calibrate and Test only applicable above 100% of rated power.) | S (1) M*(4) | D (2) Q*(4) | M (3) | 1) Load v.s. flux curve 2) Thermal power calculation 3) Signal to ΔT ; bistable action (permissive, rod stop, trips) 4) Upper & lower detectors for symmetric offset (+5 to -5%) |
| 2. Nuclear Intermediate Range | S (1)+ | N.A. | P (2) | 1) Once/shift up to 50% R.P. 2) Log level; bistable action (permissive, rod stop, trip) |
| 3. Nuclear Source Range | S (1) | N.A. | P (2) | 1) Once/shift when in service 2) Bistable action (alarm, trip) |
| 4. Reactor Coolant Temperature | S+ | R | B/W (1)+ (2)+ | 1) Overtemperature- ΔT 2) Overpower- ΔT |
| 5. Reactor Coolant Flow | S+ | R | M+ | |
| 6. Pressurizer Water Level | S+ | R | M+ | |
| 7. Pressurizer Pressure | S+ | R | M+ | |
| 8. 4 kv Voltage & Frequency | N.A. | R** | R | Reactor protection circuits only |
| 9. Analog Rod Position | S+ | R | M+ | 1) With step counters 2) Calibrate indicated position to within 12 steps of actual position. |



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION
RELATED TO AMENDMENT NO. 65 TO FACILITY OPERATING LICENSE NO. DPR-31
AND AMENDMENT NO. 57 TO FACILITY OPERATING LICENSE NO. DPR-41

FLORIDA POWER AND LIGHT COMPANY
TURKEY POINT PLANT UNIT NOS. 3 AND 4
DOCKET NOS. 50-250 AND 50-251

Background

The staff recently completed a review of the LERs and Technical Specification requirements related to the Control Rod Position Indication System (RPI) at Westinghouse PWRs and determined that a wide variation exists in the number of LERs received and the Technical Specification requirements.

Discussion and Evaluation

Westinghouse has performed safety analyses for control rod misalignment up to 15 inches or 24 steps (one step equals 5/8 inch). Since analysis of misalignments in excess of this amount have not been submitted, we have imposed an LCO restricting continued operation with a misalignment in excess of 15 inches. Because the analog control rod position indication system has an uncertainty of 7.5 inches (12 steps), when an indicated deviation of 12 steps exists, the actual misalignment may be 15 inches. This is because one of the coils, spaced at 3.75 inches, may be failed without the operator's knowledge. The Standard Technical Specifications were written to eliminate any confusion about this, and restrict deviations to 12 indicated steps. Surveillance requirements, on the indication accuracy of 12 steps, were also prepared to ensure that the 15 inch LCO is met. Since there is no difference intended in requirements issued for any Westinghouse reactor, plants with Technical Specifications written in different terms of misalignment should consider the 12 step instrument in accuracy when monitoring rod position.

A related problem is that the installed analog control rod position indicating system equipment may not, in some areas, be adequate to maintain the control rod misalignment specification requirement because of drift problems in the calibration curves. This is evidenced by numerous LERs concerning rod position indication accuracy. In these cases, the uncertainty may be more than 12 steps.

Florida Power and Light Company (the licensee) was requested, by letter dated October 29, 1980, to review the Technical Specifications for the Turkey Point Plant, Unit Nos. 3 and 4 to ensure that the control rods are required to be maintained within +12 steps indicated position and that the rod position indication system is accurate to within +12 steps.

8105150 415

~~05150~~

By letter dated February 27, 1980, (L-80-62), the licensee responded to the NRC request and provided proposed Technical Specification changes to incorporate the staff's requirements.

Summary

Based on our review of the licensee's submittal, we find that the proposed changes are in conformance with the staff's request and are, therefore, acceptable.

Environmental Consideration

We have determined that the amendments do not authorize a change in effluent types or total amounts nor an increase in power level and will not result in any significant environmental impact. Having made this determination, we have further concluded that the amendments involve an action which is insignificant from the standpoint of environmental impact and, pursuant to 10 CFR §51.5(d)(4), that an environmental impact statement or negative declaration and environmental impact appraisal need not be prepared in connection with the issuance of these amendments.

Conclusion

We have concluded, based on the considerations discussed above, that: (1) because the amendments do not involve a significant increase in the probability or consequences of accidents previously considered and do not involve a significant decrease in a safety margin, the amendments do not involve a significant hazards consideration, (2) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and (3) such activities will be conducted in compliance with the Commission's regulations and the issuance of these amendments will not be inimical to the common defense and security or to the health and safety of the public.

Date: May 6, 1981

UNITED STATES NUCLEAR REGULATORY COMMISSIONDOCKET NOS. 50-250 AND 50-251FLORIDA POWER AND LIGHT COMPANYNOTICE OF ISSUANCE OF AMENDMENT TO FACILITY
OPERATING LICENSE

The U. S. Nuclear Regulatory Commission (the Commission) has issued Amendment No. 65 to Facility Operating License No. DPR-31, and Amendment No. 57 to Facility Operating License No. DPR-41 issued to Florida Power and Light Company (the licensee), which revised Technical Specifications for operation of Turkey Point Plant, Unit Nos. 3 and 4 (the facilities) located in Dade County, Florida. The amendments are effective as of the date of issuance.

The amendments incorporate the requirement that control rods be maintained within +12 steps indicated and that the rod position indication system be verified to be accurate within 12 steps.

The application for the amendments complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR Chapter I, which are set forth in the license amendments. Prior public notice of these amendments was not required since the amendments do not involve a significant hazards consideration.


- 2 -

The Commission has determined that the issuance of these amendments will not result in any significant environmental impact and that pursuant to 10 CFR §51.5(d)(4) an environmental impact statement or negative declaration and environmental impact appraisal need not be prepared in connection with issuance of these amendments.

For further details with respect to this action, see (1) the application for amendments dated February 27, 1980, (2) Amendment Nos. 65 and 57 to License Nos. DPR-31 and DPR-41, and (3) the Commission's related Safety Evaluation. All of these items are available for public inspection at the Commission's Public Document Room, 1717 H Street, N.W., Washington, D.C. and at the Environmental and Urban Affairs Library, Florida International University, Miami, Florida 33199. A copy of items (2) and (3) may be obtained upon request addressed to the U. S. Nuclear Regulatory Commission, Washington, D.C. 20555, Attention: Director, Division of Licensing.

Dated at Bethesda, Maryland, this 6th day of May 1981.

FOR THE NUCLEAR REGULATORY COMMISSION


Steven A. Varga, Chief
Operating Reactors Branch #1
Division of Licensing