

DISTRIBUTION

Docket File
 NRC PDR
 Local PDR
 ORB 1 File
 D. Eisenhut
 C. Parrish
 D. McDonald
 OELD
 SECY
 E. L. Jordan
 J. M. Taylor
 L. J. Harmon
 T. Barnhart (8)
 L. Schneider
 D. Brinkman
 ACRS (10)
 OPA (Clare Miles)
 R. Diggs

NSIC
ASLAB

*Correction to
Admt. 56 to DPR-31*

DEC 27 1982

Docket Nos. 50-250
and 50-251

Dr. Robert E. Uhrig, Vice President
 Advanced Systems and Technology
 Florida Power and Light Company
 Post Office Box 529100
 Miami, Florida 33152

Dear Mr. Uhrig:

On March 21, 1980, the Commission issued Amendment Nos. 56 and 48 to Facility Operating License Nos. DPR-31 and DPR-41 for Turkey Point Units 3 and 4, respectively. The amendments revised the reactor coolant pressure-temperature limits to account for neutron irradiation induced increases in reactor vessel metal nil ductility temperature.

Technical Specifications page 3.1-2 did not correctly reference the applicable figures 3.1-1a through 3.1-1d (Unit 3) and 3.1-2a through 3.1-2d (Unit 4). In order to provide the correct reference to the figures, enclosed is the corrected page 3.1-2 to be inserted in Appendix A of Facility Operating License Nos. DPR-31 and DPR-41.

Please accept our apologies for any inconvenience this error may have caused.

Sincerely,

ORIGINAL SIGNED

Daniel G. McDonald, Project Manager
 Operating Reactors Branch No. 1
 Division of Licensing

Enclosure:
As stated

cc w/enclosure:
See next page

8301060521 821227
 PDR ADOCK 05000250
 P PDR

OFFICE	ORB 1	ORB-1	ORB-1				
SURNAME	CParrish	DMcDonald/rs	Stange				
DATE	12/15/82	12/27/82	12/27/82				

Robert E. Uhrig
Florida Power and Light Company

cc: Harold F. Reis, Esquire
Lowenstein, Newman, Reis and Axelrad
1025 Connecticut Avenue, N.W.
Suite 1214
Washington, D. C. 20036

Bureau of Intergovernmental Relations
660 Apalachee Parkway
Tallahassee, Florida 33130

Norman A. Coll, Esquire
Steel, Hector and Davis
1400 Southeast First National
Bank Building
Miami, Florida 33131

Mr. Henry Yaeger, Plant Manager
Turkey Point Plant
Florida Power and Light Company
P. O. Box 013100
Miami, Florida 33101

Mr. M. R. Stierheim
County Manager of Metropolitan
Dade County
Miami, Florida 33130

Resident Inspector
Turkey Point Nuclear Generating Station
U. S. Nuclear Regulatory Commission
Post Office Box 1207
Homestead, Florida 33030

Regional Radiation Representative
EPA Region IV
345 Courtland Street, N.W.
Atlanta, Georgia 30308

Mr. Jack Shreve
Office of the Public Counsel
Room 4, Holland Building
Tallahassee, Florida 32304

Administrator
Department of Environmental
Regulation
Power Plant Siting Section
State of Florida
2600 Blair Stone Road
Tallahassee, Florida 32301

James P. O'Reilly
Regional Administrator - Region II
U. S. Nuclear Regulatory Commission
101 Marietta Street - Suite 3100
Atlanta, Georgia 30303

2. PRESSURE-TEMPERATURE LIMITS

The Reactor Coolant System (except for the pressurizer) pressure and temperature shall be limited during heatup, cooldown, criticality (except for low power physics tests), and inservice leak and hydrostatic testing in accordance with the limit lines shown on Figures 3.1-1a through 3.1-1d (Unit 3) and 3.1-2a through 3.1-2d (Unit 4). Allowable pressure-temperature combinations are BELOW AND TO THE RIGHT of the lines on the Figures. Heatup and cooldown rate limits are:

- a. A maximum heatup rate of 100°F in any one hour.
- b. A maximum cooldown rate of 100°F in any one hour.
- c. A maximum temperature change of $\geq 5^\circ\text{F}$ in any one hour during hydrostatic testing operation above system design pressure.

The pressurizer pressure and temperature shall be limited in accordance with the following:

- d. The pressurizer shall be limited to a maximum heatup rate of 100 °F in any one hour, and a maximum cooldown rate of 200 °F in any one hour.
- e. The pressurizer shall be limited to a maximum Reactor Coolant System spray water temperature differential of 320°F.

With any of the above limits exceeded, restore the temperature and/or pressure within the limits within 30 minutes, determine that the RCS or pressurizer remains acceptable for continued operations or, if at power, be in at least Hot Shutdown within the next 6 hours and Cold Shutdown within the following 30 hours.

With reactor power less than 70 percent Rated Thermal Power, the moderator temperature coefficient* shall not be more positive than $+5 \times 10^{-5} \Delta\text{K/K}/^\circ\text{F}$. When this condition is not met, the reactor shall be made subcritical by an amount equal to or greater than the potential reactivity insertion due to depressurization and cooldown.

With reactor power greater than or equal to 70 percent Rated Thermal Power, the moderator temperature coefficient shall not be more positive than $0 \Delta\text{K/K}/^\circ\text{F}$. When this condition is not met, the reactor shall be made subcritical by an amount equal to or greater than the potential reactivity insertion due to depressurization and cooldown.

* These moderator temperature coefficient conditions do not apply to low power physics tests.