

Docket Nos. 50-250
and 50-251

January 15, 1985

DISTRIBUTION

~~Docket File~~

JPartlow

NRC PDR

L PDR

ORB#1 Rdg

DEisenhut

ORAB

CParrish

DMcDonald

EJordan

PMcKee

TBarnhart 8

CMiles

RDiggs

gray 4

Mr. J. W. Williams, Jr., Vice President
Nuclear Energy Department
Florida Power and Light Company
Post Office Box 14000
Juno Beach, Florida 33408

Dear Mr. Williams:

Reference: TAC Nos. 56378 and 56379

SUBJECT: SCHEDULAR EXEMPTION - FIRE PROTECTION SCHEDULAR REQUIREMENTS
OF 10 CFR 50.48(c)(2), (c)(3) and (c)(4)

The Commission has issued the enclosed Exemption to the schedular requirements for fire protection relating to water suppression, fire dampers, structural steel fireproofing and penetrations for both Turkey Point Units 3 and 4. The extension also includes raceway protection and alternate shutdown for Unit 3 only. The length of the schedular deferment for each of the items is included in the Exemption.

A copy of the Exemption is being forwarded to the Office of the Federal Register for publication. The Notice of Environmental Assessment and Finding of No Significant Impact was published in the Federal Register on January 15, 1985 (50 FR 2112).

Sincerely,

/s/SVarga

Steven A. Varga, Chief
Operating Reactors Branch #1
Division of Licensing

Enclosure:
As stated

cc w/enclosure:
See next page

*See previous white for concurrence
ORB#1:DL* ORB#1:DL* BC-ORB#1:DL*
CParrish DMcDonald;ps SVarga
12/28/84 12/28/84 12/28/84

D:DA D:NRR
DEisenhut HDenton
1/14/85 *1/14/85*

JVM WVV AD/MCET OELD AD-OR:DL
TWambach WJohnston *W Shuler* GLainas
1/2/85 1/2/85 1/3/85 1/3/85

8501290459 850115
PDR ADDCK 05000250
F PDR

Docket Nos. 50-250
and 50-251

Mr. J. W. Williams, Jr., Vice President
Nuclear Energy Department
Florida Power and Light Company
Post Office Box 14000
Juno Beach, Florida 33408

Dear Mr. Williams:

DISTRIBUTION

Docket File JPartlow
NRC PDR
L PDR
ORB#1 Rdg
DEisenhut
ORAB
CParrish
DMcDonald
EJordan
PMcKee
TBarnhart 8
CMiles RDiggs

Reference: TAC Nos. 56378 and 56379

SUBJECT: SCHEDULAR EXEMPTION - FIRE PROTECTION SCHEDULAR REQUIREMENTS
OF 10 CFR 50.48(c)(2), (c)(3) and (c)(4)

The Commission has issued the enclosed Exemption to the schedular requirements for fire protection relating to water suppression, fire dampers, structural steel fireproofing and penetrations for both Turkey Point Units 3 and 4. The extension also includes raceway protection and alternate shutdown for Unit 3 only. The length of the schedular deferment for each of the items is included in the Exemption.

A copy of the Exemption is being forwarded to the Office of the Federal Register for publication. The Notice of Environmental Assessment and Finding of No Significant Impact was published in the Federal Register on January , 1985 (FR).

Sincerely,

Steven A. Varga, Chief
Operating Reactors Branch #1
Division of Licensing

Enclosure:
As stated

cc w/enclosure:
See next page

ORB#1:DL
CParrish
12/28/84
D:NRR
HDenton
//

ORB#1:DL
DMcDonald;ps
12/28/84

BC-ORB#1:DL
SVarga

STET
Twambach
1/2/85

AD/MCET
WJohnston

OELD
//

AD-OR:DL D:DL
GLainas DEisenhut
// //

J. W. Williams, Jr.
Florida Power and Light Company

Turkey Point Plants
Units 3 and 4

cc: Harold F. Reis, Esquire
Newman and Holtziner P.C.
1615 L Street, N.W.
Washington, DC 10036

Administrator
Department of Environmental
Regulation
Power Plant Siting Section
State of Florida
2600 Blair Stone Road
Tallahassee, Florida 32301

Bureau of Intergovernmental Relations
660 Apalachee Parkway
Tallahassee, Florida 33130

James P. O'Reilly
Regional Administrator, Region II
U.S Nuclear Regulatory Commission
Suite 2900
101 Marietta Street
Atlanta, GA 30303

Norman A. Coll, Esquire
Steel, Hector and Davis
4000 Southeast Financial
Center
Miami, Florida 33131-2398

Martin H. Hodder, Esquire
1131 N.E. 86th Street
Miami, Florida 33138

Mr. Ken N. Harris, Vice President
Turkey Point Nuclear Plant
Florida Power and Light Company
P.O. Box 013100
Miami, Florida 33101

Joette Lorion
7269 SW 54 Avenue
Miami, Florida 33143

Mr. M. R. Stierheim
County Manager of Metropolitan
Dade County
Miami, Florida 33130

Mr. Chris J. Baker, Plant Manager
Turkey Point Nuclear Plant
Florida Power and Light Company
P.O. Box 013100
Miami, Florida 33101

Resident Inspector
Turkey Point Nuclear Generating Station
U.S. Nuclear Regulatory Commission
Post Office Box 57-1185
Miami, Florida 33257-1185

Attorney General
Department of Legal Affairs
The Capitol
Tallahassee, Florida 32304

Regional Radiation Representative
EPA Region IV
345 Courtland Street, N.W.
Atlanta, GA 30308

Mr. Allan Schubert, Manager
Public Health Physicist
Department of Health and
Rehabilitative Services
1323 Winewood Blvd.
Tallahassee, Florida 32301

Mr. Jack Shreve
Office of the Public Counsel
Room 4, Holland Building
Tallahassee, Florida 32304

NUCLEAR REGULATORY COMMISSION

B501290473 B50115
PDR ADDCK 05000250
F PDR

Section 50.48(c)(2) specifies schedules for modifications not requiring prior NRC approval and non-outage related, Section 50.48(c)(3) specifies schedules for modifications not requiring prior NRC approval and outage related, and Section 50.48(c)(4) specifies schedules for modifications pursuant to Section III.G.3 of Appendix R (alternate safe shutdown capability) which requires NRC approval and applies to both non-outage and outage related activities.

By letter dated November 16 and supplemented on December 14, 1984, the licensee requested exemptions to the schedular requirements of 10 CFR 50.48, Sections (c)(2), (c)(3) and (c)(4) for six items pursuant to 10 CFR 50.12. The six items, current schedules required by Section 50.48 and the requested extensions are:

Units 3 and 4

- 1) Water Suppression - Required by 50.48(c)(2), January 31, 1985
- Requested extension (3 mos), April 30, 1985
- 2) Structural Steel Fire Proofing - Required by 50.48(c)(2) & (c)(3), January 31, 1985
- Requested extension (approx. 12 mos.) Unit 4, fall 1985, Outage plus 1 month
- 3) Fire Dampers - Required by 50.48(c)(2) & (c)(3), January 31, 1985
- Requested extension (approx. 11 mos.) Unit 4, Fall 1985, Outage
- 4) Penetration Seals - Required by 50.48(c)(2) & (c)(3), January 31, 1985
- Requested extension (approx 12 mos.) Unit 4, Fall 1985, Outage plus 1 month

Unit 3 Only

- 5) Paceway Protection - Required by 50.48(c)(2) & (c)(3), January 31, 1985
- Requested extension (approx. 4 mos.) Unit 3, Spring 1985, Outage plus 1 month

- 6) Alternate Shutdown
 - Required by 50.48(c)(4) Unit 3, Spring 1985, Outage
 - Requested extension (approx. 18 mos.) Unit 3, Winter 1986, Outage

III.

Reasonable interim compensatory measures for fire protection and post-fire safe shutdown capability must be provided in order to grant schedular exemptions from the implementation schedules defined in 10 CFR 50.48.

The licensee will implement three roving fire watch patrols in all areas for which schedular relief has been requested as compensation pending the completion of the modifications in items 1 through 5 identified above. The fire watch patrols will be implemented January 31, 1985, and continue until all fire protection work identified for Appendix R in each of the affected fire areas has been completed and is operable. All procedures and training needed for the fire watch patrols will be completed and available prior to the January implementation date.

The roving fire watch patrols will identify any indication of fire, smoke or burning odor and will immediately notify the control room; will be trained in the use of portable fire extinguishers; and will log-in at specific zones in their fire areas every 20 minutes on log sheets as detailed in the licensee's submittal.

In addition to the roving fire watch patrols, the licensee will implement a 24 hour continuous fire watch in the cable spreading room, the auxiliary building north-south breezeway and the control room as compensation pending completion of the alternate shutdown capability for Unit 3. The continuous fire watches will be implemented prior to the Unit 3

start-up after the spring 1985 refueling outage and continue until all the Unit 3 alternate shutdown work has been completed and the equipment is operable.

All procedures and training required for the continuous fire watches for each of the three areas identified above will be completed and available prior to the watch implementation date. The fire watches will identify any indication of fire, smoke or burning odor and will immediately notify the control room; will be trained in the use of portable fire extinguishers; and will supplement their continuous observations by making area-wide surveys at a frequency of once every 20 minutes as detailed in the licensee's submittal.

If a fire should occur within any fire area monitored by the roving fire watch patrols or the continuous 24 hour fire watches, there is reasonable assurance that the fire will be detected in its incipient stage before significant flame propagation or temperature rise occurs. Upon discovery of a fire, the control room will be immediately notified and a fire brigade response initiated. The fire patrols and watches will be trained in the proper use of portable fire extinguishers and be capable of controlling or suppressing the fire to minimize damage pending arrival of the fire brigade.

The projected status of the Appendix R fire protection related work for the Turkey Point Plant as of January 31, 1985, is detailed in the licensee's December 14, 1984 letter. The hangers will be fabricated and installation of the water and halon suppression systems started. Substantial portions of fire detection, barriers and fire doors will be completed. Thirty-five percent of the penetration seals and the major portion of the conduit for

cable rerouting will also be completed. The design documents for alternate shutdown will be available and installation started. Fire damper related work is currently on a hold status until resolution of qualification problems with the vendor.

IV.

Based on the considerations and current status of the fire portion related work discussed above, the staff has concluded that the licensee has provided sound rationale for the need of schedular relief; a best effort is being expended to complete the Appendix R related work; and reasonable and acceptable interim measures for fire protection and alternate shutdown capability to support the requested schedular exemptions have been provided. Therefore, based on our evaluation, the staff has concluded that the requested schedular exemption from the requirements of 10 CFR 50.48, Sections (c)(2), (c)(3) and (c)(4) should be granted.

Accordingly, the Commission has determined that, pursuant to 10 CFR 50.12, the schedular exemptions requested by the licensee's letter of November 16, 1984 and supplemented on December 14, 1984, are authorized by law and will not endanger life or property or the common defense and security and are otherwise in the public interest.

The Commission hereby grants the licensee exemptions from the schedular requirements of 10 CFR 50.48, Sections (c)(2), (c)(3) and (c)(4) for the following six areas and duration:

Units 3 and 4

- 1) Water Suppression - April 30, 1985
- 2) Structural Steel - Unit 4, Fall 1985, Outage startup plus one month Fire Proofing

- 3) Fire Dampers - Unit 4, Fall 1985, Outage startup plus one month
- 4) Penetration Seals - Unit 4 Fall, 1985, Outage startup plus one month

Unit 3 only


- 5) Raceway Protection - Unit 3, Spring 1985, Outage startup plus one month
- 6) Alternate Shutdown - Unit 3, Winter 1986, Outage startup

Pursuant to 10 CFR 51.32, the Commission has determined that the issuance of the exemption will have no significant impact on the environment (50FR 2112 , dated January 15, 1985).

For further details with respect to this action, see the request for exemption dated November 16 and supplement dated December 14, 1984, which are available for public inspection at the Commission's Public Document Room, 1717 H Street, N.W., Washington, D.C., and at the Environmental and Urban Affairs Library, Florida International University, Miami, Florida 33199.

This Exemption is effective upon issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

A handwritten signature in black ink, appearing to read 'Edson G. Case', with a long horizontal flourish extending to the right.

Edson G. Case, Deputy Director
Office of Nuclear Reactor Regulation

Dated at Bethesda, Maryland
this 14th day of January 1985