

Docket No. 50 254

November 6, 1976

Commonwealth Edison Company
ATTN: Mr. R. L. Bolger
Assistant Vice President
Post Office Box 767
Chicago, Illinois 60690

Gentlemen:

DISTRIBUTION

Docket BJones
NRC PDR TBAbernathy
Local PDR JRBuchanan
ORB #2 Reading ACES (16)
VStello
KRGoller
TJCarter
JMcGough
DLZiemann
PWO'Connor
MGrotenhuis
RMDiggs
DEisenhut
OI&E (3)
OELD - Karman

This confirms our telephoned authorization given on November 6, 1976 for a change in Technical Specifications for the Quad Cities Station Unit No. 1 in response to your telecopy of November 3, 1976. Facility Operating License No. DPR 29 is amended on this date by making the following technical specification change:

Add a note following paragraph 3.5.E.3 to read:

Note: During the period November 6 through November 20, 1976 the unit may be started up with the RCIC inoperable provided that 1) the facility is not operated more than 7 days with the RCIC inoperable and 2) all the HPCI system active components are demonstrated to be operable immediately after start up and daily thereafter.

Copies of the license amendment, our safety evaluation and Federal Register Notice for this technical specification change will be sent to you when completed.

Sincerely,

Original signed by:
Karl R. Goller

Karl R. Goller, Assistant Director
for Operating Reactors
Division of Operating Reactors

cc: see next page

OFFICE➤	DOR:ORB #2	DOR:ORB #2	DOR:AD/ORBs			
SURNAME➤	PWO'Connor:ah	DLZiemann	KRGoller			
DATE➤	11/6/76	11/6/76	11/6/76			

Commonwealth Edison Company

- 2 -

November 6, 1976

cc

Mr. Charles Whitmore
President and Chairman
Iowa-Illinois Gas and
Electric Company
206 East Second Avenue
Davenport, Iowa 52801

Mr. John W. Rowe
Isham, Lincoln & Beale
Counselors at Law
One First National Plaza, 42nd Floor
Chicago, Illinois 60603

Anthony Z. Roisman, Esquire
Roisman, Kessler and Cashdan
1025 15th Street, N. W., 5th Floor
Washington, D. C. 20005

Moline Public Library
504 - 17th Street
Moline, Illinois 61265