8-9-75

Dockets Nos. 59-250/251)

Florida Power and Light Company ATTN: Dr. Robert E. Uhrig Vice President P. O. Box 013100 Miami, Florida 33101

Distribution:

Docket

(RB#3

NRC PDR

Local PDR

OI&E (3)

BJones (4)

JMcGough

DME11iott

RIngram

Gentlemen:

On June 5, 1975, the Commission issued Amendment No. 9 to Facility Operating License No. DPR-31 and Amendment No. 8 to Facility Operating License No. DPR-41 with Change No. 21 to the Technical Specifications for the Turkey Point Nuclear Generating Units 3/4. Revised page 2.3-3 was, however, inadvertently omitted from this change although it was considered at the time of the issuance.

Please replace page 2.3-3 of the Technical Specifications with the enclosed revised page.

Sincerely,

George Lear, Chief Operating Reactors Branch #3 Division of Reactor Licensing

Enclosure: Page 2.3-3

cc: See next page

y P

	•				
OFFICE →	ORB#3	ORB#3			
SURNAME >	RIngram/dg 8/ /75	GLear		-	
DATE→	8/ /75	8/ /75			

Overpower
$$\Delta T \leq \Delta T_0$$
 1.09 - $K_1 \frac{dT}{dt} - K_2 (T - T') - f (\Delta I)$

 ΔT_0 = Indicated ΔT at rated power, F

T = Average temperature, F

T' = Indicated average temperature at nominal conditions and rated power, F

 K_2 = 0.00134 for T equal to or more than T^* ; 0 for T less than T^*

 $\frac{dT}{dt}$ = Rate of change of temperature, F/sec

 $f(\Delta I) = As$ defined above

Pressurizer

Low Pressurizer pressure - equal to or greater than 1715 psig.

High Pressurizer pressure - equal to or less than 2385 psig.

High Pressurizer water level - equal to or less than 92% of full scale.

Reactor Coolant Flow

Low reactor coolant flow - equal to or greater than 90% of normal indicated flow

Low reactor coolant pump motor frequency - equal to or greater than 56.1 Hz

Under voltage on reactor coolant pump motor bus - equal to or greater than 60% of normal voltage

Steam Generators

Low-low steam generator water level - equal to or greater than 5% of narrow range instrument scale