DATE: TIME:	11/28 08:27	/01 :41		DOCUME DOCU	AMI NT C MENT	EREN, NTRO TRAI	/UE DL SYS NSMITT	STEM TAL			PAGE: ARDC8801	50
TRANS TO CO TITLE DEPT: LOCAT TRANS	MITTAL NTROL : OTHE NUCLE ION: U MITTAL	NUMBER: NUMBER: R AR REGUI SNRC - V DATE:	478378 338U LATORY COM NASH DC 2001112	IM . 8	RI SI	ETURI UPERS	N ACKI SEDED ADM AMEI CALI P.O FUL	NOWLI DOCU INIST REN/U LAWAY . BOY TON,	EDGED JMENTS FRATIC JE Y PLAN K 620 MO 65	TRANSMIT S (IF APP) ON RECORD NT 5251	TAL AND LICABLE) S	TO:
TRAN CODE	DOC TYPE D	OCUMENT	NUMBER	REV	RET REV	MED	СОРУ	ALT MED	ALT COPY	AFFECTED	DOCUMEN'	T
R R R	PROC E PROC E PROC E	IP-ZZ-A(IP-ZZ-0(IP-ZZ-0()020)213)240	020 020 029	019 019 028	C C C	1 1 1					

_

ACKNOWLEDGED BY:

A045

EIP-ZZ-A0020 Revision 020 October 17, 2001

CALLAWAY PLANT

 \mathbf{x}_{j}

ĩ

ŝ

EMERGENCY PLAN IMPLEMENTING PROCEDURE

EIP-ZZ-A0020

MAINTAINING EMERGENCY PREPAREDNESS

RESPONSIBLE DEI	PARTMENT <u>Emerg</u>	ency Preparedn	ess
PROCEDURE OWN	IER <u>G. R. Pendergra</u>	ıff	
WRITTEN BY	G. R. Pendergraff		
PREPARED BY	<u>G. R. Pendergraff</u>		· · · · · · · · · · · · · · · ·
APPROVED BY	Warren A.	with	
			NENT CONTRACTOR
DATE ISSUED	-28-01	· · · · · · · · · · · · · · · · · · ·	AUCUUNTABLE HOLDER
This procedure conta	ins the following:		Doot
Pages	1	through	11
Attachments	1	through	6
Tables		through	<u>.</u>
Figures		through	
Appendices		through	
Checkoff Lists		through	
This procedure has	checkoff l	ist(s) maintained	l in the mainframe computer.
Conversion of comm	nitments to TRS reference	e/hidden text co	mpleted by <u>Revision Number</u> :
Non-T/S Commitme	nts 018	_	

EIP-ZZ-A0020 Rev. 020

TABLE OF CONTENTS

ē

ŝ

.

Section			Page Number
1	PUR	POSE AND SCOPE	1
2	RES	PONSIBILITIES	1
3	PRO	CEDURE	2
3.1	ANN	NUAL REVIEW	2
3.2	RAI (REI PRC	DIOLOGICAL EMERGENCY RESPONSE PLAN RP) AND EMERGENCY IMPLEMENTING DCEDURES (EIP)S MODIFICATIONS	3
3.3	EMI MO	ERGENCY RESPONSE FACILITY AND EQUIPMENT	Г 4
3.4	ON-	SITE EMERGENCY RESPONSE TRAINING	4
3.5	OFF	-SITE EMERGENCY RESPONSE TRAINING	5
3.6	DRI	LLS AND EXERCISES	6
3.7	DRI	LL AND EXERCISE DEVELOPMENT	7
3.8	TES	TS AND SURVEILLANCES	8
4	REF	ERENCES	10
5	REC	CORDS	11
Attachm Attachm Attachm Attachm Attachm	ent 1 ent 2 ent 3 ent 4 ent 5	Drill and Exercise Descriptions and Frequencies Exercise Development Items Drill and Exercise Objectives Drill Approval Form (CA-#594) Annual EAL Review (CA-#2433) DEDB Drill and Evaluated Exercise Security Agreemen	1 Page 2 Pages 2 Pages 1 Page 1 Page
Anavilli		TELCE Diffi and Evaluated Exceeding regreement	

(CA-#2553)

MAINTAINING EMERGENCY PREPAREDNESS

1 PURPOSE AND SCOPE

This procedure provides guidance for the review and maintenance of the Emergency Preparedness Program. This should include:

- Annual review of the Radiological Emergency Response Plan (RERP);
- Annual review of the Emergency Implementing Procedures;
- Oversight of the RERP Training Program; and
- An independent annual review of the Emergency Preparedness Program.

2 <u>RESPONSIBILITIES</u>

2.1 <u>NUCLEAR SAFETY REVIEW BOARD (NSRB)</u> (COMN 2681)

The Nuclear Safety Review Board is responsible for providing an independent annual review of the Radiological Emergency Preparedness Program.

2.2 SUPERINTENDENT, PROTECTIVE SERVICES

- 2.2.1 The Superintendent, Protective Services is responsible for ensuring an effective integrated program is maintained to provide for protection of the health and safety of the public in the event of a radiological emergency at the Callaway Plant. These responsibilities include:
- 2.2.1.1 Identification of candidates to become Emergency Response Personnel.
- 2.2.1.2 Notifying the Training Department of changes to the Emergency Response Organization (ERO), procedures, or equipment that effect RERP training activities.
- 2.2.1.3 Approval of RERP training objectives and review of substantial content changes to RERP training material.
- 2.2.1.4 Approval of changes to the RERP Training Program.

2.2.1.5 Development and conduct of Drills and Exercises.

2.3 <u>EMERGENCY PREPAREDNESS (EP)</u>

÷

Emergency Preparedness (EP) is responsible for identifying the Emergency Response Organization and for maintaining the Radiological Emergency Response Plan, Emergency Implementing Procedures, and Emergency Response Facilities for use by the Callaway Plant staff in responding to a radiological emergency. EP is also responsible for supporting State and Local government agencies with technical and training assistance to ensure their plans, procedures, facilities and personnel are prepared for response to a radiological emergency at the Callaway Plant.

2.4 TRAINING DEPARTMENT

The Training Department is responsible for preparation and conduct of periodic training as identified in **EIP-ZZ-A0066**, RERP Training Program, including assisting in the development of radiological emergency response drills.

2.4.1 <u>SUPERINTENDENT, TRAINING</u>

The Superintendent, Training is responsible for the overall administration of the RERP Training Program, as delineated in **EIP-ZZ-A0066**.

3 <u>PROCEDURE</u>

- 3.1 <u>ANNUAL REVIEW</u> (COMN 2681)
- 3.1.1 An independent review of the Emergency Preparedness Program SHALL be performed at least once every twelve (12) months under the direction and cognizance of the Nuclear Safety Review Board. Each review SHALL include an evaluation for adequacy of interfaces with State and local governments and of plant emergency drills, exercises, capabilities, and procedures.
- 3.1.2 Open findings identified SHALL be reviewed, investigated, and resolved in accordance with **APA-ZZ-00500**, Corrective Action Program.
- 3.1.3 Any portion of the review involving an evaluation for the adequacy of interfaces with State and local governments SHALL be made available to the affected governmental agency.

3.1.4 The results of the review of the Emergency Preparedness Program, along with recommendations for improvement, SHALL be documented and reported to Plant and company management, and retained for a period of 5 years.

3.2 <u>RADIOLOGICAL EMERGENCY RESPONSE PLAN (RERP)</u> <u>AND EMERGENCY IMPLEMENTING PROCEDURES (EIP)S</u> <u>MODIFICATIONS</u>

> <u>CAUTION</u>: No actions associated with a change to the RERP will be implemented until after ORC has approved the change notice or revision. CARS 200105886

3.2.1 The RERP and the letters of agreement/purchase orders listed in the RERP SHALL be reviewed annually and periodically updated as needed. (COMN 3924)

- 3.2.1.1 If the RERP is not revised as a result of the annual review, the review should be documented by placing a letter into the EP RERP file stating that the RERP was reviewed and no changes were needed.
- 3.2.1.2 The annual review of the Letters of Agreement/Purchase Orders should be documented by placing a letter in the EP RERP Letters of Agreement file. This letter should describe either how each letter was verified current or that the letter was updated as a result of the review.
- 3.2.1.3 All revisions and change notices to the RERP are prepared, reviewed, and processed in accordance with **KDP-ZZ-00400**, Emergency Preparedness 10CFR50.54(q) Evaluations, and **KDP-ZZ-00410**, Radiological Emergency Response Plan (RERP) Change Notice/Revision Process.
- 3.2.1.4 All changes to the RERP SHALL be made available to the State and appropriate local government emergency response agencies. (COMN 43392)
- 3.2.2 The EIPs SHALL be reviewed annually. (COMN 42346)
- 3.2.2.1 Modification or revisions to EIPs are reflected in the periodic update of the RERP.

- 3.2.2.2 Any changes or revision to the EIPs that affects the interface with State and/or local government emergency response plans should be made available to the affected governmental agency.
- 3.2.2.3 Telephone numbers listed in the EIPs SHALL be reviewed and updated at least quarterly as per the Plant's Surveillance Program. (COMN 3925)
- 3.2.3 The RERP and the EIP distribution lists SHALL be reviewed annually to ensure that the proper personnel, departments, and agencies are included on the lists as per the Plant's Surveillance Program. (COMN 20409)

3.3 <u>EMERGENCY RESPONSE FACILITY AND EQUIPMENT</u> MODIFICATION

- 3.3.1 When necessary changes, repairs, or modifications to Emergency Response Facilities are identified, the work should be accomplished by the appropriate Plant department following the procedures outlined in APA-ZZ-00320, Initiating and Processing Work Requests.
- 3.3.2 If the change or modification is of such a degree as to require a design change to the Emergency Response Facility, the change or modification MUST be accomplished following the guidance of **APA-ZZ-00600**, Design Change Control.

3.4 <u>ON-SITE EMERGENCY RESPONSE TRAINING</u> (COMN 3907)

On-site emergency response training is conducted in accordance with **EIP-ZZ-A0066**. It covers the training provided for both Emergency Response Personnel and Non-Emergency Response Personnel.

3.4.1 NON-EMERGENCY RESPONSE PERSONNEL

Non-Emergency Response Personnel are those personnel who are granted unescorted access to the Callaway Plant, but who do not have designated responsibilities in the Emergency Response Organization. Non-Emergency Response Personnel SHALL successfully complete GET training (Callaway Orientation – T8.0030.6/8). This training includes duties and responsibilities of emergency response and non-emergency response personnel, emergency classifications, assembly areas, alarms, emergency response actions and accountability/evacuation. (COMN 3905)

3.4.2 <u>EMERGENCY RESPONSE PERSONNEL</u> (COMN 42658)

Emergency Response Personnel are selected and assigned to a position in the Emergency Response Organization per **EIP-ZZ-A0001**, Emergency Response Organization. Prior to assuming a position in the Emergency Response Organization (ERO), each individual will complete required initial training.

3.4.2.1 RERP INITIAL TRAINING

RERP Initial Training required for each ERO position is identified in **EIP-ZZ-A0066**. (COMN 3905)

3.4.2.2 RERP CONTINUING TRAINING

RERP Continuing Training should be based, as appropriate, on changes to applicable procedures and processes, Plant and industry experiences, and the results of previous drills and Exercises.

- 3.4.2.2.1 Drills and Exercises may be utilized as training activities where familiarity with specific RERP duties and/or functions can be demonstrated.
- 3.4.2.2.2 The applicable provisions of **EIP-ZZ-A0066** MUST be met when utilizing drills and Exercises to meet training requirements.

3.5 OFF-SITE EMERGENCY RESPONSE TRAINING

- 3.5.1 Callaway Plant coordinates with SEMA in emergency planning and emergency response with four (4) counties which partially lie within the Plume Exposure Pathway (10-mile EPZ) and the city of Fulton. The county jurisdictions are Callaway, Gasconade, Montgomery and Osage Counties. (COMN 42673)
- 3.5.2 Off-site emergency response training is the responsibility of the Missouri State Emergency Management Agency (SEMA) in conjunction with the Missouri Department of Health (DOH), and local county agencies. Callaway Plant provides support to these agencies as requested.
- 3.5.3 Training for off-site fire fighting personnel includes radiological hazards, which may be encountered while fighting fires in the Plume Exposure Pathway. (COMN 42508)

3.5.4 For those local support services who may enter the site, Callaway Plant provides training which also includes site access procedures and the identity (by position title) of the individual who requests the services. (COMN 42722)

3.6 DRILLS AND EXERCISES

- 3.6.1 Emergency Preparedness has overall responsibility for conducting RERP drills and exercises on site. Additional guidance on conducting RERP drills and exercises is contained in **KDP-ZZ-02001**, Drill and Exercise Program. (COMN 3917)
- 3.6.2 Periodic drills SHALL be conducted in accordance with Attachment 1, Drill and Exercise Descriptions and Frequencies, to evaluate emergency response capabilities and to test specific aspects of emergency response plans, implementing procedures, and equipment. These drills may be incorporated with the RERP Continuing Training when the situation allows. (COMN 3916)
- 3.6.3 Unannounced drills MUST have prior approval.
- 3.6.3.1 Approval should be obtained from departments most affected by the drill.
- 3.6.3.2 Approval MUST be obtained from a Manager or above.
- 3.6.3.3 Approval from the Shift Supervisor (SS) that is on shift at the time of the drill should be obtained for drills when on-shift personnel in the power block are expected to actively participate. If the on-shift Shift Supervisor is to actively participate, then prior approval should be obtained from a different Shift Supervisor.
- 3.6.4 To maintain the confidentiality of unannounced drills and exercises, personnel requiring knowledge of the drill or exercise should sign the Unannounced RERP Drill and Exercise Security Agreement (CA-#2553), Attachment 6. This includes controllers and evaluators from outside the EP Department. This also includes pre-staged personnel who have knowledge that could affect the evaluation of the drill or exercise.
- 3.6.5 Drills are not required to be conducted independently and may be conducted as part of an integrated drill or exercise.
- 3.6.6 Actual events that may cause the activation of the Radiological Emergency Response Plan (RERP) may not be substituted for a required drill or exercise.

- 3.6.7 Some drills are scheduled while others are unannounced. (COMN 3916)
- 3.6.8 Periodically arrangements SHALL be made for federal agencies to participate in Exercises. (COMN 3967)
- 3.6.9 Provisions SHALL be made to start an Exercise between 1800 and 0400 once every six (6) years. (COMN 3968)
- 3.7 DRILL AND EXERCISE DEVELOPMENT

ĩ

Radiological Emergency Response Drills and Exercises are developed using **KDP-ZZ-02001** and the guidance in Attachment 2, Exercise Development Items, and the following guidelines:

- 3.7.1 Objectives SHALL be selected to include those listed in Attachment 3, Drill and Exercise Objectives, as necessary to meet the stated frequency requirements for each objective. (COMN 3918)
- 3.7.2 Development of off-site objectives and guidelines should be coordinated with appropriate State and local agencies, if applicable.
- 3.7.3 Exercises should include mobilization of appropriate Callaway Plant, State and local organizations to verify their ability to respond to an accident scenario, which requires implementation of on-site and off-site radiological emergency response plans.
- 3.7.4 Exercise and drill scenarios SHALL be varied to assure that all the major elements of on-site and off-site emergency response plans and organizations are tested within a six-year period. (COMN 3917)
- 3.7.5 Exercise objectives, extent of play, and scenarios are submitted to the Nuclear Regulatory Commission (NRC) and Federal Emergency Management Agency (FEMA) in accordance with **KDP-ZZ-00510**, Exercise Submittals to NRC/FEMA.
- 3.7.6 A Lead Controller, as designated by the Superintendent, Protective Services, SHALL be responsible for the overall conduct of Radiological Emergency Response Drills and Exercises. Utility provided controllers and evaluators SHALL be trained and briefed prior to the drill/exercise. (COMN 3919)

- 3.7.7 No actions should be performed during a drill or exercise which have the potential for affecting Plant operations.
- 3.7.8 Drill/exercise activities should be placed on hold or suspended, if an actual emergency arises.
- 3.7.9 Upon completion of drills and exercises, critiques SHALL be conducted. The lead facility participant in each Emergency Response Facility (Recovery Manager, Emergency Coordinator, Shift Supervisor, etc.) is normally designated to conduct a critique with the controllers, evaluators, and participants. (COMN 3920, COMN 42978)
- 3.7.10 The NRC and, if applicable, FEMA SHALL be invited to evaluate and critique the exercise. (COMN 3920)
- 3.7.11 The facility lead controller should record or have recorded any programmatic comments or deficiencies identified.
- 3.7.12 Emergency Preparedness collects all facility critiques and dispositions deficiencies and areas for improvement in accordance with Plant procedures. (COMN 3920)
- 3.7.13 Upon completion of a drill or exercise, forward a copy of the Drill Approval Forms (if applicable), Drill/Exercise Objectives, and Critique to Document Control as QA Records.
- 3.8 <u>TESTS AND SURVEILLANCES</u>
- 3.8.1 <u>EMERGENCY EQUIPMENT KITS</u>
- 3.8.1.1 Emergency equipment kits are located in various Emergency Response Facilities and contain supplies, equipment and procedures that may be utilized during an emergency.
- 3.8.1.2 Health Physics supplies and equipment contained in the emergency equipment kits are inventoried and maintained by the Health Physics Department, per **HTP-ZZ-05007**, Maintenance and Inventory of HPOPS Emergency Equipment Kits, and **HTP-ZZ-07003**, Maintenance and Inventory of Health Physics Technical Support Emergency Equipment Kits.

3.8.2 <u>EMERGENCY PACKETS</u>

Emergency packets containing copies of procedures, forms, and clerical supplies are maintained in accordance with **KDP-ZZ-00300**, Emergency Packet Maintenance.

3.8.3 EMERGENCY TELEPHONE DIRECTORY (ETD)

The ETD is part of the Callaway Plant Personnel Data Base System. A document copy of the ETD can be printed upon demand. The ETD is printed and distributed quarterly per the Plant's Surveillance Program.

3.8.4 <u>PUBLIC ALERT SYSTEM</u>

A Public Alert System is maintained to provide prompt notification of the public in the event of an emergency at the Callaway Plant. The system is tested monthly in accordance with the Plant's Surveillance Program.

3.8.5 PUBLIC INFORMATION PROGRAM

A Public Information Program, in cooperation with Corporate Communications, is maintained to ensure that the general public and news media in the Plume Exposure Pathway Emergency Planning Zone are provided with information regarding an emergency at the Callaway Plant on an annual basis. The Public Information Program is maintained in accordance with the Plant's Surveillance Program. (COMN 42507)

3.8.6 <u>COMMUNICATION TESTS</u>

Communications with Federal, State and local governments will be tested monthly. Once a quarter, this will be done transmitting a simulated emergency notification to ensure the content of the message is understood. Field monitoring team communications is tested annually from the EOF and Backup EOF. These tests are done from different sectors in the field in accordance with the Plant's Surveillance Program and also include the aspect of understanding message content.

3.8.7 EMERGENCY RESPONSE DATA SYSTEM (ERDS) TESTING

ERDS testing, involving actual Plant data transmission to the Nuclear Regulatory Commission, is an evolution that is scheduled with the NRC and performed quarterly in accordance with the Plant's Surveillance Program.

3.8.8 EMERGENCY ACTION LEVELS (EALs)

EALs SHALL be reviewed with State and local agencies on an annual basis and documented using Attachment 5, Annual EAL Review. (COMN 43393)

- 3.8.9 Tool kits are available in the Technical Support Center. They contain various mechanical, electrical, and instrument and control tools that may be used during an emergency. CARS 200104423
- 3.8.9.1 Work Control Electrical, Work Control Mechanical, and Instrument & Control (I&C) Departments maintain the tool kits in accordance with the Preventive Maintenance Program.

4 **REFERENCES**

- 4.1 10CFR50.47
- 4.2 10CFR50.54
- 4.3 10CFR50, Appendix E
- 4.4 NUREG 0654, FEMA-REP-1
- 4.5 APA-ZZ-00320, Initiating and Processing Work Requests
- 4.6 APA-ZZ-00500, Corrective Action Program
- 4.7 APA-ZZ-00600, Design Change Control
- 4.8 EIP-ZZ-A0001, Emergency Response Organization
- 4.9 **EIP-ZZ-A0066**, RERP Training Program
- 4.10 **FPP-ZZ-00009**, Fire Protection Training Program
- 4.11 **HTP-ZZ-05007**, Maintenance and Inventory of HPOPS Emergency Equipment Kits
- 4.12 **HTP-ZZ-07003**, Maintenance and Inventory of Health Physics Technical Support Emergency Equipment Kits
- 4.13 **KDP-ZZ-00300**, Emergency Packet Maintenance
- 4.14 **KDP-ZZ-00400**, Emergency Preparedness 10CFR50.54(q) Evaluations

EIP-ZZ-A0020 Rev. 020

- 4.15 **KDP-ZZ-00410**, Radiological Emergency Response Plan (RERP) Change/Revision Process
- 4.16 **KDP-ZZ-00510**, Exercise Submittals to NRC/FEMA
- 4.17 **KDP-ZZ-02001**, Drill and Exercise Program

5 <u>RECORDS</u>

- 5.1 QA RECORDS
- 5.1.1 Annual EP Review Records (File G170.0046)
- 5.1.2 Drills/Annual Exercises (objectives, critiques, and approval forms) (File K235.0001)
 - 5.1.3 Letter documenting annual review of RERP (File A210.0038)
 - 5.1.4 Letter documenting annual review of RERP Letters of Agreement (File K190.0011)
 - 5.1.5 Annual EAL Review (File A190.0001)
 - 5.1.6 Callout Tests/Drills (File K231.0024)
 - 5.1.7 Pre-Exercise Drills (File K233.0000)
 - 5.1.8 Medical Emergency Drills (File K234.0001)
 - 5.1.9 Remedial Exercises (File K235.0002)
 - 5.1.10 Other Drills (File K234.0000)
 - 5.1.11 Unannounced RERP Drill Approval Form (K235.0001)
 - 5.1.12 Unannounced RERP Drill and Exercise Security Agreement (File K235.0001/K235.0002)

EIP-ZZ-A0020 Rev. 020

DRILL AND EXERCISE DESCRIPTIONS AND FREQUENCIES

These are minimum frequencies required. Additional drills may be held as determined by the Superintendent, Protective Services.

COMN	TYPE	DESCRIPTION	FREQUENCY	RESPONSIBLE DEPT.
3917	Exercise	The Exercise tests the integrated capability of the Callaway Plant emergency response organizations to respond to an emergency. (State and local emergency organizations are tested as required by Federal Guidelines.)	Biennial	Emergency Preparedness
3917		The Exercise SHALL provide for periodic participation by Federal Emergency Response agencies.	Periodic	Emergency Preparedness
3968		Provisions SHALL be made to start an exercise between 6:00 p.m. and 4:00 a.m.	At least once every 6 years.	Emergency Preparedness
20602	Call-Out Test	This test verifies the ability of the ERO to be contacted and estimate their arrival at their specific Emergency Response Facility.	Quarterly (Test)	Emergency Preparedness
	Call-Out Drill	This drill verifies the ability to actually augment the emergency response organization as specified in the RERP.	At least once every 6 years (Drill)	Emergency Preparedness
3921	Medical Emergency Drill	This drill involves the response to simulated contaminated injured/ill individuals providing for periodic participation by off-site ambulance services and medical treatment facilities.	Annually	Emergency Preparedness and SEMA
3921	Medical Emergency MERT Drill	This drill involves response to simulated medical emergencies providing participation by the onsite Medial Emergency Response Team (MERT). These drills are conducted in accordance with the Fire Protection Training Program, FPP-ZZ-00009 .	At least annually	Fire Protection
3923	Health Physics Drill	This drill involves the response to, and analyses of, simulated elevated airborne and liquid samples, and direct radiation measurements in the environment.	Semi-Annually	Emergency Preparedness
3922	Radiological Monitoring Drill	Plant environs and radiological monitoring drills (on and off site) are conducted annually. These drills include collection and analysis of all sample media (e.g., water, vegetation, soil, and air) and provisions for communications and record keeping.	Annually	Emergency Preparedness
	Fire Drills	These drills are conducted in accordance with the Fire Protection Program.	Periodically	Fire Protection

EXERCISE DEVELOPMENT ITEMS

Lead Controller Responsibilities

- 1. Drill Approval Form Attachment 4 (if applicable)
- 2. Drill/Exercise Scenario Package Contents (COMN 42506)
 - a. On-site Objectives
 - b. On-site Guidelines and Extent of Play
 - c. Controllers Instructions
 - d. Controller List
 - e. Participant List
 - f. On-site Evaluation Material
 - g. Narrative Summary
 - h. Logs, Watch Turnover Material, Work Packages and RWPs etc.,
 - i. On-site Sequence of Events
 - j. Simulator Actions
 - k. Initial Conditions
 - l. On-site Messages
 - m. On-site Mini-scenarios
 - n. Plant parameters, Rad Monitor Data, Chemistry Data, and other Simulated Plant Data
 - o. Meteorological Date
 - p. In-Plant Survey, Perimeter, and Field Monitoring Rad Data
 - q. Ingestion Pathway Rad Data
- 3. Identify On-site Participants, Controllers, and Evaluators
- 4. Complete On-site Controller/Evaluator Briefings/Training
- 5. Schedule and Prepare Simulator
- 6. Scenario Printing and Distribution
- 7. Prepare and Distribute Accountability Exemption Lists
- 8. Provide for and Coordinate Controller Communications
- 9. Initial Condition Briefings

<u>NOTE:</u> Not every item listed is applicable for each drill or exercise.

EXERCISE DEVELOPMENT ITEMS

Emergency Preparedness Department Off-Site Responsibilities

- 1. Drill/Exercise Scenario Package Contents
 - a. Off-site Objectives
 - b. Off-site Guidelines and Extent of Play
 - c. Off-site Evaluation Material
 - d. Off-site and Public Information Sequence of Events
 - e. Off-site, Public Information, Media Monitor, and Rumor Control Messages
 - f. Off-site Mini-Scenarios
- 2. Submittal of Objectives and Guidelines and Scenario to the NRC and FEMA.
- 3. Identify Off-site Controllers and Evaluators
- 4. Schedule Off-site Controller and Evaluator Briefing/Training
- 5. Schedule NRC and FEMA Entrance and Exit Meetings
- 6. Schedule Facilities (Except Simulator)
- 7. Place Drill/Exercise Meal Orders
- 8. Drill/Exercise Critiques

<u>NOTE:</u> Not every item is applicable for each drill or exercise.

DRILL AND EXERCISE OBJECTIVES

I. Objectives That SHALL Be Met Each Year (COMN 3918)

- A. Demonstrate the ability to perform accident detection and assessment.
- B. Demonstrate the ability to classify an emergency.
- C. Demonstrate the ability to notify on-site and off-site emergency response personnel.
- D. Demonstrate primary communications between the plant, its various facilities, and other emergency response organizations.
- E. Demonstrate emergency radiological controls.
- F. Demonstrate the ability to make Protective Action Recommendations to off-site authorities.
- G. Demonstrate the ability to augment emergency response organizations.
- H. Demonstrate the ability to staff the On-Shift Emergency Response Organization.

II. Objectives That SHALL Be Met Over a 6-Year Period

- A. Demonstrate emergency response capabilities during varied conditions. (Off-hours staffing 6 p.m. to 4 a.m.; various weather conditions; unannounced). (COMN 3968)
- B. Demonstrate the activation of the Joint Public Information Center (JPIC) and dissemination of information to the public.
- C. Demonstrate the ability to use the Fire Brigade.
- D. Demonstrate the use of a Medical Emergency Response Team (MERT) and/or search and rescue teams.
- E. Demonstrate the ability to provide Emergency Medical Services (EMS) for contaminated injured individuals. (COMN 3921)
- F. Demonstrate that security can allow for prompt access of emergency equipment and support.
- G. Demonstrate the availability of backup communication capabilities.
- H. Assist the State of Missouri in performing rumor control.
- I. Demonstrate the use of emergency power (where not a part of plant safety systems, e.g. Technical Support Center (TSC)).
- J. Demonstrate the ability to evacuate Emergency Response Facilities (ERFs) and relocate to backup ERFs where applicable.
- K. Demonstrate the ability to provide support to off-site agencies for environmental sampling and analysis, and protective action recommendations for the Ingestion Pathway.
- L. Demonstrate the ability to perform field monitoring, including soil, vegetation, and water samples.
- M. Demonstrate the ability to determine the magnitude and impact of a radiological release.
- N. Demonstrate the ability to monitor radioactive iodines in off-site environs. (COMN 43477)
- O. Demonstrate the ability to provide for the use of potassium iodide.
- P. Demonstrate the ability to account for site personnel.
- Q. Demonstrate the ability to perform plant recovery and plant re-entry.

EIP-ZZ-A0020 Rev. 020

UNANNOUNCED RERP DRILL APPROVAL FORM

-

Drill Type	Dril	1 Date
Start Time		
Expected Duration		
Brief Drill Scenario:		
Prepared By:		
Name	, Title	, Date
Approved by Responsible Department(s)		
	Signature	Date
	Signature	, Date
	Signature	, Date
Manager Approval	Signature	, , Date
Shift Supervisor Approval*		,
	Signature	Date

*Should be obtained if personnel on-shift in the power block are expected to participate.

EIP-ZZ-A0020 Rev. 020

Annual EAL Review

Date

 EIP-ZZ-00101, Emergency Action Levels (EALs), have been reviewed with me and I understand this fulfills the annual review requirement. (COMN 43393)

Callaway County

County Commissioner/EMD

County Commissioner/EMD

County Commissioner/EMD

Gasconade County

Montgomery County

Osage County

State Emergency Management Agency

SEMA Director/State Representative

County Commissioner/EMD

File A190.0001 (EIP-ZZ-00101) Pa

ATTACHMENT 5 CA-#2433

Unannounced RERP Drill and Exercise Security Agreement

I acknowledge that I have acquired specialized knowledge about the scheduled drill or Exercise indicated below. I agree that I will not knowingly divulge any information about this drill or Exercise scenario to any unauthorized person.

An unauthorized person is anyone that may be called upon to participate as a responder in the scheduled drill or Exercise. (Unannounced drills are considered scheduled drills or Exercises.)

I understand that as a controller, evaluator, pre-designated participant required to be staged, I will keep and control any scenario-related materials, including the dates for unannounced drills or Exercises, in a secured manner. Additionally, I acknowledge that if I allow disclosure of information or material of this nature to unauthorized persons, it could result in the failure of the drill or Exercise.

Scheduled drill/Exercise Date: _____

Printed Name	Signature	Date
	<u></u>	
		·····

File K235.0001/K235.0002

ATTACHMENT 6 CA-#2553

EIP-ZZ-00213 Revision 020 October 30, 2001

CALLAWAY PLANT

EMERGENCY PLAN IMPLEMENTING PROCEDURE

EIP-ZZ-00213

TECHNICAL ASSESSMENT

PROCEDURE OWN	ER <u>W. R. Bevard</u>		
WRITTEN BY	W. R. Bevard		
PREPARED BY	W. R. Bevard		
APPROVED BY	Warren A.	with	
		(NO	V 2 8 2001
DATE ISSUED This procedure conta	<u>1-28-01</u> ins the following:	NO AU	V 2 8 2001 V 2 8 2001 HOLDER 338U
DATE ISSUED <u>1</u> This procedure contai Pages	<u>1-28-01</u> ins the following:	through	V 2 8 2001 V 2 8 2001 HOLDER 338U 6
DATE ISSUED This procedure contai Pages Attachments	<u>1-28-01</u> ins the following: 1	through through	V 2 8 2001 V 2 8 2001 COUNTABLE HOLDER <u>6</u> <u>4</u>
DATE ISSUED This procedure contai Pages Attachments Tables	<u>1-28-01</u> ins the following: <u>1</u> 1	through through through	V 2 8 2001 V 2 8 2001 COUNTABLE HOLDER <u>6</u> <u>4</u>
DATE ISSUED This procedure conta: Pages Attachments Tables Figures	<u>1-28-01</u> ins the following: 1	through through through through through	V 2 8 2001 COUNTABLE HOLDER <u>6</u> <u>4</u>
DATE ISSUED This procedure conta Pages Attachments Tables Figures Appendices	<u>1-28-01</u> ins the following: 1	through through through through through through through	V 2 8 2001 V 2 8 2001 COUNTABLE HOLDER <u>6</u> <u>4</u>
DATE ISSUED This procedure conta Pages Attachments Tables Figures Appendices Checkoff Lists	<u>1-28-01</u> ins the following: 1 1	through through through through through through through through through	V 2 8 2001 COUNTABLE HOLDER <u>6</u> <u>4</u>

TABLE OF CONTENTS

Section		Page Number
1	PURPOSE AND SCOPE	1
2	RESPONSIBILITIES	1
2.1	TECHNICAL ASSESSMENT COORDINATOR	1
2.2	TSC ENGINEERING STAFF	2
3	PROCEDURE	2
3.2	MAINTAINING THE PLANT STATUS BOARDS	4
3.3	EMERGENCY RESPONSE DATA SYSTEM DEACTIVATION	5
4	FINAL CONDITIONS	5
5	REFERENCES	6
6	RECORDS	6

Attachment 1	Plant Status Board	1 page
Attachment 2	Plant Status Board Key	1 page
Attachment 3	Plant Status Board/PCS Cross Reference	4 pages
Attachment 4	Plant Status Board/Main Control Board Cross Reference	8 pages

TECHNICAL ASSESSMENT

1 <u>PURPOSE AND SCOPE</u>

1.1 To provide guidance to the Technical Support Center (TSC) engineering staff in performing technical assessment and maintaining plant status boards during an emergency. Also provides guidance for actions necessitated in the event of Plant Computer System (PCS) failure.

2 **RESPONSIBILITIES**

- 2.1 TECHNICAL ASSESSMENT COORDINATOR
- 2.1.1 The Technical Assessment Coordinator (TAC):
- 2.1.1.1 The TAC reports to the Emergency Coordinator (EC). The TAC is responsible for technical assessment of Plant conditions to identify EALs and emergency mitigating recommendations to the EC. The TAC is also responsible for coordinating Protective Action Recommendations (PARs) consistent with Plant Conditions with the Recovery Manager and Dose Assessment Coordinator in the EOF prior to the arrival of the Protective Measures Coordinator (PMC) or Plant Assessment Coordinator (PAC). (COMN 3333)
- 2.1.1.2 Provides the TSC Engineering Staff with direction and control.
- 2.1.1.3 Ensures coordination with other groups and sources of information.
- 2.1.1.4 Provides oversight and direction of the TSC until the EC arrives.
- 2.2 <u>TSC LEAD ENGINEER (TLE)</u>
- 2.2.1 The TLE reports to the Technical Assessment Coordinator in the TSC. The TLE is responsible for assisting the TAC in directing and controlling the Engineering staff. (COMN 3351)

2.3 <u>TSC ENGINEERING STAFF</u>

The TSC Engineering Staff reports to the Technical Assessment Coordinator in the TSC. They are responsible for diagnosing and analyzing potential and actual Plant problems, and providing recommended courses of action to the Technical Assessment Coordinator. These responsibilities include; assessment of core physics, thermal hydraulics, and general plant conditions. They may be dispatched to Plant areas for surveillance purposes as directed by the Technical Assessment Coordinator.

2.4 ENGINEERING STATUS BOARD LOGKEEPERS (ESL)

2.4.1 The ESLs report to the TAC and are responsible for maintaining the logs and status boards for the Technical Assessment Group.

3 <u>PROCEDURE</u>

- 3.1.1 Place the TSC HVAC system in recirculation per **OOA-UB-00005**.
- 3.1.2 Use EIP-ZZ-00217 to activate the Emergency Response Data System (ERDS) as soon as possible, but NOT later than one hour after a declared plant Alert or higher emergency, The ERDS can be activated from the Control Room or from the Technical Support Center Plant Computer terminals. (COMN 42625)
- 3.1.3 Develop strategies, using Severe Accident Management Guidelines (SAMGs), for severe accident conditions.
- 3.1.4 Evaluate the condition of the Reactor Core using: (COMN 42534)
 - a. Radiation Monitoring System.
 - b. Plant instrumentation and Plant Computer System.
 - c. Post accident sampling results.

3.1.5	Assess essential safety-related systems using:	
-------	--	--

- a. Appropriate Callaway Plant drawings.
- b. Plant Operating/Emergency, Engineering, I & C, and Maintenance procedures, and Severe Accident Management Guidelines.
- c. The Plant Computer System or parameters as given through communications.
- d. The Callaway Plant Final Safety Analysis Report and Callaway Technical Specifications.
- e. Equipment technical manuals.
- f. Information obtained from other sources.
- 3.1.6 Assist the Control Room staff by relieving the reactor operators of peripheral duties such as:
 - a. Plotting key parameters to backup or assist in trend analysis, as requested.
 - b. Evaluating the adequacy of natural circulation flow or heat sink efficiency.
- 3.1.7 Coordinate the design and installation of temporary modifications.
- 3.1.8 Recommend any changes to plant operations to mitigate damage or to place the plant in a safe mode of operation.
- 3.1.9 Dispatch engineers to plant areas for surveillance purposes or to assist repair teams as required. (COMN 3351)
- 3.1.10 Assist in the preparation of emergency repairs including material suitability and/or procedure preparation.
- 3.1.11 Monitor Emergency Action levels per **EIP-ZZ-00101**, Classification of Emergencies.
- 3.1.12 Prior to the arrival of the Protective Measures Coordinator (PMC) and the Plant Assessment Coordinator (PAC) to the EOF, monitor criteria for protective action recommendations per **EIP-ZZ-00212**, Protective Action Recommendations.

3.1.13	Provide an estimation of radiological release duration and core
	damage assessment to the Health Physics Coordinator, Dose
	Assessment Coordinator and Emergency Coordinator.

- 3.1.14 Upon entry into the recirculation phase of RHR:
- 3.1.14.1 Direct the Chemistry Coordinator to obtain samples from the RWST once every 12 hours, using **CSP-ZZ-07540**.

NOTE:Local samples should be taken from BN-V-0023
and BN-V-0029. Increased activity indicates
valve leakage back to the RWST.

- 3.1.14.2 Inform the Health Physics Coordinator of probable increase in Auxiliary Building radiation levels and have him inform any Teams in the field.
- 3.1.14.3 Inform the Health Physics Coordinator of possible valve leakage to the RWST so that Health Physics support for sampling, sample counting, and possible release calculations can be arranged.
- 3.2 MAINTAINING THE PLANT STATUS BOARDS
- 3.2.1 Maintain the plant status boards using the Plant Computer.
- 3.2.1.1 Call up the plant status boards displays on the Plant Computer to obtain plant status. The information needed to maintain the plant status boards is contained on these displays.
- 3.2.1.1.1 On the Plant Computer command line enter PSB (Plant Status Board). This brings up the first screen and from that you can move to the next screen.
- 3.2.1.1.2 Either print each display or, if the printer is inoperable, transfer the data to Attachment 1, Plant Status Board.
- 3.2.1.2 If data points are not available on the PSB displays, they can be obtained from the Plant Computer using Attachment 3.

NOTE:A cross reference of the information required for
the status board with Plant Computer data points
is available by using Attachment 2, Plant Status
Board Key and Attachment 3, Plant Status Board
/ Plant Computer Cross Reference.

3.2.1.3	If the PSB data is questionable Attachment 4 may be used to
	compare redundant but sometimes less desirable data. If data
	remains questionable the data should be annotated with a question
	mark to indicate the data is questionable. (SOS 97-0904)

- 3.2.2 If the Plant Computer is inoperable.
- 3.2.2.1 The Technical Assessment Coordinator should designate and direct the necessary individuals to report to the Control Room and provide regular plant status board updates. (SOS 97-0904)
- 3.2.2.1.1 The individuals reporting to the Control Room should establish communication with the TSC upon arrival.
- 3.2.2.2 Using Attachment 4, Plant Status Board / Main Control Board Cross Reference to assist in collecting the data and Attachment 2, Plant Status Board Key, complete Attachment 1 in as close to 15 minute intervals as practical.

<u>NOTE</u>: Relay of Attachment 1 information from the Control Room can be done using the fax machine.

- 3.2.2.3 Relay the information on the completed Attachment 1 to the TSC Engineering Staff to update the plant status boards.
- 3.2.3 As much as possible and appropriate, arrows should be placed next to specified values on the PSB to indicate upward $\{\uparrow\}$ or downward $\{\downarrow\}$ trends.
- 3.3 EMERGENCY RESPONSE DATA SYSTEM DEACTIVATION
- 3.3.1 The ERDS is deactivated on the Plant Computer terminal by going to the ERDS display and pressing <F3>. Pressing <F3> terminates the modem program and returns the Plant Computer terminal to the user.

4 <u>FINAL CONDITIONS</u>

4.1 The Emergency Coordinator or the designee has determined that technical assessment is no longer required.

5 <u>REFERENCES</u>

- 5.1 Callaway Plant Radiological Emergency Response Plan (RERP)
- 5.2 NRC Information Notice 91-56
- 5.3 NUREG-1394, Rev. 1 Emergency Response Data System (ERDS) Implementation
- 5.4 ETP-ZZ-02000 TECHNICAL ASSESSMENT
- 5.5 10 CFR 50, Appendix E, part V
- 5.6 EIP-ZZ-00217 Emergency Response Data System Activation
- 5.7 **CSP-ZZ-07540** Water Storage Tank Activity
- 5.8 Severe Accident Management Guidelines

6 <u>RECORDS</u>

<u>NOTE</u>: Position logs, screen prints, forms, memos, notes, etc. should be attached to each Coordinator's checklist and turned in to the Admin Coordinator and/or Emergency Preparedness (EP).

- 6.1 QA RECORDS
- 6.1.1 Plant Status Report, Attachment 1 (K171.0010)
- 6.2 <u>COMMERCIAL RECORDS</u>

None

(
EIP-ZZ-00213	
Rev. 020	

		_						<u>PL</u>	ANT STAT	US BOARD									
UPDATE	UPDATE TIME: EMERGENCY PROCEDURE: DESCRIPTION																		
RCS CONDITIONS					STEAM GENERATORS				ECCS STATUS				CONTAINMENT CONDITIONS						
Rx TRIP	Rx PWR	RCS PRES	WR SS.	<u>RVLIS</u> DYNAMI %	SUB- C COOLING 6 (NEG. IF			р		D	ON/OFF	TDAINIA	TDAIN 'B'	FLOW	PRESS	. темі	P HUMIDIT	Y RAD LV	L H2 CONC
date	%			STATIC	SUPER- HEAT)		A			D D	ONOT			(GPM)	nsig			R/HR	
ume HIGHEST CORE	PZR LVL			⁷	<u>• </u>	LVL					ССР				CTMT SPRAY PUMP 'A': ON / OFF)FF
EXIT T/C				PRESS	PSIG	% NR			:		NCP		NIA		CTMT SPRAY PUMP 'B'; ON / OF			OFF	
°F	%	mC	i/cc	LEVEL	%						NCF		N/A						
PZR POR <u>'A'</u>	A' PO BLOCK	RV VLV	PZR 	PORV <u>B'</u>	'B' PORV BLOCK VLV	LVL					SI					CTMT R	ECIRC SUM	'A';	IN.
OP/CL	OP/C	CL	OP	/CL	OP / CL	/6 WK										CTMT R	ECIRC SUM	' 'B';	_ IN.
RCS LOOP	A	B	3	С	D	PRESS PSIG					RHR								
Thot (wr/nr)						MAIN FEED FLOW					SI ACC 'A' %	SI ACC 'B' %	SI ACC 'C' %	SI ACC 'D' %	ESI ACTU N	FAS JATIO IS	CSF STATUS	COLOR	REASON (if not green)
Tcold (wr/nr)						AUX FEED FLOW					psig	j psig	F	WST LVL	SIS	CIS-A	SUBCRIT		
LOOP FLOW (%)						Klbm/Hr STEAM FLOW					ELEC	CTRICAL S	YSTEMS S	<u>ratus</u>	CIS-B	CSAS	CORE COOLING		
RCP (ON/OFF/ UNAVAIL)						Klbm/Hr MSIV OP/CL					SWYD BUS	5 A SWYD B (V)(US B KV)	NK01 VDC	CPIS	MSLIS	HEAT SINK		
	CONTRO	DL RO	D POS	SITIONS	<u> </u>	FWIV OP/CL			-		<u>D/G 'A'</u> ON/OFF/ UNAVAII	<u>D/G 'I</u> ON/OF UNAVA	<u>8'</u> F/ IL	NK02 VDC	FWIS	AFAS	RCS INTEGRITY		
CTRL BANK A	CTRL BANK B	CTI BAN	RL K C	CTRL BANK E		S/G ATM PORV					NB01 ENERGIZI	NB02 ED ENERGI		NK03 VDC	CRVIS	FBIS	СТМТ		
S/D BANK A	S/D BANK B	S/J BAN	D KC	S/D BANK E	<u>S/Ð</u> D BANK E	MDAFP '/ MDAFP '/ TDAFP	A' ON/OFF/ B' ON/OFF/	I UNAVAIL UNAVAIL	сят 	`LVL %	PA01 ENERGIZI YES/NO	ED ENERGI	<u>ZED</u>	NK04 VDC		1	RCS INVEN- TORY		
						IDARY	011/0FF/	UNATAL	NOTES AND N	IISC ITEMS	1		I		L		L		L
Tank V H H	Yolumes Pressurizer: 12 PRT: 132.6 gal Accumulators:	0 gal/% (1/% 64 7.291 ga	Cold -88% al/%	62 gal/% H	Hot V R C	CT: 20.4 gal/% WST: 4007.23 ga ST: 4608.85 gal/%	W% % Notify	CTMT Normal CTMT Emerger Instrument Tunn Chemistry an	Sumps: 15.6 gal/ icy Sumps: 40 ga iel Sump: 15 gal/ d HP Coordin	% or 10 gal/in al/% <96 in % vator when ent	tering recirc	nhase							
						;	rionry	Saturday an	D	1 C 1									

(
EIP-2	LL-00213
Rev.	020

							PLAN	T STATUS	BOARD KI	EY									
UPDATE	TIME:				EMERGENCY PROCEDURE:					DESCRIPTION									
RCS CONDITIONS					STEAM GENERATORS					ECCS STATUS					CONTAINMENT CONDITIONS				
Rx TRIP (1) date (1) time	Rx PWR (2)_%	RCS WR PRESS. (3) psig	<u>RVLIS</u> DYNAMIC (4) % STATIC (4)%	SUB- COOLING (NEG. IF SUPER- HEAT) (5)°F		A	В	С	D	ON/OFF	TRAIN 'A'	TRAIN 'B'	FLOW (GPM)	PRESS _(51) psig	. TEMI (52)_ °F	HUMIDIT	Y RAD LV (54) 	⁷ L H2 CONC - (55)%	
HIGHEST CORE EXIT T/C (6) °F	PZR LVL	RCS ACTIVITY (8) mCi/cc	TEMP PRESS	<u>PRT</u> (9)°F (9)PSIG (9)%	LVL % NR	(18)	(18)	(18)	(18)	ССР NСР	(29) (30)	(29) N/A		CTMT SPRAY PUMP 'A'; ON / OFF (56) CTMT SPRAY PUMP 'B'; ON / OFF				off Off	
PZR PORV <u>'A'</u> (10) OP/CL	/ 'A' PO BLOCK (10) OP / (RV PZR VLV CL OI	t PORV <u>'B'</u> 1 (11) P / CL	'B' PORV BLOCK VLV (11) OP / CL	LVL % WR	(19)	(19)	(19)	(19)	SI	(31)	(31)			CTMT R	ECIRC SUMI (57) ECIRC SUMI	Р'А'; Р'В';	_ IN. _ IN.	
RCS LOOP	A	В	С	D	PRESS PSIG	(20)	(20)	(20)	(20)	RHR	(32)	(32)							
Thot (wr/nr)	(12)	(12)	(12)	(12)	MAIN FEED FLOW Klbm/Hr	(21)	(21)	(21)	(21)	SI ACC 'A' (33) %	SI ACC 'B' (34) %	SI ACC 'C' _(35)% (35) psig	SI ACC 'D' (36)% (36) psig	ESI ACTI N	FAS JATIO IS	CSF STATUS	COLOR	REASON (if not green)	
Tcold (wr/nr)	(13)	(13)	(13)	(13)	AUX FEED FLOW Klbm/Hr	(22)	(22)	(22)	(22)				WST LVL _(38)%	SIS (59)	CIS-A (60)	SUBCRIT	(69)	(69)	
LOOP FLOW (%)	(14)	(14)	(14)	(14)	STEAM FLOW Klbm/Hr	(23)	(23)	(23)	(23)	ELEC	TRICAL S	YSTEMS S	<u>ratus</u>	CIS-B (61)	CSAS (62)	CORE COOLING	(69)	(69)	
RCP (ON/OFF/ UNAVAIL)	(15)	(15)	(15)	(15)	MSIV OP/CL	(24)	(24)	(24)	(24)	SWYD BUS (39)_(KV	A SWYD B	US B (KV)(4	NK01 7) VDC	CPIS (63)	MSLIS (64)	HEAT SINK	(69)	(69)	
	CONTR	OL ROD PO	OSITIONS		FWIV OP/CL	(25)	(25)	(25)	(25)	<u>D/G 'A'(</u> 41 ON/OFF/ UNAVAIL) <u>D/G 'B'</u> ON/OF UNAVA	(42) (F/ .IL(4	NK02 8) VDC	FWIS (65)	AFAS (66)	RCS INTEGRITY	(69)	(69)	
CTRL BANK A (16)	CTRL BANK B (16)	CTRL BANK C (16)	CTRL BANK D (16)		S/G ATM PORV OP/CL	(26)	(26)	(26)	(26)	NB01 ENERGIZE (43) YES/NO	NB02 <u>ENERGI</u> (44) YES/N	2 <u>ED</u> 10	NK03 49) VDC	CRVIS (67)	FBIS (68)	СТМТ	(69)	(69)	
S/D BANK A (17)	S/D BANK B (17)	S/D BANK C (17)	S/D BANK D (17)	S/D BANK E (17)	MDAFP ' MDAFP ' TDAFP	A' ON/OFF/ (27) B' ON/OFF/ (27) ON/OFF/U	UNAVAIL UNAVAIL JNAVAIL	CST (28	° LVL 8)%	PA01 ENERGIZE (45) YES/NO	ED PA02 ENERGI (46) YES/N	ZED 10	NK04 (50) VDC			RCS INVEN- TORY	(69)	(69)	
Tank V I I	Tank Volumes NOTES AND MISC ITEMS Pressurizer: 120 gal% Cold 62 gal% Hot VCT: 20.4 gal% CTMT Normal Sumps: 15.6 gal% or 10 gal/in PRT: 132.6 gal% GVT: 4007.23 gal% CTMT Normal Sumps: 15.6 gal% or 10 gal/in Accumulators: 7.291 gal% CST: 4608.85 gal% Instrument Tunnel Sump: 15 gal% Notify Chemistry and HP Coordinator when entering recirc phase																		

PLANT STATUS BOARD / PLANT COMPUTER CROSS REFERENCE

This Attachment is designed to match up information on the Plant Status Board with the appropriate computer points on the Plant Computer. The key number is the matching number from Attachment 2. If there is no associated computer point for an item number, additional information is provided as to where this information can be obtained. When there is more than one computer point that provides the information for an item number the preferred computer point is provided first separated from the secondary computer points by semi colons.

<u>KEY</u>	PLANT COMPUTER POINT
1	Reactor Trip Date = SPDS4033-35, Reactor Trip time SPDS4036-38; ALARM Review
2	Rx PWR ; Post Accident Wide Range = SEN0701; SEN0060B, 61B
	Power Range SPDS00059; REU1169; REN0049A-52A
3	RCS WR PRESSURE; SPDS0001; REP0498A, 499A
4	RVLIS DYNAMIC = REU0523; REL0503A, 523A
	RVLIS STATIC = SPDS0042; REL0501A, 521A
5	SUBCOOLING; SPDS0006; REU1734-37
6	HIGHEST CORE EXIT T/C; REU0090;
	$\underline{\text{LOCATION}} = \text{REU0092}; \text{RET00}\underline{01A} - \text{RET00}\underline{50A}$
7	PZR LVL; REU0483; REL0480A - 482A
8	RCS ACTIVITY; SJR0001 OR CHEMISTRY COORDINATOR
9	PRT TEMP = RET0485A PRT PRESS = REP0485A PRT LEV = REL0485A
10	PZR PORV A = BBZ455AA BLOCK VALVE A = BBZ8000A
11	PZR PORV B = BBZ455AB BLOCK VALVE B = BBZ8000B
12	RCS LOOPS Thot ; A = WIDE RET0419A; NARROW REU411A
	B = WIDE RET0439A; NARROW REU421A
	C = WIDE RET0459A; NARROW REU431A
	D = WIDE RET0479A; NARROW REU441A
13	RCS LOOPS Tcold; A = NARROW RET0402A; WIDE RET0406A
	$\mathbf{B} = \mathbf{NARROW} \text{ RE10422A}; \text{ WIDE RE10426A}$
	C = NARROW RE10442A; WIDE RE10446A
	D = NARROW KE10462A; WIDE KE10460A
14	RCS LOOP FLOWS; $A = REU0400$; REF0400A - 402A
1	B = KEU0420; KEF0420A - 422A $C = BEU0440 + BEE0440A - 442A$
1	U = REU0440; REF0440A - 442A $D = PEU0460; PEE0460A - 462A$
	D = KEU0400, KEF0400A = 402A

KEY	PLANT COMPUTER POINT
15	RCP STATUS; A = BBQ0001
	B = BBQ0002
	C = BBQ0003
	D = BBQ0004
16	CONTROL BANK POSITIONS ; A = REU0001 ; REU0049 ; REC0041 , 42 ,45 ,46
	B = REU0002; REU0050; REC0050 - 57
	C = REU0003 ; REU0051 ; REC0059-66
	D = REU0004 ; REU0052 ; REC0068 , 69, 72 ,73, 74
17	S/D POSITIONS; A = REU0010; REU0053; REC0009 - 12, REC0014 - 17
	B = REU0011; REU0054; REC0019 - 22, REC0024 - 27
	C = REU0012 ; REU0055 ; REC0029 - 32
	D = REU0013; REU0056; REC0033 - 36
	E = REU0014; REU0060; REC0037 - 40
18	S/G NARROW RANGE LEVELS ; A = REU0415 ; REL0400A - 403A
	B = REU0435; REL0420A - 423A
	C = REU0455; REL0440A - 443A
	D = REU0475; REL0460A - 463A
19	S/G WIDE RANGE LEVELS ; A = REL0404A
	$\mathbf{B} = \mathrm{REL0424A}$
	C = REL0444A
	$\mathbf{D} = \text{REL0464A}$
20	S/G PRESSURES; $A = REU0414$; REP0400A - 402A
	B = REU0434; REP0420A - 422A
	C = REU0454; REP0440A - 442A
	D = REU0474; REP0460A - 462A
21	MAIN FEED FLOW; A = REU0410A; REF0403A, 4A
	$\mathbf{B} = \mathbf{R} \mathbf{E} \mathbf{U} 0 4 3 0 \mathbf{A} ; \mathbf{R} \mathbf{E} \mathbf{F} 0 4 2 3 \mathbf{A} , 2 4 \mathbf{A}$
	C = REU0450A; REF0443A, 44A
	$\mathbf{D} = \mathbf{R}\mathbf{E}\mathbf{U}0470\mathbf{A} ; \mathbf{R}\mathbf{E}\mathbf{F}0463\mathbf{A} , 64\mathbf{A}$
22	AUX FEED FLOW; $A = ALF0702$
	$\mathbf{B} = \mathrm{ALF0703}$
	C = ALF0704
	$\mathbf{D} = \mathrm{ALF0701}$
23	STEAM FLOW; $A = REU0412A$; REF0405A, 6A
	$\mathbf{B} = \mathbf{REU0432A}; \mathbf{REF0425A}, \mathbf{26A}$
	$\mathbf{C} = \operatorname{REU0452A}$; $\operatorname{REF0445A}$, 46A
	$\mathbf{D} = \text{REU0472A}; \text{REF0465A}, 66\text{A}$
24	MSIV POSITION; A = ABZ0014
	$\mathbf{B} = \mathbf{A}\mathbf{B}\mathbf{Z}0017$
	C = ABZ0020
	$\mathbf{D} = \mathbf{A}\mathbf{B}\mathbf{Z}0011$

-

<u>KEY</u>	PLANT COMPUTER POINT
25	FWIV POSITION ; $A = AEZ0039$
	$\mathbf{B} = \mathbf{A}\mathbf{E}\mathbf{Z}0040$
	C = AEZ0041
	$\mathbf{D} = \mathbf{A}\mathbf{E}\mathbf{Z}0042$
26	S/G ATM PORV; $A = ABZ0001$
	$\mathbf{B} = \mathbf{A}\mathbf{B}\mathbf{Z}0002$
	C = ABZ0003
	$\mathbf{D} = \mathbf{ABZ0004}$
27	AFP STATUS; MDAFP $A = ALQ0023$
	$\mathbf{MDAFP B} = \mathbf{ALQ0022}$
	$\mathbf{1DAFP} = \mathbf{ALQ0600}$
28	CST LEVEL; APL0004
29	CCP STATUS AND FLOW; CCP A = BGQ0001
	CCPB = BGQ0002
20	BIH FLOW = RE00003; REF0927A + REF0926A
30	NCP STATUS AND FLOW; NCP = BGQ0003 $NBC FLOW - PEE0128A$
21	CLDUMD STATUS SID A - EMO0004
31	SI PUIVIP STATUS SIP $A = EVIQUUU4$ AND ELOW. SID $B = EMO0005$
	AND FLOW; SIF $B = EMQ0003$ COLD LFC FLOW = RFU0502 · RFF0921A + RFF0922A
30	DUD DUMP STATUS: PHP PIIMP A = $FIO0001$
32	AND FLOW RHR PLIMP $B = EIO0002$
	$\mathbf{COLD} \mathbf{LEG} \mathbf{FLOW} = \mathbf{REU0501} : \mathbf{REF0626A} + \mathbf{REF0627A}$
	HOT LEG RECIRC FLOW = $REF0948A$
33	SLACC A LEVEL: REU0512: REL0940A, 941A
20	SI ACC A PRESS ; REP0940A, 941 A
34	SI ACC B LEVEL ; REU0513 ; REL0942A , 943A
	SI ACC B PRESS; REP0942A, 943 A
35	SI ACC C LEVEL; REU0514; REL0944A, 945A
	SI ACC C PRESS; REP0944A, 945 A
36	SI ACC D LEVEL; REU0515; REL0946A, 947A
	SI ACC D PRESS ; REP0946A, 947 A
37	INJECTION/RECIRC ALIGNMENT; CONTROL ROOM (OR SYSTEM VALVE
	LINEUP COMPUTER POINTS/ SYSTEM
	DISPLAYS)
38	RWST LEVEL ; REU0511; REL0930A - 933A
39	SWYD BUS A VOLTAGE ; MSE0345A
40	SWYD BUS B VOLTAGE ; MSE0345B
41	D/G A STATUS ; NEE0601
42	D/G B STATUS ; NEE0602
43	NB01 STATUS ; NBQ0701; NEQ0017 , NBQ0013 , NBQ0015
44	NB02 STATUS ; NBQ0702; NEQ0018 , NBQ0017 , NBQ0019
45	PA01 STATUS : PAE0003

-

<u>KEY</u>	PLANT COMPUTER POINT
46	PA02 STATUS; PAE0004
47	NK01 VOLTAGE: NKE0001
48	NK02 VOLTAGE: NKE0002
49	NK03 VOLTAGE: NKE0003
50	NK04 VOLTAGE: NKE0004
51	CONTAINMENT PRESSURE ; REU1000 ; REP1000A - 1002A , REP1038A , 39A
52	CONTAINMENT TEMP; SPDS0007; GNT0060 - 0063
53	CONTAINMENT HUMIDITY ; SPDS0010 ; GNA0027 , 28
54	CONTAINMENT RADIATION; SPDS0011; GTR0059, 60
55	CONTAINMENT H ₂ CONC.; SPDS0053; GSA0019, 10
56	CONTAINMENT SPRAY PUMP STATUS ; CSP 'A' ; ENQ0003
	CSP 'B' ; ENQ0009
57	CONTAINMENT RECIRC SUMP A LEVEL ; EJL0007
	CONTAINMENT RECIRC SUMP B LEVEL ; EJL0008
58	H ₂ RECOMBINER STATUS; OBTAIN FROM CONTROL ROOM IF THERE IS
	INDICATION OF H ₂ IN CONTAINMENT.
59	SIS ACTUATION ; SAQ0605; SAQ0010A, 10B
60	CIS - A ACTUATION ; SAQ0601, SAQ0005A, 5B
61	CIS - B ACTUATION ; SBQ0012
62	CSAS ACTUATION ; SBQ0013
63	CPIS ACTUATION; SAQ0603, SAQ0007A, 7B
64	MSLIS ACTUATION; ABZ0602
65	FWIS ACTUATION ; AEZ0600
66	AFAS ACTUATION ;SAQ0606; SAQ011A/B/C
67	CRVIS ACTUATION ; SAQ0602, SAQ0006A, 6B
68	FBIS ACTUATION ; SAQ0604, SAQ0014A, 14B
69	CSF STATUS ; SUBCRIT ;
	(SPDS) CORE COOLING;
	HEAI SINK ; DCS DITECTITY.
	CONTAINMENT.
	DCS INVENTORY
	KUS INVENTORI;

-
PLANT STATUS BOARD / MAIN CONTROL BOARD CROSS REFERENCE

This reference is set up to match information on the Plant Status Board with the location and identification number of where that information is found, i.e. the Control Room instrument(s) etc.

Key # = Corresponds to the numbers on Attachment 2, Plant Status Board Key.

PANEL = Designates the panel of the main control board or elsewhere on which the desired instrument or indication is located.

LOC =General location on the panel where the instrument is located:

1st Letter	2nd Letter
U = Upper	R = Right
L = Lower	L = Left
	C = Center

Instrument = Identification number of desired instrument. This number is normally on a label under, over, or on the instrument.

When two or more instruments measure the same parameter, all instruments are listed, one under another, with the same margin. Any, or ideally a rough average of all, of these readings can be used.

In the case where it is preferable to obtain a reading from one instrument rather than another, the less favorable one will be indented. Even less favorable ones will be further indented.

INSTRUMENT EXAMPLE			
XX-XX-XXX	Three desirable instruments. Rough average the valid readings.		
XX-XX-XXX			
XX-XX-XXX			
XX-XX-XXX	Less desirable instrument reading for use if desirable not valid.		
XX-XX-XXX	Least desirable instrument		

<u>KEY</u>	PSB ITEM	PANEL	INSTRUMENT ID	CONTROL BOARD LABEL/INFORMATION
1	Rx TRIP DATE/TIME	ALARM PRINTER	NA	REACTOR TRIP TIME AND DATE
2	Rx PWR	RL004 - LL	SE NI-41B SE NI-42B SE NI-43B SE NI-44B	POWER LEVEL
		RL020 - UR RL020 - UR	SE NI-60B SE NIR-61	<i>(USE THESE DETECTORS IN EVENT OF LOCA, MSLB OR CSAS)</i> POST ACCIDENT PR POST ACCIDENT PR/SR DETECTOR
3	RCS WR PRESS.	RL022 -LC RL022- LC RL002- UC RL022- LC RL002-UC	BB PI-403 BB PI-405 BB PI-406 BB PR-403 BB PI-403A	RCS WR PRESS TRN B RCS WR PRESS TRN A RCS WR PRESS TRN B RCS WR PRESS RCS LO RANGE PRESS
4	RVLIS DYNAMIC/ STATIC	RL021 - UC RL021 - UC RL021 - UC	BB LI-1312 BB LI-1322 BB LI-1311	REACTOR VESSEL WTR LEV PUMPS ON REACTOR VESSEL WTR LEV PUMPS ON REACTOR VESSEL WTR LEV PUMPS OFF
		RL021 - UC	BB LI-1321	REACTOR VESSEL WTR LEV PUMPS OFF
5	SUB- COOLING	RL022 - LC RL022 - LC	BB TI-1390A BB TI-1390B	RCS DEGREES SUBCOOLING RCS DEGREES SUBCOOLING
6	HIGHEST CORE EXIT T/C	RP081 (in Control Room equip room)		
7	PZR LVL	RL002 - UR RL002 - UR RL002 - UR RL002 - UR RL002 - UR RL002 - UR	BB LI-461 BB LI-460A BB LI-459A BB LR-459 BB LI-462	PZR LEV PZR LEV PZR LEV PZR PROGRAM LEV RECORDER PZR LEV COLD CALIBRATION
8	RCS ACTIVITY	RM011	SJL 016	
9	PRT TEMP PRESS LEVEL	RL021 - LC RL021 - LC RL021 - LC	BB TI-468 BB PI-469 BB LI-470	PRESSURIZER RELIEF TANK TEMP PRESSURIZER RELIEF TANK PRESS PRESSURIZER RELIEF TANK LEV
10	PZR PORV A A PORV BLOCK VLV	RL021 - LC RL021 - LC	BB HIS-455A BB HIS-8000A	PZR PORV
11	PZR PORV B B PORV BLOCK VLV	RL021 - LC	BB HIS-456A BB HIS-8000B	PZR PORV PZR PORV BLOCK VLV

KEY	PSB ITEM	PANEL	INSTRUMENT ID	CONTROL BOARD LABEL/INFORMATION
12	RCS LOOP Thot A	RL022 - LC	BB TR-413	LOOP 1 H/C LEGS WR TEMP
	В	RL021 - UR RL022 - LC RL021 - UR	BB TR-423 BB TI-423A	LOOP 2 H/C LEGS WR TEMP LOOP 2 H/C LEGS WR TEMP
	с	RL022 - LC	BB TR-433	LOOP 3 H/C LEGS WR TEMP
	D	RL022 - LC	BB TR-443	LOOP 4 H/C LEGS WR TEMP
13	RCS LOOP Tcold			
	A	RL022 - LL RL021 - UR	BB TR-413 BB TI-413B	LOOP 1 H/C LEGS WR TEMP LOOP 1 COLD LEG WR TEMP
	в	RL022 - LL RL021 - UR	BB TR-423 BB TI-423B	LOOP 2 H/C LEGS WR TEMP LOOP 2 COLD LEG WR TEMP
	с	RL022 - LC	BB TR-433	LOOP 3 H/C LEGS WR TEMP
	D	RL022 - LC	BB TR-443	LOOP 4 H/C LEGS WR TEMP
14	RCS LOOP			
	A	RL022 - LL RL022 - LL RL022 - LL	BB FI-414 BB FI-415 BB FI-416	LOOP 1 REACTOR COOLANT FLOW
	В	RL022 - LL RL022 - LL RL022 - LL	BB FI-424 BB FI-425 BB FI-426	LOOP 2 REACTOR COOLANT FLOW
	с	RL022 - LL RL022 - LL RL022 - LL	BB FI-434 BB FI-435 BB FI-436	LOOP 3 REACTOR COOLANT FLOW
	D	RL022 - LC RL022 - LC RL022 - LC	BB FI-444 BB FI-445 BB FI-446	LOOP 4 REACTOR COOLANT FLOW
15	RCP A B C D	RL021 - UL RL021 - UL RL021 - UL RL021 - UL	BB HIS-37 BB HIS-38 BB HIS-39 BB HIS-40	RCP A RCP B RCP C RCP D
16	CTRL BANK POSITION A	RL022 - UR RL003 - UC RL003 - UC	SF074 SC CB-A1 SC CB-A2	PNL CONT RPI DISPLAY CTRL BANK A1 STEP COUNTER CTRL BANK A2 STEP COUNTER

<u>KEY</u>	PSB ITEM	PANEL	INSTRUMENT ID	CONTROL BOARD LABEL/INFORMATION
16	В	RL022 - UR RL003 - UC RL003 - UC	SF074 SC CB-B1 SC CB-B2	PNL CONT RPI DISPLAY CTRL BANK B1 STEP COUNTER CTRL BANK B2 STEP COUNTER
	С	RL022 - UR RL003 - UC RL003 - UC	SF074 SC CB-C1 SC CB-C2	PNL CONT RPI DISPLAY CTRL BANK C1 STEP COUNTER CTRL BANK C2 STEP COUNTER
	D	RL022 - UR RL003 - UC RL003 - UC	SF074 SC CB-D1 SC CB-D2	PNL CONT RPI DISPLAY CTRL BANK DI STEP COUNTER CTRL BANK D2 STEP COUNTER
17	S/D BANK POSITION			
	A	RL022 - UR RL003 - LC RL003 - LC	SF074 SC SB-A1 SC SB-A2	PNL CONT RPI DISPLAY S/D BANK A1 STEP COUNTER S/D BANK A2 STEP COUNTER
	В	RL022 - UR RL003 - LC RL003 - LC	SF074 SC SB-B1 SC SB-B2	PNL CONT RPI DISPLAY S/D BANK B1 STEP COUNTER S/D BANK B2 STEP COUNTER
	С	RL022 - UR RL003 - LC	SF074 SC SB-C1	PNL CONT RPI DISPLAY S/D BANK C1 STEP COUNTER
	D	RL022 - UR RL003 - LC	SF074 SC SB-D1	PNL CONT RPI DISPLAY S/D BANK D1 STEP COUNTER
	Е	RL022 - UR RL003 - LC	SF074 SC SB-D1	PNL CONT RPI DISPLAY S/D BANK E STEP COUNTER
18	S/G NR LEVEL			
	А	RL026 - LL RL026 - LL RL026 - LL RL025 - UL RL006 - UL	AE LI-517 AE LI-518 AE LI-519 AE LI-551 AE FR-510	SG A LEV SG A LEV SG A LEV STEAM GENERATOR A LEV SG A STEAM/FW FLOW/LEV
	В	RL026 - LL RL026 - LL RL026 - LC RL025 - UL RL006 - UL	AE LI-527 AE LI-528 AE LI-529 AE LI-552 AE FR-520	SG B LEV SG B LEV SG B LEV STEAM GENERATOR B LEV SG B STEAM/FW FLOW/LEV
	с	RL026 - LC RL026 - LC RL026 - LC RL025 - UC RL006 - UC	AE LI-537 AE LI-538 AE LI-539 AE LI-553 AE FR-530	SG C LEV SG C LEV SG C LEV STEAM GENERATOR C LEV SG C STEAM/FW FLOW/LEV
	D	RL026 - LC RL026 - LC RL026 - LC RL025 - UC RL006 - UC	AE LI-547 AE LI-548 AE LI-549 AE LI-554 AE FR-540	SG D LEV SG D LEV SG D LEV STEAM GENERATOR D LEV SG D STEAM/FW FLOW/LEV

•

2"

	<u>KEY</u>	<u>PSB ITEM</u>	PANEL	INSTRUMENT ID	CONTROL BOARD LABEL/INFORMATION
ſ	19	S/G WR			······································
		LEVEL A	RL025 - UL RL026 - UL	AE LI-501 AE LR-501	SG A WR LEV SG A & B WR LEV
		В	RL025 - UL RL026 - UL	AE LI-502 AE LR-501	SG B WR LEV SG A & B WR LEV
		С	RL025 - UC RL026 - UL	AE LI-503 AE LR-503	SG C WR LEV SG A & B WR LEV
		D	RL025 - UC RL026 - UL	AE LI0504 AE LR-503	SG D WR LEV SG A & B WR LEV
	20	S/G PRESS	RI 026 - 11	AB PL-514A	SG A PRESS
		A	RL026 - LL	AB PI-515A	SG A PRESS
			RL026 - LL	AB PI-516A	SG A PRESS
			RL026 - UC	AB PR-514	SG A & B PRESS
			RL026 - LL	AB PI-524A	SG B PRESS
		В	RL026 - LL	AB PI-525A	SG B PRESS
			RL026 - LL	AB PI-526A	SG B PRESS
			RL026 - UC	AB PK-514	SU A & B FRESS
			RL026 - LL	AB PI-534A	SG C PRESS
			RL026 - LL	AB PI-535A	SG C PRESS
		С	RL026 - LL	AB PI-536A	SG C PRESS
			KL026 - UC	AB PK-333	SUC & D PRESS
			RL026 - LL	AB PI-544A	SG D PRESS
		D	RL026 - LL	AB PI-545A	SG D PRESS
			RL026 - LL	AB PI-546A	SG D PRESS
	21	MAIN FEED	RL020 - UC	AD FK-333	SUC & DTRESS
		FLOW			
			RL026 - UL	AE FI-510A	STEAM GENERATOR A FW FLOW
		A	RL026 - UL RL006 - UI	AE FI-SITA AF FR-510	STEAM GENERATOR A FW FLOW
			KE000 - OE	ALTR-510	
1			RL026 - UL	AE FI-520A	STEAM GENERATOR B FW FLOW
		В	RL026 - UL	AE FI-521A	STEAM GENERATOR B FW FLOW
			RL006 - UL	AE FK-520	SGB STEAM/FW FLOW/LEV
			RL026 - UC	AE FI-530A	STEAM GENERATOR C FW FLOW
		С	RL026 - UC	AE FI-531A	STEAM GENERATOR C FW FLOW
			RL006 - UC	AE FR-530	SG C STEAM/FW FLOW/LEV
			RL026 - UC	AE FI-540A	STEAM GENERATOR D FW FLOW
-		D	RL026 - UC	AE FI-541A	STEAM GENERATOR D FW FLOW
		AUVEEED	RL006 - UC	AE FR-540	SG D STEAM/FW FLOW/LEV
	22	FLOW			
		A	RL006 - UL	AL FI-2A	AFW TO SG A FLOW
		В	RL006 - UL	AL FI-3A	AFW TO SG B FLOW
			RL006 - UC	AL FI-4A	AFW TO SG C FLOW
. I			KL000 - UC	AL FI-IA	

-					
	<u>KEY</u>	PSB ITEM	PANEL	INSTRUMENT ID	CONTROL BOARD LABEL/INFORMATION
	23	STEAM			
		FLOW			
			RL026 - UL	AB FI-512A	STEAM GENERATOR A STEAM FLOW
		A	RL026 - UL	AB FI-513A	STEAM GENERATOR A STEAM FLOW
			RE000 - UL	AE FK-JIU	30 A STEAM/FW FLOW/LEV
			RL026 - UL	AB FI-522A	STEAM GENERATOR B STEAM FLOW
		В	RL026 - UL	AB FI-523A	STEAM GENERATOR B STEAM FLOW
			RL006 - UL	AE FR-520	SG B STEAM/FW FLOW/LEV
			RL026 - UC	AB FI-532A	STEAM GENERATOR C STEAM FLOW
		C	RL026 - UC	AB F1-533A	STEAM GENERATOR C STEAM FLOW
			KL006 - UC	AE FK-330	SG C STEAM/FW FLOW/LEV
			RL026 - UC	AB FI-542A	STEAM GENERATOR D STEAM FLOW
		D	RL026 - UC	AB FI-543A	STEAM GENERATOR D STEAM FLOW
			RL006 - UC	AE FR-540	SG D STEAM/FW FLOW/LEV
	24	MSIV			
		POSITION	DI 005 11		
		A	RL025 - LL	AB HIS-14	SG A MS ISO VLV
		B	RL025 - LL	AD HIS-17	SG C MS ISO VLV
			RL025 - LC	AB HIS-11	SG D MS ISO VLV
	25	FWIV	10000 00		
		POSITION			
		A	RL025	AE HIS-39	SG A FW ISO VLV
		B	RL025	AE HIS-40	SG B FW ISO VLV
			RL025	AE HIS-41	SG C FW ISO VLV
	26	S/G PORV	KL023	AE 115-42	
	20	POSITION			
		A	RL006 - LL	AB ZL-1A	SG A STEAM DUMP TO ATM
		В	RL006 - LL	AB ZL-2A	SG B STEAM DUMP TO ATM
		C	RL006 - LC	AB ZL-3A	SG C STEAM DUMP TO ATM
	07	D	RL006 - LC	AB ZL-4A	SG D STEAM DUMP TO ATM
	27		RI 005	AL HIS-23A	MD AFP A
		MDAFP B	RL005	AL HIS-22A	MD AFP B
		TDAFP	RL005	AL PI-21A > AL PI-26A	TD AFP DISCH PRESS > TD AFP SUCT PRESS
	28	CST LEVEL	RL005 - UC	AP LI-4A	CST LEV
	29	CCP		DOVIDAL	
		A	RL00I - LR	BG HIS-IA	CCP A Run/Stop
		в	RL018 - ML	BGHIS-24	CCP B Run/Ston
			RL018 - MR	EM-FI-917B	CCP B Flow
	30	NCP	RL001	BG HIS-3	Normal Charging Pump
			RL002	BG-FI-121A	NCP Flow
	31	SI Pump			
		A	RL017 – UR	EM HIS-4	SI Pump A
			KLUI/-UK	EM-F1-918	SI Pump A Flow
		В	RL017 - UL	EM-FI-922	SI Pump B Flow
	32	RHR Pump			
		A	RL017 – LR	EJ HIS-1	RHR Pump A
			RL017	EJ-FI-618	RHR Pump A Flow
		В	RL017 – LL	EJ HIS-2	RHR Pump B
			RL017	EJ-FI-619	RHR Pump B Flow

÷

5

-

<u>KEY</u>	PSB ITEM	PANEL	INSTRUMENT ID	CONTROL BOARD LABEL/INFORMATION
33	SI ACC 'A'	RL018 - UR	EP LI-950	ACCUMULATOR TANK A LEVEL
	LEVEL/PRESS	RL018 - UR	EP LI-951	ACCUMULATOR TANK A LEVEL
1		RL018 - UR	EP PI-960	ACCUMULATOR TANK A PRESSURE
		RL018 - UR	EP PI-961	ACCUMULATOR TANK A PRESSURE
34	SI ACC 'B'	RL018 - UL	EP LI-952	ACCUMULATOR TANK B LEVEL
	LEVEL/PRESS	RL018 - UL	EP LI-953	ACCUMULATOR TANK B LEVEL
		RL018 - UL	EP PI-962	ACCUMULATOR TANK B PRESSURE
		RL018 - UL	EP PI-963	ACCUMULATOR TANK B PRESSURE
35	SI ACC 'C'	RL018 - UR	EP LI-954	ACCUMULATOR TANK C LEVEL
	LEVEL/PRESS	RL018 - UR	EP LI-955	ACCUMULATOR TANK C LEVEL
		RL018 - UR	EP P1-964	ACCUMULATOR TANK C PRESSURE
		RL018 - UK	EP PI-965	ACCUMULATOR TANK C PRESSURE
- 30	SI ACC 'D'	RLUI8 - UL	EP L1-956	ACCUMULATOR TANK D LEVEL
	LEVEL/PRESS		EP LI-95/	ACCUMULATOR TANK D LEVEL
			EP PI-900	ACCUMULATOR TANK D PRESSURE
27	ECCS	KLUI0-UL	LF F1-907	ECCS IS IN THE INJECTION MODE IE ANY OF
57	INTECTION OF			THE FOLLOWING ARE OPEN AND THE DUMP IS
	RECIRC			RUNNING
	MODE			Normino.
1	(in the recirc			RL001 - UC · BN HIS-112D (CCP A)
	mode if not in			RL001 - UC; BN HIS-112E (CCP B)
1	the injection			RL017 - UR : BN HIS-8806A (SIP A)
	mode and ECCS			RL017 - UL; BN HIS-8806B (SIP B)
1	is activated)			RL017 - LR ; BN HIS-8812A (RHR PUMP A)
1	· ·			RL017 - LL; BN HIS-8812B (RHR PUMP B)
38	RWST	RL018 - UR	BN LI-930	RWST LEV
	LEVEL	RL018 - UR	BN LI-932	RWST LEV
		RL018 - UL	BN LI-931	RWST LEV
		RL018 - UL	BN LI-933	RWSTLEV
39	SWYD			
	BUS A	RL014 - LC		VOLT BUS A
	VOLTAGE			
40	SWYD			
	BUS B	RL014 - LC		VOLT BUS B
	VOLTAGE	DIALS UC		DO NEAL AT VOLT (AT EDEO
41	D/G A	RLUIS-UC	ALS - UC NE ZL-20/ NE ZL-27 DU NEULAI VULI/ ALFREU	
42	D/G B	RLUIS-UC	ND EL1	A 16 KW DUS NDOL WOLT
43	INDUI	RI015-III	NB 71-5	4.16 KV BUS NB01
44	NB02	RL015-LR	NB EL-2	4 16 KV BUS NB02 VOLT
1	11202	RL015 - UR	NB ZL-6	4.16 KV BUS NB02
45	PA01	RL016 - UL	PA EI-1	13.8 KV BUS PA01 VOLT
		RL016 - UL	PA ZL-1	13.8 KV BUS PA01
46	PA02	RL016 - UR	PA EI-2	13.8 KV BUS PA02 VOLT
		RL016 - UR	PA ZL-2	13.8 KV BUS PA02
47	NK01	RL016 - UL	NK EI-1	125 V DC BUS NK01 VOLT
48	NK02	RL016 - UL	NK EI-2	125 V DC BUS NK02 VOLT
49	NK03	RL016 - UR	NK EI-3	125 V DC BUS NK03 VOLT
50	NK04	RL016 - UR	NK EI-4	125 V DC BUS NK04 VOLT

•

<u>KEY</u>	<u>PSB ITEM</u>	PANEL	INSTRUMENT ID	CONTROL BOARD LABEL/INFORMATION
51	CTMT	RL018 - UL	GN PI-934	CTMT ATMS PRESS
	PRESS	RL018 - UL	GN PI-936	CTMT ATMS PRESS
		RL018 - UC	GN PI-935	CTMT ATMS PRESS
		RL018 - UC	GN PI-937	CTMT ATMS PRESS
		RL018 - UL	GN PR-934	CTMT ATMS PRESS
		RL020 - UL	GN PI-938	CTMT ATMS PRESS
		RL020 - UL	GN PI-939	CTMT ATMS PRESS
	-	RL020 - UL	GN PR-938	CTMT PRESS RECORDER
52	CTMT TEMP	RL020 - UL	GN TR-63	CTMT TEMP RECORDER
53	CTMT	RL020 - UL	GN AI-27	CTMT HUMIDITY
	HUMIDITY	RL020 - UL	GN AI-28	CTMT HUMIDITY
54	CTMT RAD	RL020 - UL	GT RR-60	CTMT RAD RECORDER
55	CTMT	RL020 - UL	GS AI-10	CTMT H2 CONCENTRATION
	H ₂ CONC	RL020 - UL	GS AI-19	CTMT H2 CONCENTRATION
	-	RL020 - UL	GS AR-10	CTMT H2 CONCENTRATION
56	CTMT	RL017	EN HIS-3	CTMT SPRAY PUMP A
	SPRAY PUMP	RL017	EN HIS-9	CTMT SPRAY PUMP B
57	CTMT	RL018 - UL	EJ LI- 8	CTMT RECIRC SUMP LEV
	RECIRC	RL018 - UR	EJ LI- 7	CTMT RECIRC SUMP LEV
	SUMP	RL020 - UL	EJ LR-6	CTMT RECIRC SUMP LEV RECORDER
58	H ₂ RECOMB.	RL020 - LR	GS HS-1A	H2 RECOMBINER A
		RL020 - LC	GS HS-29A	H2 RECOMBINER B
59	SIS	RL018	SA 066-Y	ESF SYS STATUS INDICATION
			SA 066-X	ESF SYS STATUS INDICATION
60	CIS-A	RL018	SA 066-Y	ESF SYS STATUS INDICATION
			SA 066-X	ESF SYS STATUS INDICATION
61	CIS-B	RL018	SA 066-Y	ESF SYS STATUS INDICATION
			SA 066-X	ESF SYS STATUS INDICATION
62	CSAS	RL018	SA 066-Y	ESF SYS STATUS INDICATION
			SA 066-X	ESF SYS STATUS INDICATION
63	CPIS	RL018	SA 066-Y	ESF SYS STATUS INDICATION
	1		SA 066-X	ESF SYS STATUS INDICATION
64	MSLIS	RL018	SA 066-Y	ESF SYS STATUS INDICATION
			SA 066-X	ESF SYS STATUS INDICATION
65	FWIS	RL018	SA 066-Y	ESF SYS STATUS INDICATION
			SA 066-X	ESF SYS STATUS INDICATION
66	AFAS	RL018	SA 066-Y	ESF SYS STATUS INDICATION
			SA 066-X	ESF SYS STATUS INDICATION
67	CRVIS	RL018	SA 066-Y	ESF SYS STATUS INDICATION
			SA 066-X	ESF SYS STATUS INDICATION
68	FBIS	RL018	SA 066-Y	ESF SYS STATUS INDICATION
			SA 066-X	ESF SYS STATUS INDICATION
69	CSF STATUS		CSF STATUS TREES	
			CSF PROCEDURES	

ι

.

EIP-ZZ-00240 Revision 029 October 26, 2001

CALLAWAY PLANT

EMERGENCY PLAN IMPLEMENTING PROCEDURE

EIP-ZZ-00240

TECHNICAL SUPPORT CENTER OPERATIONS

RESPONSIBLE DE	PARTMENT <u>EM</u>	ERGENCY PREPA	AREDNESS
PROCEDURE OWN	NER <u>T. W. PARK</u>	ER	
WRITTEN BY	T. W. PARKER		
PREPARED BY	T. W. PARKER		
APPROVED BY	Warren.	A. Witt	
DATE ISSUED	1-28-01		NOV 2 8 2001 ACCOUNTABLE HOLDER
This procedure conta	ains the following:		
Pages	1	through	<u> </u>
Tables	1	through	
Figures		through	
Appendices		through	
Checkoff Lists		through	
This procedure has	checko	ff list(s) maintained	in the mainframe computer.
Conversion of comm	nitments to TRS refer	ence/hidden text cor	npleted by <u>Revision Number</u> :
Non-T/S Commitme	onts 022		

TABLE OF CONTENTS

Section Page Number 1 1 PURPOSE AND SCOPE 2 RESPONSIBILITIES 1 3 PROCEDURE 4 3.1 **TSC STARTUP** 4 3.2 **TSC OPERATION** 4 **TSC EVACUATION** 4 3.3 EVENT CLOSEOUT 5 3.4 5 **TSC SHUTDOWN** 3.5 6 4 REFERENCES 5 RECORDS 7

Attachment 1	Emergency Coordinator Checklist	2 Pages
Attachment 2	Technical Assessment Coordinator (TAC) Checklist	5 Pages
Attachment 3	Operations Support Coordinator (OSC) Checklist	3 Pages
Attachment 4	Administrative (Admin.) Coordinator Checklist	3 Pages
Attachment 5	Health Physics (HP) Coordinator Checklist	7 Pages
Attachment 6	TSC (ENS) Communicator Checklist	1 Page
Attachment 7	Chemistry Coordinator Checklist	2 Pages
Attachment 8	Security Coordinator (SC) Checklist	2 Pages
Attachment 9	Emergency Team Coordinator (ETC) Checklist	3 Pages

TECHNICAL SUPPORT CENTER OPERATIONS

1 <u>PURPOSE AND SCOPE</u>

1.1 Establishes responsibilities for the Emergency Response Organization, provides guidance and checklists for each coordinator in the Technical Support Center (TSC) during emergency operation of the TSC, including the Operations Support Area (SA).

2 <u>RESPONSIBILITIES</u>

- 2.1 EMERGENCY COORDINATOR (EC)
- 2.1.1 The Emergency Coordinator has overall responsibility for TSC operations.
- 2.2 TECHNICAL ASSESSMENT COORDINATOR (TAC)
- 2.2.1 The TAC reports to the EC. The TAC is responsible for directing technical analysis of plant conditions to formulate EAL'S and emergency mitigating recommendations to the EC. Responsible for coordinating Protective Action Recommendations (PAR'S) consistent with plant conditions with the Recovery Manager and Dose Assessment Coordinator in the EOF prior to the arrival of the Protective Measures Coordinator (PMC) and Plant Assessment Coordinator (PAC). The TAC also evaluates Severe Accident Management Guidelines (SAMG's). (COMN 3333)
- 2.3 ADMINISTRATIVE COORDINATOR (AC)
- 2.3.1 The AC reports to the Emergency Coordinator in the TSC. The AC is responsible for ensuring the completion of the Admin Coordinator checklists. The AC is also responsible for ensuring that technical documents are available, providing food and beverage needs, and ensuring continuity of resources for the On-Site Emergency Response Organization. (COMN 3341)
- 2.4 TSC (ENS) COMMUNICATOR (TC)
- 2.4.1 The TSC Communicator reports to the EC. He is responsible for manning the ENS Communication Line and relaying technical information to the NRC.

2.5 HEALTH PHYSICS COORDINATOR (HPC)

- 2.5.1 The HPC reports to the Emergency Coordinator in the TSC. The HPC is responsible for assessing on-site radiological conditions, reviewing radiological EAL's, and directing in-plant radiation protection activities. (COMN 3331)
- 2.6 OPERATIONS SUPPORT COORDINATOR (OSC)
- 2.6.1 The OSC reports to the Emergency Coordinator in the TSC. The OSC assesses plant information from the control room and technical support staff to establish emergency team priorities and direct operation support activities. (COMN 3336)
- 2.7 SECURITY COORDINATOR (SC)
- 2.7.1 The SC reports to the Emergency Coordinator in the TSC. The SC establishes communications with the Shift Security Supervisor (SSS), assumes overall plant security responsibility, and directs the security force through the SSS. These responsibilities include access control, personnel evacuation and accountability, coordination of any off-site law enforcement agency involvement, and normal and emergency security activities in accordance with the security plan. (COMN 3347)
- 2.8 CHEMISTRY COORDINATOR (CC)
- 2.8.1 The CC reports to the Technical Assessment Coordinator, and assumes responsibility for plant chemistry operations from the shift supervisor. The Chemistry Coordinator directs primary and secondary chemistry operations, (including post-accident chemistry) and non-radiological environmental monitoring. The CC ensures that the TAC is aware of chemistry activities and provides input to the TSC engineering staff in assessing plant chemistry problems. The CC directs the Rad/Chem Technicians -Chemistry. (COMN 3349)
- 2.9 EMERGENCY TEAM COORDINATOR (ETC)
- 2.9.1 The ETCs report to the OSC and assist in formation, briefing, direction, and tracking of emergency teams. The Fire Brigade and MERT continue to report to the Shift Supervisor in the Control Room.

2.10 STORES PERSONNEL

- 2.10.1 A member of the Materials Department reports to the OSC and is responsible for obtaining parts, supplies, and materials when needed.
- 2.11 OTHER TSC STAFF MEMBERS
- 2.11.1 Each TSC coordinator that arrives at the TSC is responsible for starting their Checklist. If the TSC is without power, they should start the TSC diesel per **OOA-UB-EPG70** if it is within their capability.
- 2.11.2 All personnel are responsible for walking through the portal monitor and carding in on the accountability reader as they enter the TSC during a radiological emergency or drill.

NOTE:The portal monitor should be response checked as
soon as possible by the Health Physics group

- 2.11.3 Personnel that leave the Facility should check out with the Security Officer and card out on the accountability reader. If a release has occurred or is likely to occur a HP brief is required. CARS 199701061
- 2.11.4 The following TSC coordinators are responsible for their attachment to this procedure.
 - a) Emergency Coordinator (EC)
 - b) Technical Assessment Coordinator (TAC)
 - c) Operations Support Coordinator (OSC)
 - d) Administrative (Admin) Coordinator (AC)
 - e) Health Physics (HP) Coordinator (HPC)
 - f) TSC (ENS) Communicator (TC)
 - g) Chemistry Coordinator (CC)
 - h) Security Coordinator (SC)
 - i) Emergency Team Coordinator (ETC)

3 <u>PROCEDURE</u>

3.1 <u>TSC STARTUP</u>

- 3.1.1 Each TSC staff member that arrives at the TSC is responsible for carding in on the accountability card reader, assisting in the facility startup and initiating their checklist.
- 3.2 <u>TSC OPERATION</u>
- 3.2.1 The Emergency Coordinator ensures that Attachment 1, Emergency Coordinators Checklist, is used as a guide.
- 3.2.1.1 The EC should periodically discuss priorities, habitability of the facility and Site radiological conditions with the HPC. If evacuation of the TSC becomes necessary refer to Section 3.3.
- 3.2.1.2 The EC should ensure TSC personnel receive a periodic plant status update, including priorities, any change to facility habitability or Site radiological conditions.
- 3.2.2 Each TSC coordinator is responsible for completing their Checklist.

3.3 <u>TSC EVACUATION</u>

- 3.3.1 Evacuation of the facility should be considered:
 - a) When direct dose rates reach or exceed 5,000 mrem/hour, or
 - b) When cumulative dose reaches or exceeds 4,400 mrem, or
 - c) When iodine concentration reaches or exceeds 1.9 E-5 μCi/ml.
- 3.3.2 Evacuation may be required if power is unavailable or the ventilation system fails.

- 3.3.3 Coordinators should go to the facilities as indicated depending on their availability.
 - a) Emergency Coordinator (EC) to Control Room.
 - b) Technical Assessment Coordinator (TAC) to Field Office if habitable then Control Room.
 - c) Operations Support Coordinator (OSC) to Field Office if habitable then Control Room.
 - d) Administrative (Admin) Coordinator (AC) to EOF.
 - e) Health Physics (HP) Coordinator (HPC) to Field Office if habitable then Control Room.
 - f) TSC (ENS) Communicator (TC) to Control Room.
 - g) Chemistry Coordinator (CC) to EOF.
 - h) Security Coordinator (SC) to EOF.
- 3.3.4 Coordinators reporting to the Control Room should evaluate minimum staff required to go with them and assign others to the EOF.
- 3.3.4.1 The OSC should take the Emergency Team Coordinators and minimum number of team members.

3.4 EVENT CLOSEOUT

- 3.4.1 If the emergency conditions allow the initiation of recovery operations or the closeout of the event, the Emergency Coordinator should contact the Recovery Manager (RM) and discuss implementation of **EIP-ZZ-00260**, Event Closeout/Recovery.
- 3.4.2 TSC personnel continue activities in accordance with this procedure until turned over to the Recovery Organization or closeout is declared.

3.5 <u>TSC SHUTDOWN</u>

- 3.5.1 If the TSC is to be shut down, direct the Coordinators to initiate Termination and Shutdown section of their Checklist.
- 3.5.2 The Emergency Coordinator should make preparations with the Shift Supervisor to transfer remaining responsibilities to the Control Room.

- 3.5.3 The Administrative Coordinator assesses the status of the TSC and ensures the following actions have been completed:
- 3.5.3.1 All functional equipment/supplies have been restored to startup conditions.
- 3.5.3.2 The entire TSC staff has been relieved of all duties associated with the operation of the TSC.
- 3.5.3.3 All records generated during the operation of the TSC have been collected.
- 3.5.4 After shifting responsibilities, inform the Shift Supervisor and Recovery Manager that the TSC is shut down.

4 <u>REFERENCES</u>

- 4.1 Callaway Plant Radiological Emergency Response Plan (RERP)
- 4.2 **EIP-ZZ-00101**, Classification of Emergencies
- 4.3 EIP-ZZ-00102, Emergency Implementing Actions
- 4.4 EIP-ZZ-00212, Protective Action Recommendation
- 4.5 EIP-ZZ-00213, Technical Assessment
- 4.6 EIP-ZZ-00217, Emergency Response Data System Activation
- 4.7 EIP-ZZ-00220, Emergency Team Formation
- 4.8 EIP-ZZ-00230, Accountability
- 4.9 **EIP-ZZ-00260**, Event Closeout/Recovery
- 4.10 **OTN-ZZ-00001**, TSC Building HVAC System.
- 4.11 HPCI 96-007, Emergency Response Facility Habitability Guidelines
- 4.12 Severe Accident Management Guidelines

5 <u>RECORDS</u>

<u>NOTE:</u>	All Facility Logs, SENTRY or MAGNEM screen prints, office memos, notes, etc. should be
	attached to the Coordinator Checklist and turned
	in to the Admin Coordinator and/or Emergency
	Preparedness (EP).

5.1 <u>QA RECORDS</u>

- 5.1.1 Attachment 1, Emergency Coordinator Checklist (File K171.0010)
- 5.1.2 Attachment 2, Technical Assessment Coordinator (TAC) Checklist (File K171.0010)
- 5.1.3 Attachment 3, Operations Support Coordinator (OSC) Checklist (File K171.0010)
- 5.1.4 Attachment 4, Administrative (Admin) Coordinator Checklist (File K171.0010)
- 5.1.5 Attachment 5, Health Physics (HP) Coordinator Checklist (File K171.0010)
- 5.1.6 Attachment 6, TSC (ENS) Communicator Checklist (File K171.0010)
- 5.1.7 Attachment 7, Chemistry Coordinator Checklist (File K171.0010)
- 5.1.8 Attachment 8, Security Coordinator (SC) Checklist (File K171.0010)
- 5.1.9 Attachment 9, Emergency Team Coordinator (ETC) Checklist (File K171.0010)

Rev. 029

EMERGENCY COORDINATOR CHECKLIST

.

Date _____ Time: _____

	INITIATION	
1.	 Card in on the accountability card reader. Sign in on Facility Sign-in board. Obtain the EC package. Clip on Emergency Coordinator badge. Review KOA-ZZ- A0002 "COMMAND AND CONTROL GUIDELINES" 	
2.	Initiate Log Sheet.	
3 .	 Receive briefing by: Technical Assessment Coordinator. (EAL Monitoring). Shift Supervisor and relieve him as Emergency Coordinator. 	
4.	Announce assumption of duties to TSC staff.	
5.	Review plant/group status with TSC Coordinators: Administrative. TSC (ENS) Communicator. Health Physics. Operations Support/Support Area. Technical Assessment. Chemistry. Security.	
6.	 Ensure the following responsibilities have been transferred from Control Room. <u>EAL MONITORING.</u> <u>ENS COMMUNICATION.</u> <u>PAR MONITORING</u> (if the RM position in the EOF is not manned). <u>SAMG Implementation</u> (if applicable). 	
7.	Make a site-wide announcement that, "The TSC has accepted emergency responsibilities from the Control Room."	
8.	Announce the following: "TSC Coordinators assess your manpower needs and request additional personnel from the Admin Coordinator as needed. All excess personnel should assemble in the Operations Support Area and await further instructions."	
9.	After assessing manpower needs, instruct all excess personnel to return home or return to work (ALERT) and remain near their phones. Personnel sent home should remain fit for duty and will be contacted concerning shift relief and turnover.	

<u>OPERATIONS</u> (*) Steps are items that MUST be frequently reviewed	
• *1.	Periodically update TSC personnel including priorities, habitability status and Site radiological conditions.
	Note: Priorities should be listed on the Priority Status Board
• *2.	Continue activities per EIP-ZZ-00102, Emergency Implementing Actions.
*3	Perform periodic briefs with the below individuals concerning on-site activities:
— <i>3</i> .	□ TSC Coordinators.
	\square RM.
	\square SS.
	On site NRC personnel.

Rev. 029

EMERGENCY COORDINATOR CHECKLIST

	TURNOVER	
1 1.	Incoming Emergency Coordinator briefed on TSC status and log reviewed.	
2.	Recovery Manager and Shift Supervisor informed.	
3 .	Turnover announced to TSC staff.	
4.	Turnover complete Time.	
5 .	Turnover logged.	
6.	Initiate a new checklist CA# 259.	

	RECOVERY		
1.	Declare Recovery per EIP-ZZ-00260, Event Closeout/Recovery (if applicable).		
	 Recovery Manager contacted. Shift Supervisor contacted. Recovery organization established. Make site wide announcement. 		

	TERMINATION and SHUTDOWN	
0 1.	Shutdown TSC (if required). Coordinators directed to shutdown TSC Time. Make site wide announcement.	

Emergency Coordinator Signature

Rev. 029

TECHNICAL ASSESSMENT COORDINATOR (TAC) CHECKLIST

.

-

	INITIATION	
D 1.	 Card in on the accountability card reader. Sign in on Facility Sign-in board. Obtain the TAC package Clip on the Tech. Assessment Coordinators badge. 	
2.	 Ensure the TSC has power. Normal power, (i.e. lights on, power available to computers, etc.). No Power. Start the TSC diesel per OOA-UB-EPG70. (An EO may be used if available.) 	
3.	Shift the following to UPS power: Computer link located in the closet near the kitchen. PC power supplies CARS 200105972	
4.	If outside temperature is approximately 40°F or above, locate panel FIKUB7001 <u>TSC Air Handling Unit Control</u> <u>Panel</u> , just inside the TSC Equipment Room Door and to the left. Place the <u>TSC Air Handling Unit Control Switch</u> CSUB7005 in the <u>COOL</u> position. CARS 200002783	
D 5.	Initiate Log Sheet.	
6.	Activate Plant Status Boards from the Plant Computer (Cancel, type PSB, Return) or use keyboard commands on the PC. <u>NOTE:</u> In the event of Plant Computer System failure, refer to EIP-ZZ-00213, Technical Assessment, for further guidance.	
7.	Turn on the Projected Status Boards using the remote control. They are connected to the PCs. Keyboard controls MUST be used for the PCs.	
8.	Obtain brief from the SS, STA or other CR personnel. Contact CR via phone as little as possible until the Control Room TSC Liaison is staffed then use the Tech Assessment Line (dial 211), always provide your name and title.	
9.	The following should be logged: Plant Status/Event Status Current EAL(s) Equipment Status (equipment out of service?) Protective Action Recommendations (PAR) Issued per EIP-ZZ-00212. Dose Assessment contact (name) Inform Control Room when accepting EAL(s) PAR(s) SAMG(s) responsibilities Additional instructions?	
10.	Activate Emergency Response Data System ERDS per EIP-ZZ-00217 (if not already activated) from the Plant Computer. (Cancel, type ERDS, return type in password NRCERDS, return, select F2 to activate) When ERDS is activated the system displays "Data Transmission in Progress". To return to PSB's, select Cancel, type PSB, Return; ERDS continues to run unaffected in the background. Inform the ENS Communicator if ERDS cannot be activated (i.e., loss of Plant Computer). CARS 199903613	
11.	Assign the Reactor Engineer to perform core damage assessment using EDP-ZZ-00005.	
1 2.	Begin monitoring Emergency Action Levels (EAL) per EIP-ZZ-00101.	
1 3.	Brief the Emergency Coordinator, upon his arrival, on the TSC activities.	
1 4.	Place TSC Ventilation System in the Filter Mode per OOA-UB-00005. (An EO may be used if available.)	

S. 12

Rev. 029

TECHNICAL ASSESSMENT COORDINATOR (TAC) CHECKLIST

1 5.	Personnel Assessment	
	Chemistry Coordinator	(Name)(1 required)
	Technical Assessment Status Board Keepers	(Name) (3 required)
		(Name)
		(Name)
	Engineers	
	Mechanical (1 required) Elect	rical (1 required)
	Reactor (1 required)I&C	(1 required)
	OtherOthe	r
1 6	Ensure the Facility clock is synchronized to the plant comp	uter or control room clock
1 7.	Technical Assessment Group ready to accept responsibilities. Log and inform the Emergency Coordinator.	
1 8.	Discuss any additional support or supplies required with th	e Admin Coordinator.

OPERATIONS	
1 *1.	Engineering Personnel that leave the Facility should check out with the Security Officer. If a release has occurred or is likely to occur a HP brief is required. CARS 199701061
*2.	If personnel are dispatched to another facility a follow up call should be initiated in 15-20 minutes to ensure they arrive safely. CARS 199901904
• *3.	To obtain Plant Status Boards printout from the Plant Computer terminals (not PCs), Cancel , enter FF ; select the TSC printer, then F1 . To use the color printer depress Ctrl & PF20 simultaneously.
4 .	Toggle between PSB1 and PSB2 using the Blue TOUCH areas on the Plant Computer terminals or keyboard commands on the PCs. To obtain area radiation monitors type ARM or PCD – Return .
() *5.	Inform the EC of any changes in EAL's or of any conditions or trends, that could cause a change in EAL's (i.e. radiation levels, releases, etc.).
• *6.	 Plant Computer turn on codes ARM Area Radiation Monitors PCD Dose Assessment general overview including MET data, Rad data and flow status. PCDU Dose Assessment for the Unit Vent, Containment and Aux Building releases. PCDRS Dose Assessment for Radwaste and Steam releases.
• *7.	 Upon entry into the Recirculation Phase of RHR perform the following: Direct the Chemistry Coordinator to obtain 12 hour RWST samples per CSP-ZZ-07540. Inform HPC of probable increase in Auxiliary Building dose rates. Inform HPC of possible valve leakage back to RWST, which could change dose rates.

	TURNOVER	
1 .	Incoming Technical Assessment Coordinator briefed on TSC status and review log.	
2.	Emergency Coordinator informed.	
3.	Turnover announced to Technical Assessment staff.	
D 5.	Turnover complete Time.	
6.	Turnover logged.	
7.	Initiate a new checklist CA# 261.	

Rev. 029

TECHNICAL ASSESSMENT COORDINATOR (TAC) CHECKLIST

	RECOVERY	
1 .	Assess the following: a. Plant equipment status b. Accident assessment c. Control of radiological releases d. Ability to resume normal operations	
2.	Continue Technical Assessment activities until directed otherwise by the Emergency Coordinator or RM.	

	TERMINATION and SHUTDOWN	
1 .	When directed by the Emergency Coordinator, inform Tech Assessment staff of deactivation.	
2.	Ensure equipment and supplies are deactivated and/or stored.	
D 3.	Ensure documents are collected and given to the Admin Coordinator.	
4.	Restore PC UPS power supply to LINE.	
D 5.	Restore TSC Air Handling Unit Control Switch to <u>AUTO</u> position.	

Technical Assessment Coordinator Signature

TECHNICAL ASSESSMENT COORDINATOR (TAC) CHECKLIST

PLANT COMPUTER GUIDE

COLOR AND DESCRIPTION OF COMPUTER POINT QUALITY CODES

The Plant Computer System (PCS) assigns a "Data Quality Code" to each field input and calculated variable at the time the point is processed. These quality codes are determined by a series of checks/tests performed during both input-data validation and point processing. A list of the quality codes follows, which is ordered by severity:

- 1. **UNK** (Blue) Unknown; point not yet processed. If a point is deleted from processing when SAIPMS is first activated, "UNK" quality code is assigned. This quality code is also displayed for calculated or derived points which have not yet cycled through their first processing period.
- 2. **DEL** (Blue) Point has been deleted from processing. If a point was active when the SAIPMS software was activated, and was subsequently disabled from processing, the quality code "DEL" is assigned and no further engineering unit conversion is attempted.
- 3. NCAL (Blue) Derived point not calculable. This quality code is assigned when it has been determined that insufficient inputs exist to accurately perform the associated equation or calculation.
- 4. INVL (Blue) Invalid code is generated when a point's defined hardware channel address has not been selected, does not exist, or cannot be accessed. This usually indicates either an invalid hardware channel address, or a failed hardware component. For example, if a defined card slot address does not contain a card, all points assigned to that card are tagged as INVL. Also, if a multiplexer has either failed or been taken offline, all points assigned to that multiplexer are tagged as INVL.
- 5. **RDER** (Blue) Sensor Read Error code is generated when no test return/input is received for a point in response to a scan command/output to a valid hardware channel address. This usually indicates a faulty sensor or a multiplexer communication problem. Whenever a quality code of RDER is observed, a hardware error condition exists.
- 6. **OTC** (Blue) Open thermocouple.
- 7. BAD (Blue) The BAD (Bad Scanned Value) code is generated when the "corrected" scanned value (i.e. adjusted for A/D gain and zero-drift error) exceeds the sensor range as defined by a point's "SENSOR LIMIT LOW" and "SENSOR LIMIT HIGH" values in the database.
- 8. **HRL** (Blue) Point exceeds high reasonable limits. This condition is tested after engineering unit conversion and if the value exceeds the defined High Reasonable limit, a quality code of "HRL" is assigned.
- LRL (Blue) Point exceeds low reasonable limits. This condition is tested after engineering unit conversion and if the value exceeds the defined Low Reasonable limit, a quality code of "LRL" is assigned.
- REDU (Cyan) Point fails redundant point check. If a point has a defined Redundant Point and its current value does not match the defined point within the specified tolerance, it is assigned a quality code of "REDU".

TECHNICAL ASSESSMENT COORDINATOR (TAC) CHECKLIST

PLANT COMPUTER GUIDE

- 11. **HIHI**(Red) Point above high alarm limit. This condition is met when a point's current value has exceeded the defined High Alarm limit, and is assigned a quality code of "HIHI".
- 12. LOLO (Red) Point below low alarm limit. This condition is met when a point's current value is less than the defined LOW Alarm limit, and is assigned a quality code of "LOLO".
- 13. **HALM** (Yellow) Point above high warning limit. This condition is met when a point's current value has exceeded the defined High Operating limit, and is assigned a quality code of "HALM".
- 14. **LALM** (Yellow) Point below low warning limit. This condition is met when a point's current value is below the defined Low Operating limit, and is assigned a quality code of "LALM".
- 15. ALM (Red) State/Change-of-State alarm. Any logical-value point may be alarm monitored against either a defined logical state (i.e., "TRUE", or "FALSE"), or a defined change-of-state condition (i.e., "TRUE" to "FALSE", "FALSE" to "TRUE", or either state change). A quality code of "ALM" is assigned if the point meets any of the above conditions.
- 16. **SUB** (Cyan) Substitute value inserted for point. If a substitute value has been entered for a point, the point is assigned a quality code of "SUB", and no further alarm checks or engineering unit conversions are made.
- 17. **DALM** (Cyan) Point is deleted from alarm checks. If a point is currently disabled from alarm processing, it is assigned a quality code of "DALM", and no further alarm checks are made.
- 18. **INHB** (Green) Point is inhibited from alarm by cut-out point. If a point has an assigned cut-out point, and the current state of the cut-out point matches the specified alarm inhibit state, the point is assigned a quality code of "INHB", and no alarm transaction is generated. While inhibited, the point value WILL continue to update, only the alarm condition is inhibited.
- 19. **GOOD** (Green) Point passed all the above checks. The quality code "GOOD" indicates that all defined alarm conditions, states, or values have not been exceeded or met.

OPERATIONS SUPPORT COORDINATOR (OSC) CHECKLIST

Date _____ Time: _____

	INITIATION
Q 1.	 Card in on the accountability card reader. Sign in on Facility Sign-in board. Obtain the OSC package. Clip on the Operations Support Coordinator badge.
2.	Ensure the TSC has power. Normal power Normal power No Power. Start the TSC diesel per OOA-UB-EPG70 or call for Equipment operator if available
3 .	Inform Emergency Coordinator and Admin. Coordinator of your arrival.
4.	Initiate Log Sheet.
D 5.	Control Room/TSC Liaison contacted and status brief obtained.
G 6.	Contact Emergency Team Coordinator(s) (ETC) and obtain the Support Area (SA) status.
7.	Personnel Assessment
	a. Emergency Team Coordinator (s) Mechanical: (name) (1 required)
	Electrical:(name) (1 required)
	b. Personnel: Mechanics(number) (2 required) Electricians(number) (2 required) I&C Techs(number)(This should include the shift Techs) (2 required) Storekeeper(name) (1 required)
8.	OSC Group ready for responsibilities Time. (Also make log entry).
9.	Emergency Coordinator and Admin. Coordinator informed OSC ready.
1 0.	Discuss any additional support or supplies required with the Admin Coordinator. OSA Support Request may be made utilizing page 3 of 3 of this attachment.

	OPERATIONS (*) Steps are items that MUST be frequently reviewed
• *1.	Maintain contact with Control Room/TSC Liaison and keep Emergency Coordinator informed of significant activities/events.
• *2.	Inform the ETC that Support Area Personnel that leave the Facility should check out with the Security Officer. If a release has occurred or is likely to occur a HP brief is required. CARS 199701061
• *3.	If personnel are dispatched to another facility a follow up call should be initiated in 15-20 minutes to ensure they arrive safely. CARS 199901904
4 .	Ensure Emergency Teams are formed and briefed as needed per EIP-ZZ-00220 Emergency Team Formation.
• *5.	Ensure Emergency Team Coordinators track Teams as to location and progress of their assignment.
•6.	Interface with the Technical Assessment and Health Physics Groups to ensure coordination of activities.
7.	If accountability is declared, provide Security Coordinator with badge numbers of personnel that have been assigned to an emergency team that has left the TSC.

Rev. 029

OPERATIONS SUPPORT COORDINATOR (OSC) CHECKLIST

- .

1 *8	Monitor TSC operating equipment periodically:
- 0.	□ TSC Emergency Diesel.
	□ TSC Emergency Ventilation Filter System. (<i>NOTE</i> : Be aware of rapidly changing radiation levels
	during periods of releases.)
•9.	Periodically brief the Emergency Coordinator on the priorities that have been established for Emergency Teams.
	CARS 199903669

TURNOVER	
Q 1.	Incoming OSC Coordinator briefed on OSC status and review log.
Q 2.	Notify the Emergency Team Coordinators of the turnover.
D 3.	Notify the Control Room/TSC Liaison of the turnover.
4.	Emergency Coordinator informed.
D 5.	Turnover complete Time.
6.	Turnover logged.
D 7.	Initiate a new checklist CA# 262.

	RECOVERY	
1 1.	Assess the following:	
	 Plant equipment status. Emergency team status. All Emergency Team work needs to be completed, turned over to Recovery or normal maintenance. Ability to resume normal operations 	
2.	Continue Operations Support activities until directed otherwise by the Emergency Coordinator or RM.	

	TERMINATION and SHUTDOWN	
1 .	Upon direction of the Emergency Coordinator/Administrative Coordinator, contact the Emergency Team Coordinator and inform of deactivation	
2.	Ensure OSC/SA equipment and supplies are deactivated and/or stored.	
3 .	Ensure documents are collected and given to the Admin Coordinator.	

Operations Support Coordinator Signature

OPERATIONS SUPPORT COORDINATOR (OSC) CHECKLIST

EIP-ZZ-00240 Rev. 029

OSA SUPPORT REQUEST

Administrative (Admin.) Coordinator,

The operations support in the (osit) requires the fond this support is noticed (on of one)
--

Immediately	At next Shift, at	(enter time)
POSITION		NUMBER NEEDED
Operations Support Coordinator		
Electrical Emergency Team Coordinator		
Mechanical Emergency Team Coordinator		
Storekeeper		
Mechanical Supervisor		
Electrical Supervisor		
I&C Supervisor		······································
Mechanical Planner		
Electrical Planner		
I&C Planner		
Electrician		<u></u>
Machinist		
Welder		<u></u>
I & C Technician		
Electrical Apprentice		
Machinist Apprentice		
Welder Apprentice		
I&C Apprentice		
Insulator		
Plant Helper		
Nuclear Utility Worker		
Tool Room Mechanic		
Operating Supervisor (Shift Superv	visor concurrence obtained)	
Equipment Operator (Shift Supervi	sor concurrence obtained)	

ATTACHMENT 3 CA-#262

ADMINISTRATIVE (ADMIN) COORDINATOR CHECKLIST

Date _____ Time: ___

 INITIATION

 Image: Initiate Log Sheet.

	OPERATIONS CARS 199903558 (*) Steps or items that must be frequently reviewed
1.	Equipment availability and operation.
	 Personal Computers (PC) SENTRY Computer (NOTE: Ensure SENTRY is operational) CARS 200105707 Telephones Copier Fax Reader/Printer Print Plotter
2.	Status TSC Coordinators and keep the EC informed periodically until all positions are filled.
•	 Technical Assessment Coordinator Health Physics Coordinator Operations Support Coordinator TSC (ENS) Communicator Chemistry Coordinator Security Coordinator
• *3.	Check status of TSC emergency responders per EIP-ZZ-00200 Attachment 2. DO NOT delete messages until all positions are filled. Distribute copies of Attachment 2 to the coordinators periodically until all positions are filled. Paging or calling using the Emergency phone directory may be required. Call 64777 to obtain Audix. Enter 68400 and the # sign. Enter the password which is only the # sign. Follow the instructions to listen to the new messages and complete attachment 2.
4.	Personnel Assessment Admin/Clerical Support Personnel (call in as necessary) CARS 199903558 (name) One NIS Support person should be considered. (name) One person to callout/canvass additional support. (name) One person for the RM in the EOF. (name) One person for the LSC in the EOF. (name) One person for the EC in the TSC. (name) (name) (name) (name) (name) (name) (name) (name) (name)
• *5.	 Monitor the Declaration Status Boards. Ensure the Declaration Status Boards are current with the Emergency Classification announcements. CARS 199903558 Monitor the receipt of SENTRY Notifications at LAN printer and /or Fax machine and deliver to ENS Communicator.

Rev. 029

ADMINISTRATIVE (ADMIN) COORDINATOR CHECKLIST

•6.	Personnel that leave the Facility should check out with the Security Officer. If a release has occurred or is likely to occur a HP brief is required. CARS 199701061	
*7.	If personnel are dispatched to another facility a follow up call should be initiated in 15-20 minutes to ensure they arrive safely. CARS 199901904	
1 *8	Ensure the availability of the following administrative services:	
— 0.	Typing, Word Processing	
	Copying, Reproduction	
	□ Fax	
	Document control	
	Drawings	
	□ Message and mail Delivery	
	Telephone Repair and Installation	
	🗖 Radio Repair (Ameren Telecom.)	
└ * 9.	(LSC) in the EOF to address the following items for site personnel.	
	□ Contact Security for number of personnel inside the protected area. CARS 199903558	
	□ Meals ordered and scheduled for the entire organization; personnel informed of meal times and	
	locations.	
	Steeping space arranged for emergency personnel: personnel informed as to location.	
	Shift schedule prepared for emergency personnel: appropriate personnel notified. (Use the sign in	
	board and Emergency Telephone Directory to make up roster.)	
	Janitorial/waste disposal services arrangements made.	
1 *10.	Requests for additional vendor support personnel are to be coordinated with the Logistics Support Coordinator in the EOF.	
	Obtain the following information from the Logistics Support Coordinator:	
	\square Name(s) of personnel	
	\square Social Security Number	
	Work space requirements	
	\Box Estimated time of arrival	
	Contact:	
	□ Supervisor Admin. Access Control and arrange for plant access as required.	
	□ Plant helper group to set up desk etc., as required.	
	Coordinate respects for additional equipment with the Lexistics Courset Coordinates in the EOE	
└ *11.	Coordinate requests for additional equipment with the Logistics Support Coordinator in the EOF.	
	Obtain the information from the requesting organization and supply it to the Logistics Support Coordinator:	
	Explicit equipment requirements in writing	
	□ Amount needed	
	Delivery location	
	Person on site to contact	
■ *12.	Contact the Logistical Support Coordinator in the EOF and coordinate to provide Administrative Support to the entire organization.	
*13	In the event of an accident or illness perform the following: (Note: DO NOT release the individual's name.)	
	Call the control room (CR/TSC Liaison via OSC) and obtain the following. CARS 199903558	
	□ Nature of injury or illness.	
	□ Contaminated?	
	Transported offsite to doctor, hospital etc.	
	□ If the incident may attract media attention call the JPIC Administrator or Coordinator and supply them	
	with the information.	

ADMINISTRATIVE (ADMIN) COORDINATOR CHECKLIST

	TURNOVER
1 .	Brief the incoming Admin. Coordinator of the status of administrative activities and review log.
2.	Notify the Admin. and clerical staff of the turnover.
3 .	Notify the Emergency Coordinator turnover complete.
4.	Turnover complete Time.
5 .	Turnover logged.
6.	Initiate a new Checklist CA# 263.

	RECOVERY
1 .	Continue Administrative activities until directed otherwise by the Emergency Coordinator or RM.

TERMINATION and SHUTDOWN			
1.	Upon direction of the Emergency Coordinator, begin terminating operation as follows		
		Responsibilities transferred to the Control Room.	
	All functional equipment/supplies have been restored to startup conditions.		
	Records collected, and forwarded to Emergency Preparedness Department.		
		Staff relieved of TSC duties.	
2.	Control	Room informed of TSC shutdown.	
1 3.	TSC sh	ut down Time	

Administrative Coordinator Signature

Rev. 029

HEALTH PHYSICS (HP) COORDINATOR CHECKLIST

.

Date _____ Time: _____

	INITIATION			
1.	Card in on the ac Close front door Direct incoming Sign in on Facilit Obtain the Healt	countability card reader. to vestibule and back hallway door from support area. traffic to enter through portal monitor ty Sign-in board. n Physics Coordinators package. h Physics Coordinators badge		
Q 2.	Inform Emergency Coordinate	or and Admin. Coordinator of your presence.		
3 .	Initiate Log Sheet.			
4.	Shift the HPC Plant Computer	power supply to the UPS position.		
D 5.	Personnel Assessment On Sh	lift:		
	Concerns. Status setup of Con Tech to provide HP coverage f	(name) HP Ops Shift Technician (HPOPS) . Obtain Plant status and radiological trol Room / Field Office in accordance with EIP-ZZ-00102 , Attachment 2. HPOPS for On Shift personnel as directed by Shift Supervisor.		
	meteorological, and Protecti	(name) HP Tech Support Technician (HPTS) . Obtain Plant, radiological release, ve Action Recommendation status from the HPTS Tech performing dose assessment		
	sampling and analysis as nee are qualified as Support Are	(name) Chemistry Technician . The Chemistry Technician is responsible for eded to identify the source and magnitude of the emergency. Chemistry Technicians a Personnel in the Health Physics group.		
6.	NOTE: Minimun Assign personnel as they	OSA Responders n 14 R/C Support Personnel required, (one MUST be a Chemistry Tech.) arrive to the TSC based on priorities, <u>not</u> as listed, using the below guidance.		
1.		Contact the DAC and discuss the need to Assign R/C Support Personnel to the Rapid Plume Assessment Tech, (RPAT) position if not already dispatched.		
2		 Assign 2 R/C Support Personnel to FMTs. Request Drivers from the OSC. Brief the teams and drivers in accordance with EIP-ZZ-00211. 		
4		 Assign 2 R/C Support Personnel to the EOF for Dose Assessment Staff and FMT Communicator. Brief with FMTs if personnel are available, but do not delay dispatching. 		
6.		 Assign R/C Support Personnel to perform Onsite survey of plume if a release is suspected or in progress, monitor habitability of MAF, Field Office, HPAC, and Control Room as needed. 		
7.		Assign R/C Support Personnel to monitor Plant Computer Screens, maintain Facility Log, and answer phones / radio. Initiate FF Logs and update HPC on any changes approx. every 15 minutes. Wind speed and wind direction should be closely monitored along with In Plant radiological conditions.		

		Rev. 029
HEALTH PHYSICS (HP)	COORDINATOR	CHECKLIST

		Assign R/C Support Personnel to the report directly to the OSC to support Radiological Briefing and Emergency Teams. Have R/C Techs response check portable instruments, prepare equipment and supplies, and activate the Automated Access Control Station. All prepared radiological briefings should be reviewed with HPC prior to conducting brief of Emergency Team.
		Assign Chemistry Support Personnel to the Chemistry Coordinator (if needed).
13		Assign R/C Support Personnel to communicate with the NRC via the HPN line (if requested from NRC).
14		Assign R/C Support Personnel to maintain Habitability of TSC per Initiation Step 8 and Operation Step 10 of HPC Checklist. Direct R/C Tech to conduct HP briefs and provide dosimetry for personnel leaving the facility that are not assigned to Emergency Teams (as needed).
 7. Contact Dose Assessment Coordinator (DAC) at EOF (ext. 64999): — Inform DAC of RPAT, FMT, Dose Assessment Staff, and FMT Communicator d 		inator (DAC) at EOF (ext. 64999): AT, FMT, Dose Assessment Staff, and FMT Communicator deployment status.
Establish Radiological Habit Portal Monitor ener Set up a frisking sta AMS 3 energized au Control Dosimetry	abili gized tion nd so place	ty Controls in the TSC: d and response checked. using a model 177 Rate Meter, as needed, to backup the portal monitor. burce checked. ed at HPC Desk.
Notify Emergency Coordinator that HP is ready for operation and habitability in the TSC is established. HP Group ready for responsibilities at Time. (Also make log entry)		
	Contact Dose Assessment Co — Inform DAC of Establish Radiological Habit	Image: Contact Dose Assessment Coord Image: Control Dosimetry Place Notify Emergency Coordinator th HP Group ready for responsibilitit

<u>OPERATIONS</u> (*) Steps are items that must be frequently reviewed.				
• *1.	Make Facility Announcement that "All personnel leaving the TSC should check out with the Security Officer prior to leaving the facility." If a release is in progress or anticipated announce "an HP brief will also be required."			
	NOTE: If a release is in progress or anticipated, ensure all personnel dispatched from the TSC are issued Electronic Dosimeters and dose is tracked. The Security Officer will verify HP briefs prior to exit.			
4 *2.	If personnel are dispatched to another facility a follow up call should be initiated in 15-20 minutes to ensure they arrive safely. CARS 199901904.			
1 *3.	Review needed protective actions for On Site personnel:			
	Ensure dosimetry issued to Security personnel and Security Coordinator briefed on radiological conditions, wind speed and direction.			
	 Coordinate Assembly and Evacuation actions per EIP-ZZ-00230 with the Security Coordinator. (Assembly and Evacuation are required at a SITE and GENERAL EMERGENCY. When discussing Evacuation routes utilizing MAGNEM, use the 10 Mile projected map.) Determine which Care and Reception Center is preferred based on plume direction (if needed). Determine need for R/C Support Personnel to monitor Assembly and Evacuation. 			
	Evaluate restricting access to areas due to release or potential release based on wind direction.			
	 Evaluate need for Respiratory Protection per HTP-ZZ-01201. Evaluate Potassium Iodide (KI) distribution to Emergency Teams, Ops Department and Security personnel per HDP-ZZ-01300. 			

	Rev. 029
	HEALTH PHYSICS (HP) COORDINATOR CHECKLIST
4.	Obtain Respirator Issue Log and Daily Dose Report from HPACA if LAN and Mainframe Computer are unavailable in the TSC.
• *5.	Monitor Area Radiation Monitors and appropriate Group 1 & 2 EAL's from EIP-ZZ-00101, Classification of Emergencies. Report any Area Radiation Monitor that is approaching or has exceeded EAL values to the Technical Assessment Coordinator and EC.
a *6.	Personnel requiring decontamination should be sent to HPACA. If needed, the back entrance of the TSC can be staged to receive contaminated personnel.

• *7.	Verify sufficient inventory of the following (additional quantities are available from HPAC or Cal Facility):
	 Electronic Dosimeters (ED) Portable Instruments Respirators Protective Clothing (PC) Consumables (rope, postings, bags, etc.)
• *8.	Consider preparation of Emergency Dose Extensions for selected Operations Support Area personnel in the event Plant radiological conditions change in accordance with HDP-ZZ-01450.
• *9.	Monitor Plant conditions and emergency activities to ensure personnel dose is maintained ALARA.
	 Monitor and trend Plant Area Radiation monitors, including Control Room and HPACA. Radiation levels are expected to increase when Safety Injection recirculation is lined up to Containment.
	Monitor the RWST radiation levels when in the recirculation mode. Notify the EC and make amountain the TSC on Padiological Conditions change.
	 Nonry the EC and make announcements to the FSC as Kaulological Conditions change. Establish radiological postings in the Plant as time and resources allow (MUST be performed prior to Re-entry).
* 10.	Monitor facility habitability radiological conditions and recommended appropriate protective actions:
	 Direct dose rate ≥600 mrem/hr, inform the EC, and commence monitoring cumulative dose. Cumulative dose of ≥4,400 mrem, recommend evacuation of the facility.
	□ Direct dose rate of \geq 5,000 mrem/hr, recommend evacuation.
	☐ Iodine concentrations of ≥2.4E ⁻⁶ µCi/ml, inform the EC, and commence air sampling to ensure total intake does not exceed 25 rem CDE.
	□ Iodine concentrations of $\geq 1.9E^{-5}\mu Ci/ml$, recommend evacuation.
• *11.	Periodically update the Emergency Coordinator on radiological conditions in the Plant and the status of TSC habitability.
*12.	If additional HP support or supplies are needed, coordinate requests through the Admin. Coordinator or Stores person.

	TURNOVER		
D 1.	Brief the oncoming HP Coordinator on radiological information, and any protective actions, both recommended and implemented.		
Q 2.	Brief the oncoming HP Coordinator on the status of deployed Emergency Teams.		
3 .	Review HPC Checklist and Log.		
4.	Contact Dose Assessment Coordinator in EOF — Arrange for FMT turnover. — Obtain weather forecast. — Inform DAC of oncoming relief.		

Rev. 029

	HEALTH PHYSICS (HP) COORDINATOR CHECKLIST		
5 .	Notify the Emergency Coordinator of the Turnover		
6.	Turnover complete Time.		
7.	Turnover logged.		
8.	Initiate a new Checklist CA# 264.		

RECOVERY			
1.	Discuss:		
	□ Maintain □ Survey a	ning of personnel exposure ALARA and preventing spread of contamination. and Posting Status.	
	□ Need to □ Decontar	implement EIP-ZZ-00225, Reentry mination activities.	
	Need forLong ter	r additional assistance, supplies, or equipment. rm monitoring.	
2.	Continue HP operation	ns until directed otherwise by the Emergency Coordinator or RM.	

	TERMINATION and SHUTDOWN		
D 1.	Upon direction of the Emergency Coordinator/Admin. Coordinator, notify R/C personnel of shutdown.		
2.	Turn over any HP support to normal plant staff.		
1 3.	Contact DAC in EOF.		
4.	Ensure HP equipment is de-energized, supplies and materials are stored as required. (Note: Gamma 10 should remain on.)		
D 5.	Ensure documents are collected and given to the Admin. Coordinator.		
G 6.	Restore HPC Plant Computer UPS power supply to LINE position.		

HP Coordinator Signature

HEALTH PHYSICS (HP) COORDINATOR CHECKLIST

GAMMA-10 PORTAL MONITOR RESPONSE CHECK

<u>NOTE:</u> The key for the electronics cabinet is attached to the response source.

- 1. Verify 110 VAC power to the unit (green operational light is illuminated and no alarms are activated).
- 2. Set the NIMBIN power supply On-Off switch to ON and ensure the power light is illuminated.
- 3. Set the HV-2 NIM On-Off switch to on and ensure the Positive LED is illuminated.
- 4. Verify that a current calibration label is affixed to the Electronics Box and the pot settings, on the box, are the same as identified on the label.
- 5. Inspect the monitor for physical damage.
- 6. Verify no alarms are activated. If alarms are activated clear alarms before continuing.
- 7. Ensure green operational light is illuminated.
- 8. Pass the Gamma-10 Response Source through the central region of the monitor. The Contamination alarm should activate on the box, a light and buzzer, and a red light on the portal should illuminate.
- 9. Depress the reset button on the portal. The alarms should clear and the green operational light should remain lit.
- 10. If the monitor passes this check, initial and date the Pre-Operational Check Sticker affixed to the Electronics Box.

If the monitor fails the Pre-Operational Checks, tag the unit Out Of Service and notify the Health Physics Coordinator. Set up Frisking Station and have personnel entering the building and those already in the building frisk for contamination, if it is expected.

Rev. 029

HEALTH PHYSICS (HP) COORDINATOR CHECKLIST

AMS-3 STARTUP AND OPERATION

This Startup Sequence augments HTP-ZZ-04137, Operation of the Eberline AMS-III. It is designed to be used in an Emergency Response Facility when an HP Operations Technician is not immediately available.

- 1) Connect AMS-3 (monitor) and air sampler to 110 VAC power.
- 2) Ensure monitor and air sampler have current calibration label.
- 3) Inspect the chart paper. Ensure an adequate supply of paper remains. If a RED line appears on the chart paper, notify Health Physics and continue the startup procedure.
- 4) Set monitor ON-OFF switch (located on back of monitor) to the ON position. Allow monitor to warm-up for 5 minutes.
- 5) Set BACKGROUND SUBTRACT switch (located on front of monitor) to the ON position.
- 6) Push in "PUSH TO SET" on bottom left side of monitor and note the alarm setpoint value of 20,000 cpm (this is the first scale mark to the right of the 10^4 scale value.
- 7) Set alarm setpoint to 1000 cpm by adjusting the SET knob while holding in "PUSH TO SET" button.
- 8) Remove sample holder located on the right front side of monitor by loosening the clamp and pulling out on handle.
- 9) Obtain check source from HP E-Kit Locker. Center source over sample holder opening with the recessed side of the source bracket facing the opening.
- 10) The audible alarm and the alarm light should energize (activate). If not notify Health Physics. (The startup procedure should not continue until the problem is resolved).
- 11) Press ACKNOWLEDGE button to silence alarm.
- 12) Verify count rate on chart recorder is as indicated on the response value listed on back of source bracket or a sticker on the instrument.
- 13) Remove check source. Ensure alarm light resets and count rate decreases on chart recorder.
- 14) Remove the filter in the filter holder. (Remove the filter retaining ring on the filter holder, this snaps on the end of the filter holder assembly, and may fit somewhat tight.)
- 15) Obtain a new filter from the HP Emergency Kit Locker and place it on the sample holder with the "ROUGH SIDE" of filter facing upwards.
- 16) Replace retaining ring on the sample holder and insert the sample holder into the sample chamber. Lock the filter holder into place.
- 17) Set the alarm setpoint to 20,000 cpm by adjusting the SET knob while holding in the "PUSH TO SET" button.
- 18) Place the toggle switch on the power cord to the "ON" position. The air sampler pump should start.
- 19) Ensure airflow as indicated on flowmeter is within the tolerance listed on the calibration label (read the flow at the center of the rotometer float ball.) If it is not, notify Health Physics.
- 20) Initial and date the Preoperational Check sticker.
HEALTH PHYSICS (HP) COORDINATOR CHECKLIST SET-UP AND OPERATION OF THE MODEL 177 RATEMETER

- 1. Remove Model 177 ratemeter, frisker probe, detector cable, power cord, and check source from the E-Kit cabinet.
- 2. Connect detector and power cords, if not already connected, to the Model 177 ratemeter and verify the following switch settings:

Front Panel: 1. On/Off switch in "ON" position.

- 2. Volume adjusted to hear audible counts.
- 3. Response switch in "slow" position.
- 4. Range switch to "X1" scale.

Rear Panel: 1. Alarm set at '5'.

- 2. Subtract switch in "Off" position if meter has Subtract Switch.
- 3. Perform response check as follows:
 - Ensure instrument has a current calibration sticker.
 - Set the range switch to the appropriate position and place the detector on the check source bracket.
 - Verify the response is within the acceptable range as specified on the response value determination form/sticker for that check source.
 - Check the instrument alarm by adjusting the ALARM SET switch so that it is slightly less than the count rate of the source.
 - Remove the source from the detector.
 - Depress the RESET button. The alarm condition should clear.
 - If the pre-operational checks are satisfactory, complete the attached preoperational check sticker. If either the alarm or the response check failed, notify the Health Physics Coordinator and obtain an operational ratemeter.
- 4. Return the check source to the E-Kit cabinet.

Rev. 029

TSC COMMUNICATOR (ENS) CHECKLIST

	Date Time:	
	INITIATION	
1	□ Card in on the accountability card reader.	
	Sign in on Facility Sign-in board.	
	Obtain the ENS Communicators package.	
	Clip on the Communicators badge.	
D 2.	Ensure the TSC has power.	
	Normal power, (i.e. lights on, power available to computers, etc.).	
	□ No Power. Start the TSC diesel per OOA-UB-EPG70 call for Equipment Operator if available.	
D 3.	Shift the PC power supplies to the UPS position.	
4.	Emergency Coordinator and Admin Coordinator informed of your presence.	
5.	Initiate Log sheet.	
6 .	Activate Plant Status Boards on the Plant Computer (Cancel, type PSB, Return).	
1 7.	Check dial tone on the ENS line.	
8.	Contact Control Room Communicator.	
9.	Get a brief as to the status of ENS Communications.	
1 0.	Accept responsibility of ENS Communications per EIP-ZZ-00201, CA-#2517B, or as directed by the NRC.	•
L 11.	Discuss any additional support or supplies required with the Admin Coordinator.	

OPERATIONS

(*) Steps are items that must be frequently reviewed.		
		Call the NRC or accept transfer from the Control Room on the ENS line and inform them of your name and that
		you are communicating from the Canaway Plant Technical Support Center.
🔲 *′	2	Remain on the phone and gather facts as requested by the NRC from individual positions, plant computer or status
	<i>_</i> .	boards and relay those facts back to the NRC, per EIP-ZZ-00201. (All notifications transmitted to the State and
		local agencies should also be given to the NRC Operations Center unless directed otherwise.)
	3	Log information requested and relayed to the NRC as deemed appropriate.
	4	Personnel that leave the Facility should check out with the Security Officer. If a release has occurred or is likely to
	•	occur a HP brief is required. CARS 199701061
	5	If personnel are dispatched to another facility a follow up call should be initiated in 15-20 minutes to ensure they
	-	arrive safely. CARS 199901904

TURNOVER		
1 .	Brief the incoming ENS Communicator on the status of NRC requests, awaiting information and review log.	
2 .	Log turnover.	
3 .	Turnover complete Time.	
4.	Inform Emergency Coordinator or Technical Assessment Coordinator turnover complete.	
5.	Initiate a new checklist CA# 265.	

 RECOVERY

 1.
 Continue providing the NRC with requested information.

TERMINATION and SHUTDOWN		
1.	When directed, assist with the TSC deactivation.	
2.	Ensure area is put into order and logs collected and give to the Admin Coordinator.	
□ 3.	Restore PC UPS power supply to LINE.	

Rev. 029

CHEMISTRY COORDINATOR CHECKLIST

Date _____ Time: _____

	INITIATION	
1.	 Card in on the accountability card reader. Sign in on Facility Sign-in board. Obtain the Chemistry Coordinators package. Clip on the Chemistry Coordinators badge. 	
Q 2.	Inform Emergency Coordinator and Admin. Coordinator of arrival and ready to assume duties of Chemistry Coordinator. (Make log entry.)	
3 .	Initiate Log sheet.	
4.	 Contact on shift Chemistry Tech and ensure Remind on-duty Chem tech to card in at the Field Office during accountability. RERP vehicle is operational and in the parking lot. All sample results are updated immediately on Chemistry Data Management System (CDMS). Verify CCW is lined up to the SJ panel. 	
D 5.	Personnel Assessment Rad./Chem. Chemistry technicians (2 required) (name),(responsibilitie) (responsibilitie) (name),(responsibilitie)	es) ies)
	Image: Construction of the second seco	
6.	Assign an available Chemistry Supervisor to the Hot Lab as needed.	
7.	Discuss plant chemistry status with Emergency Coordinator and Tech Assessment Coordinator.	

<u>OPERATIONS</u> (*) Steps are items that must be frequently reviewed.		
• * 1.	Review and distribute updated CDMS data as it becomes available:	
	Give a copy of CDMS Data to the: Tech Assessment Coordinator. HP Coordinator. Reactor Engineer.	
• *2.	Personnel that leave the Facility should check out with the Security Officer. If a release has occurred or is likely to occur a HP brief is required. CARS 199701061	
• *3.	If personnel are dispatched to another facility a follow up call should be initiated in 15-20 minutes to ensure they arrive safely. CARS 199901904	
• 4.	Compare latest results of Dose Equivalent I-131 and 100/E bar total specific activity to Group 2 & 4 EAL's per EIP-ZZ-00101 , Classification of Emergencies, and report any EAL that is being approached or exceeded to the Technical Assessment Coordinator and Emergency Coordinator.	
• *5.	Evaluate Secondary Chemistry conditions including Primary-to-Secondary Leakage, SEE CTP-ZZ-02590 and APA-ZZ-01023.	
6.	If Post Accident Sample is requested, refer to CTP-ZZ-08100 located in CC Packet.	

Rev. 029

CHEMISTRY COORDINATOR CHECKLIST

₩ *7.	Monitor Post Accident Sampling data and provide recommendations as necessary.
₩ *8.	On a SI actuation, SJ sample cooling water will be lost.
	 Request the Tech to secure high temp samples. Request Ops to open EGHV69A & B and EGHV70A & B to restore cooling flow as soon as practical.
	CVCS letdown samples will remain representative as long as letdown flow is available.
□ *9.	Identify additional support (e.g. personnel, off-site analysis) and coordinate requests through the Admin Coordinator.

	TURNOVER		
1.	Brief the incoming Chemistry Coordinator of Chemistry activities and review log.		
2.	Notify the Tech. Assessment Coordinator of the Turnover.		
3 .	Turnover complete Time.		
4.	Turnover logged.		
D 5.	Initiate new checklist.		

	RECOVERY]
1 .	Continue Chemistry activities until directed otherwise by the Emergency Coordinator or RM.	~

	TERMINATION and SHUTDOWN	
1 .	Upon direction assist with TSC deactivation.	
2.	Ensure Chemistry work area is deactivated and/or stored.	
1 3.	Ensure documents are collected and given to the Admin Coordinator.	

Chemistry Coordinator Signature

Rev. 029

SECURITY COORDINATOR (SC) CHECKLIST

Date _____ Time: _____

		INITIATION
	1.	□ Card in on the accountability card reader.
	••	□ Sign in on Facility Sign-in board.
		Obtain the Security Coordinators package.
		□ Clip on the Security Coordinators badge.
	2.	Inform Emergency Coordinator and Admin. Coordinator of arrival.
	3.	Initiated Log sheet.
Ū,	4.	Personnel Assessment (Call in extra personnel as required).
		Contact the Shift Security Supervisor and obtain number and names of security personnel available for assignment.
	5.	Station security officers at the Emergency Response Facilities entrances to log personnel entrance and egress.
	6.	Discuss any additional support or supplies required with the Admin Coordinator.

OPERATIONS			
	(*) Steps are items that must be frequently reviewed.		
• *1.	Conduct normal and emergency security activities in accordance with the Security Plan. If the plan cannot be followed, obtain authorization from the EC to deviate (refer to OTO-SK-00001 Attachment 1), in accordance with 10 CFR50.54(x)(y) to deviate. Inform the ENS Communicator (1 hour NRC notification). CARS 199901754		
4 *2.	Assist the EC in Evacuation and Accountability per EIP-ZZ-00230.		
3.	If accountability is declared, obtain badge numbers of personnel assigned to emergency teams that have left the TSC from the OSC, and report these badge numbers to the SSS.		
4 .	Personnel that leave the Facility should check out with the Security Officer. If a release has occurred or is likely to occur a HP brief is required. CARS 199701061		
• *5.	If personnel are dispatched to another facility a follow up call should be initiated in 15-20 minutes to ensure they arrive safely. CARS 199901904		
4 *6.	Contact the HP Coordinator to determine the affected areas in the case of a release. If Security is to be pulled back from their posts, consider requirements in Step 1, Operations (above).		
• *7.	Ensure that the Security Force has the appropriate dosimetry. Check with the HPC.		
*8.	Coordinate plant access control.		
• *9.	Contact local law enforcement to coordinate traffic control (i.e. for evacuation routes).		
• *10.	Coordinate personnel evacuation and accountability. (<i>NOTE:</i> Accountability is required within 30 minutes of declaring accountability.)		
• *11.	Coordinate any off-site law enforcement agency involvement.		

SECURITY COORDINATOR (SC) CHECKLIST

<u>TURNOVER</u>			
1.	Brief the incoming Security Coordinator of Security activities and review log.		
2 .	Notify the Emergency Coordinator of the turnover.		
3 .	Turnover complete Time.		
4.	Turnover logged.		
5 .	Initiate new checklist.		

	RECOVERY
1 .	Continue Security activities until directed otherwise by the Emergency Coordinator.

TERMINATION and SHUTDOWN		
1 1.	Upon direction assist with TSC deactivation.	
2.	Ensure security equipment is deactivated and/or stored.	
3 .	Ensure documents are collected and given to the Admin Coordinator.	

Security Coordinator Signature

EMERGENCY TEAM COORDINATOR (ETC) CHECKLIST

			Date	Time:	
 INITIATION					
1.	 Card in on the accountability card reader. Sign in on Facility Sign-in board. Obtain the ETC package. Clip on the Emergency Team Coordinator badge. 				
2.	Inform Operations Support Coordinator (OSC) of your ar	rival. If O	SC has not reported,	initiate OSC Checklist.	
3.	Initiate Log Sheet.				
4.	Personnel Assessment (number) Supervisor a. Management: b. Personnel: Machinist/Welders (2 required) Electricians (2 required) Plant Helpers Nuclear Utility Workers I&C	//	Planner	(machinist) (welder)	
5	Other				
5.	ETC Crown ready for rearrangibilities Time (Also make log entry)				
6.	The Also make log end y).				
7.	Operations Support Coordinator informed ETC ready.				
8	Brief and Pre-stage an investigative/search & rescue team for immediate response. Team members can be reassigned after accountability and job priorities are completed.				
9.	Discuss any additional support or supplies required with the Admin Coordinator. Page 3 of 3 of this attachment, OSA Support Request, may be used as an aid.				

OPERATIONS		
(*) Steps are items that MUST be frequently reviewed		
•1.	Keep Operations Support Coordinator informed of significant activities/events.	
• *2.	Inform Support Area Personnel that leave the Facility that they should check out with the Security Officer. If a release has occurred or is likely to occur a HP brief is required. CARS 199701061	
•3.	Ensure Emergency Teams are formed and briefed as needed per EIP-ZZ-00220 Emergency Team Formation.	
•4.	Ensure Emergency Teams are tracked to location and progress of their assignment at specified intervals.	
a *5.	Interface with the Health Physics Groups to ensure coordination of activities.	
•6.	Ensure log and status board are maintained.	

EMERGENCY TEAM COORDINATOR (ETC) CHECKLIST

*7	Periodically brief OSA Support personnel on Plant status and job priorities

TURNOVER			
1 1.	Incoming ETC Coordinator briefed on ETC status and review log.		
2.	Notify the Operations Support Coordinator of the turnover.		
3 .	Notify the OSA Support personnel of the turnover.		
4.	Turnover complete Time.		
5 .	Turnover logged.		
6.	Initiate a new checklist CA#0262a.		

RECOVERY			
1. Assess the following:			
		Emergency team status. All Emergency Team work is completed or turned over to the Recovery Organization or normal maintenance.	
		Able to resume normal operations.	
2.	Continue En	nergency Team activities until directed otherwise by the Operations Support Coordinator.	

TERMINATION and SHUTDOWN		
1 .	Ensure OSA equipment and supplies are deactivated and/or stored.	
2.	Ensure documents are collected and given to the Admin Coordinator.	

Emergency Team Coordinator Signature

EMERGENCY TEAM COORDINATOR (ETC) CHECKLIST

4

OSA SUPPORT REQUEST

Administrative (Admin.) Coordinator,			
The Operations Support Area (OSA) requires the following support. This support is needed (circle one)			
Immediately	At next Shift, at	(enter time)	
POSITION		NUMBER NEEDED	
Operations Support Coordinator			
Electrical Emergency Team Coordin			
Mechanical Emergency Team Coord	linator		
Storekeeper			
Mechanical Supervisor		ut t = //www.se-uuut t	
Electrical Supervisor			
I&C Supervisor	-		
Mechanical Planner			
Electrical Planner			
I&C Planner		······································	
Electrician			
Machinist			
Welder	-		
I&C Technician			
Electrical Apprentice			
Machinist Apprentice			
Welder Apprentice			
I&C Apprentice		, 011, 200 000,000	
Insulator		·····	
Plant Helper			
Nuclear Utility Worker			
Tool Room Mechanic			
Operating Supervisor (Shift Supervisor concurrence obtained)			
Equipment Operator (Shift Supervis	or concurrence obtained)		

ATTACHMENT 9 CA-#262a