

JUL 1 1974

JUL 1 1974

Docket Nos. 50-250
and 50-251

Florida Power & Light Company
ATTN: Dr. Robert E. Uhrig
Director of Nuclear Affairs
P. O. Box 3100
Miami, Florida 33101

Gentlemen:

DISTRIBUTION:

- Docket Files (Environ) (2)
- AEC PDR
- Local PDR
- EP-1 Reading
- L Reading
- RPurple
- RO (3)
- RVollmer, L:QA
- PCollins, L
- LChandler
- KRGoller
- HDenton, SS, L
- MJinks (4)
- VMoore, AD/LWR
- SSheppard, LWR 1-2 (7)
- BScharf (15)
- ACRS
- TBAbernathy, DTIE
- JBuchanan, ORNL
- EChristopherson, PNL (3)
- MSlater
- GWKnighton
- RCleveland
- DRMuller
- DElliott, OR-1

By letter dated May 20, 1974, you proposed a revision to the Environmental Technical Specifications attached as Appendix B to Facility Operating Licenses DPR-31 and DPR-41 for the Turkey Point Nuclear Plant Units 3 and 4. This revision was to permit a new submittal date for the report due by August 30, 1974 on the evaluation of effects of short-term exposures to temperatures and salinities that might be experienced under emergency conditions. This report is now proposed to be submitted by November 1, 1974.

We have reviewed the proposal and approve it. The revision in reporting date is a minor change, and its approval appears warranted. We conclude that the change does not involve significant hazards consideration and there is reasonable assurance that the health and safety of the public will not be endangered. Accordingly, Amendments Nos. 3 and 2 to Facility Operating Licenses Nos. DPR-31 and DPR-41 respectively are enclosed revising the Technical Specifications thereto to authorize the requested changes effective July 1, 1974. A copy of a notice which is being forwarded to the Office of the Federal Register for publication relating to this action is also enclosed for your information.

Sincerely,

S/
Karl R. Goller, Assistant Director
for Operating Reactors
Directorate of Licensing

Enclosures:

1. Amendment No. 3 to License DPR-31
2. Amendment No. 2 to License DPR-41
3. Federal Register Notice

KXRK

~~L: LWR 1-2~~
~~RPurple~~

cc w/enclosures: See page 2

6/ 174 CP file

OFFICE >	L:EP-1	L:EP-1	L:AD/EP	OGG	L:OR-1	EX L:AD/OR
SURNAME >	RCleveland:sh	GWKnighton	DRMuller	LChandler	RPurple	KRGoller
DATE >	6/ 174	6/ 174	6/ 174	6/ 174	6/ 174	6/ 174

DATE					
SURNAME					
OFFICE					

The Technical Specifications contained in Appendix A and B attached to Facility Operating License No. DPR-31 are revised as indicated in the attachment to this license amendment. The Technical Specifications, as

"(2) Technical Specifications

2. Accordingly, Paragraph 3.B. of Facility License No. DPR-31 is hereby amended to read as follows:

- A. The application for amendment by Florida Power and Light Company dated May 20, 1974, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended, and the Commission's rules and regulations set forth in 10 CFR Chapter 1:
- B. The facility will operate in conformity with the license, the provisions of the Act, and the rules and regulations of the Commission;
- C. There is reasonable assurance (1) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (2) that such activities will be conducted in compliance with the Commission's regulations;
- D. The issuance of this amendment will not be injurious to the common defense and security or to the health and safety of the public, and
- E. Prior public notice of this amendment is not required since the amendment does not involve a significant hazards consideration.

Amendment No. 3
License No. DPR-31

AMENDMENT TO FACILITY OPERATING LICENSE

TURKEY POINT NUCLEAR PLANT, UNIT 3

DOCKET NO. 50-250

FLORIDA POWER AND LIGHT COMPANY

revised, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications, as revised."

3. This license amendment is effective July 1, 1974.

FOR THE ATOMIC ENERGY COMMISSION

Karl R. Goller, Assistant Director
for Operating Reactors
Directorate of Licensing

Attachment:
Change No. 15 to Appendix B,
Technical Specifications

OFFICE ➤						
SURNAME ➤						
DATE ➤						

DATE					
SURNAME					
OFFICE					

The technical specifications contained in Appendix A and B attached to Facility Operating License No. DPR-41 are revised as indicated in the attachment to this license amendment. The technical specifications, as

"(2) Technical Specifications

2. Accordingly, Paragraph 3.B. of Facility License No. DPR-41 is hereby amended to read as follows:

- A. The application for amendment by Florida Power and Light Company dated May 20, 1974, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended, and the Commission's rules and regulations set forth in 10 CFR Chapter 17.
 - B. The facility will operate in conformity with the license, the provisions of the Act, and the rules and regulations of the Commission.
 - C. There is reasonable assurance (1) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (11) that such activities will be conducted in compliance with the Commission's regulations.
 - D. The issuance of this amendment will not be injurious to the common defense and security or to the health and safety of the public, and
 - E. Prior public notice of this amendment is not required since the amendment does not involve a significant hazards consideration.
1. The Atomic Energy Commission (the Commission) has found that:

Amendment No. 2
License No. DPR-41

AMENDMENT TO FACILITY OPERATING LICENSE

TURKEY POINT NUCLEAR PLANT, UNIT 4

DOCKET NO. 58-251

FLORIDA POWER AND LIGHT COMPANY

revised, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications, as revised."

3. This license amendment is effective July 1, 1974.

FOR THE ATOMIC ENERGY COMMISSION

Karl E. Celler, Assistant Director
for Operating Reactors
Directorate of Licensing

Attachment:
Change No. 15 to Appendix B,
Technical Specifications

OFFICE						
SURNAME						
DATE						

traveling screens or in the cooling system canals, notification should be made within 24 hours by telephone or telegraph to the Director of the Region II Field Office of the Directorate of Regulatory Operations.

- *f. Entrained Organisms: The effect of passage through the licensed facilities on survival of plant and animal forms will be evaluated to the level that present "state-of-the-art" techniques will permit. Representative water samples will be collected once every two weeks at the licensed facilities intake, plant discharge, a point partway down the Card Sound Canal, and at the discharge points of Grand Canal and Card Sound Canal into Biscayne Bay and Card Sound, respectively. The samples will be examined for numbers and kinds of representative organisms and their survival at different locations will be measured by applicable state-of-the-art techniques. Results will be compared with similar samples taken from four points in Biscayne Bay and Card Sound that are outside the influence of power plant operations.
- |Change 13
|Change 9
|Change 9

The data obtained from the above programs (paragraphs 1.a through 1.f) shall be analyzed as they are collected and will be compared with model and analytical predictions and preoperational data that have been collected. A report to the AEC of the results of this evaluation will be submitted within 60 days of the end of each six-month period or fraction thereof terminating on June 30 and December 31 of each year. At the end of each year, the program and the need for its continuance will be reevaluated.

- g. Tolerance studies: Laboratory studies will be performed as a supplement to the existing programs being conducted by the University of Miami under AEC/FPL sponsorship to evaluate the effect of short-term exposures to temperatures and salinities that might be experienced under emergency conditions. These studies will be evaluated and a report submitted to the AEC by November 1, 1974 on the findings and any need for additional information.
- |Change 15

*See Section 4.a.3, page 12.

|Change 13

July 1, 1974

Docket Nos. 50-250
and 50-251

DISTRIBUTION:
Docket File (Environ) (2)
EP-1 Reading
L Reading
GWKnighton
RCleveland
MSlater

Frank Karas, Chief
Public Proceeding Staff
Office of the Secretary

FEDERAL REGISTER NOTICE OF ISSUANCE OF FACILITY LICENSE AMENDMENTS FOR
THE TURKEY POINT NUCLEAR PLANT, UNITS NOS. 3 AND 4

Two signed originals of a Federal Register Notice identified as follows
are enclosed for transmittal to the Office of the Federal Register for
filing and publication.

FLORIDA POWER AND LIGHT COMPANY

TURKEY POINT NUCLEAR PLANT,

UNITS NOS. 3 AND 4

NOTICE OF ISSUANCE OF FACILITY LICENSE AMENDMENTS

Twelve additional conformed copies are enclosed for your use.

George W. Knighton, Chief
Environmental Projects Branch #1
Directorate of Licensing

Enclosure:
As stated

OFFICE ➤	L:EP-1	XXXX L:EP-1	OGC	L:EP-1	
SURNAME ➤	MSlater:sh	RCleveland	LChandler	GWKnighton	
DATE ➤	6/ /74	6/ /74	6/ /74	6/ /74	

UNITED STATES ATOMIC ENERGY COMMISSION

DOCKET NOS. 50-250 AND 50-251

FLORIDA POWER AND LIGHT COMPANY

NOTICE OF ISSUANCE OF FACILITY LICENSE AMENDMENTS

Notice is hereby given that the U. S. Atomic Energy Commission (the Commission) has issued Amendments Nos. 3 and 2 to Facility Operating Licenses Nos. DPR-31 and DPR-41 respectively issued to Florida Power and Light Company which revised Technical Specifications for operation of the Turkey Point Nuclear Plant, Units 3 and 4, located in Dade County, Florida. The amendments are effective July 1, 1974.

The amendments permit a new submittal date for the report due by August 30, 1974 on the evaluation of the effects on the marine environment of short-term exposures to temperatures and salinities that might be experienced under emergency conditions.

The application for the amendments complies with the standards and requirements of the Act and the Commission's rules and regulations and the Commission has made appropriate findings as required by the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations in 10 CFR Chapter 1, which are set forth in the license amendments.

OFFICE ➤						
SURNAME ➤						
DATE ➤						

For further details with respect to this action, see (1) the application for the amendments dated May 20, 1974, and (2) Amendments Nos. 3 and 2 to licenses Nos. DPR-31 and DPR-41, with any attachments, and (3) the letter to Florida Power and Light Company (transmitting Amendments Nos. 3 and 2) which includes an evaluation of the requested change. All of these are available for public inspection at the Commission's Public Document Room, 1717 H Street, N.W., Washington, D.C. and at the Lily Lawrence Row Public Library, 212 N.W. First Avenue, Homstead, Florida 33030.

A copy of items (2) and (3) may be obtained upon request addressed to the United States Atomic Energy Commission, Washington, D. C. 20545, Attention: Deputy Director for Reactor Projects, Directorate of Licensing - Regulation.

Dated at Bethesda, Maryland, this day of

FOR THE ATOMIC ENERGY COMMISSION

George W. Knighton, Chief
Environmental Projects Branch No. 1
Directorate of Licensing

OFFICE ➤						
SURNAME ➤						
DATE ➤						

DATE						
SURNAME						
OFFICE						

Mr. Shepard N. Moore
 Environmental Protection Agency
 1421 Peachtree Street
 Atlanta, Georgia 30309

Mr. Sheldon Meyers
 Office of Federal Activities
 Environmental Protection Agency
 Room W-541, Waterside Mall
 401 M Street, S.W.
 Washington, D. C. 20460

Mr. Ed Maroney
 Bureau of Intergovernmental
 Relations
 725 South Bronough Street
 Tallahassee, Florida 32304

Honorable Ray Goode
 County Manager of Metropolitan
 Dade County
 Miami, Florida 33130

Jack R. Newman, Esq.
 Newman, Hays & Axelrad
 1025 Connecticut Avenue, N.W.
 Washington, D. C. 20006

Florida Power & Light Company