

FEB 18 1982

DISTRIBUTION  
Dockets  
NRC PDR  
L PDR  
NSIC  
ORB#1 Rdg  
DEisenhut  
CParrish  
MGrotenhuis  
OELD  
IE  
TBarnhart-8  
LSchneider  
DBrinkman  
ACRS-10  
OPA  
RDiggs  
ASLAB  
Gray File

Docket Nos. 50-250  
and 50-251

LICENSE AUTHORITY HERE GOES

*Posted*

*Amdt. 71  
to DPR-41*

DO NOT REPLY

Dr. Robert E. Uhrig, Vice President  
Advanced Systems and Technology  
Florida Power and Light Company  
Post Office Box 529100  
Miami, Florida 33152

Dear Dr. Uhrig:

The Commission has issued the enclosed Amendment No. 77 to Facility Operating License No. DPR-31 and Amendment No. 71 to Facility Operating License No. DPR-41 for the Turkey Point Plant Unit Nos. 3 and 4, respectively. The amendments consist of changes to the Technical Specifications in response to your application transmitted by letter dated January 13, 1982.

These amendments clarify the boron concentration required during the refueling operation by including the  $\Delta k/k$  requirement of 10% in the Technical Specification as well as the boron concentration..

Copies of the Safety Evaluation and the Notice of Issuance are also enclosed.

Sincerely,

ORIGINAL SIGNED

Marshall Grotenhuis, Project Manager  
Operating Reactors Branch #1  
Division of Licensing

Enclosures:

1. Amendment No. 77 to DPR-31
2. Amendment No. 71 to DPR-41
3. Safety Evaluation
4. Notice of Issuance

cc w/enclosures:  
See next page

*[Signature]*  
\*Previous concurrences see next page

ORIGINATOR	ORB#1:DL*	ORB#1:DL*	ORB#1:DL*	AD/OR:DL*	OELD*	FRN & admnt only
SURNAME	CParrish	MGrotenhuis	SVarga	TNovak	M. Young	conditioned on [unclear]
DATE	02/ /82	02/14/82:ds	02/ /82	02/ /82	02/12/82	FA [unclear] to [unclear]

Robert E. Uhrig  
Florida Power and Light Company

cc: Mr. Robert Lowenstein, Esquire  
Lowenstein, Newman, Reis and Axelrad  
1025 Connecticut Avenue, N.W.  
Suite 1214  
Washington, D. C. 20036

Environmental and Urban Affairs Library  
Florida International University  
Miami, Florida 33199

Mr. Norman A. Coll, Esquire  
Steel, Hector and Davis  
1400 Southeast First National  
Bank Building  
Miami, Florida 33131

Mr. Henry Yaeger, Plant Manager  
Turkey Point Plant  
Florida Power and Light Company  
P. O. Box 013100  
Miami, Florida 33101

Honorable Dewey Knight  
County Manager of Metropolitan  
Dade County  
Miami, Florida 33130

Bureau of Intergovernmental Relations  
560 Apalachee Parkway  
Tallahassee, Florida 32304

Resident Inspector  
Turkey Point Nuclear Generating Station  
U. S. Nuclear Regulatory Commission  
Post Office Box 1207  
Homestead, Florida 33030

Regional Radiation Representative  
EPA Region IV  
345 Courtland Street, N.W.  
Atlanta, Georgia 30308

Mr. Jack Shreve  
Office of the Public Counsel  
Room 4, Holland Building  
Tallahassee, Florida 32304

Administrator  
Department of Environmental  
Regulation  
Power Plant Siting Section  
State of Florida  
2600 Blair Stone Road  
Tallahassee, Florida 32301

James P. O'Reilly  
Regional Administrator - Region II  
U. S. Nuclear Regulatory Commission  
101 Marietta Street - Suite 3100  
Atlanta, Georgia 30303



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

FLORIDA POWER AND LIGHT COMPANY

DOCKET NO. 50-250

TURKEY POINT PLANT UNIT NO. 3

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 77  
License No. DPR-31

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Florida Power and Light Company (the licensee) dated January 1, 1982, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 3.B of Facility Operating License No. DPR-31 is hereby amended to read as follows:

(B) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 77, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

  
Steven A. Varga, Chief  
Operating Reactors Branch #1  
Division of Licensing

Attachment:  
Changes to the Technical  
Specifications

Date of Issuance: February 18, 1982



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

FLORIDA POWER AND LIGHT COMPANY

DOCKET NO. 50-251

TURKEY POINT PLANT UNIT NO. 4

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 71  
License No. DPR-41

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Florida Power and Light Company (the licensee) dated January 1, 1982, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 3.B of Facility Operating License No. DPR-41 is hereby amended to read as follows:

(B) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 71, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

  
Steven A. Varga, Chief  
Operating Reactors Branch #1  
Division of Licensing

Attachment:  
Changes to the Technical  
Specifications

Date of Issuance: February 18, 1982

ATTACHMENT TO LICENSE AMENDMENTS

AMENDMENT NO. 77 TO FACILITY OPERATING LICENSE NO. DPR-31

AMENDMENT NO. 71 TO FACILITY OPERATING LICENSE NO. DPR-41

DOCKET NOS. 50-250 AND 50-251

Revise Appendix A as follows:

Remove Pages

3.10-2

B3.10-1

Insert Pages

3.10-2

B3.10-1

5. At least ONE residual heat removal pump shall be in operation, unless  $T_{avg}$  is less than 160F.
6. When the reactor vessel head is removed and fuel is in the vessel, the minimum boron concentration of 1950 ppm or higher, sufficient to maintain the reactor subcritical by  $10\% \Delta k/k$  in the cold condition with all rods inserted shall be maintained in the reactor coolant system and the concentration shall be verified daily.
7. Direct communication between the control room and the refueling cavity manipulator crane shall be available during refueling operation.
8. The spent fuel cask shall not be moved over spent fuel, and only one spent fuel assembly will be handled at one time over the reactor or the spent fuel pit.
9. Fuel which has been discharged from a reactor will not be moved outside the containment in fewer than 100 hours after shutdown

If any one of the specified limiting conditions for refueling is not met, refueling shall cease until specified limits are met, and there shall be no operations which may increase reactivity.



### B3.10 BASES FOR LIMITING CONDITIONS FOR OPERATION, REFUELING

Detailed instructions, safety precautions and the design of the fuel handling equipment, incorporating built-in interlocks and safety features, provide assurance that no incident could occur during the refueling operations that would result in a hazard to public health and safety.<sup>(1)</sup> Whenever changes are not being made in core geometry one flux monitor is sufficient. This permits maintenance of the instrumentation. Continuous monitoring of radiation levels and neutron flux provides immediate indication of an unsafe condition. The residual heat pump is used to maintain a uniform boron concentration.

A boron concentration of 1950 ppm was sufficient to maintain the reactor subcritical by at least  $10\% \Delta k/k$  in the cold condition with all rods inserted, and also maintained the core subcritical with no control rods inserted, for the first core design.<sup>(2)</sup> The required boron concentration may increase depending on the subsequent core design.

The control room operator will be able to inform the manipulator operator of any impending unsafe condition detected from the control board indicators during fuel movement.

The cask crane interlocks prevent cask handling above spent fuel. An excess weight interlock is provided on the spent fuel bridge crane hoist to prevent movement of more than one fuel assembly at a time. The spent fuel transfer mechanism can accommodate only one fuel assembly at a time.

#### References

- (1) FSAR - Section 9.5
- (2) FSAR Table 3.2.1-1



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION  
RELATED TO AMENDMENT NO. 77 TO FACILITY OPERATING LICENSE NO. DPR-31  
AND AMENDMENT NO. 71 TO FACILITY OPERATING LICENSE NO. DPR-41  
FLORIDA POWER AND LIGHT COMPANY  
TURKEY POINT PLANT UNIT NOS. 3 AND 4  
DOCKET NOS. 50-250 AND 50-251

I. Introduction

By letter dated January 13, 1982, the Florida Power and Light Company (the licensee) submitted a request to modify the Technical Specifications, Appendix A to Facility Operating Licenses DPR-31 and DPR-41, for the Turkey Point Plant, Unit Nos. 3 and 4. The proposed amendments clarify the boron concentration required during the refueling operation by including the  $\Delta k/k$  requirement of 10% in the Technical Specifications as well as the boron concentration.

II. Evaluation

The current Technical Specifications (3.10.6) require a minimum boron concentration of 1950 ppm in the reactor coolant system when the reactor vessel head is removed and fuel is in the vessel. This concentration must be verified daily. The bases (B3.10) indicate that 1950 ppm is sufficient to maintain the reactor subcritical by 10%  $\Delta k/k$  in the cold condition with all rods inserted, and will also maintain the core subcritical with no control rods inserted.

In the design of the earlier cores, the refueling boron concentration of 1950 ppm provided a 10% subcriticality with all rods inserted in the cold condition (reference Table 3.2.1-1 of FSAR). Also, the reactor stayed subcritical with all rods out in the cold condition.

Current cores, such as the Cycle 8 redesign core, are designed for a longer (18 month) operation and have more initial reactivity than the earliest cores. A higher boron concentration than 1950 ppm may be required to keep the core subcritical by 10%  $\Delta k/k$  in cold condition with all rods inserted and will also keep the core subcritical with all rods out (reference Table-1).

The required refueling boron concentration has to be calculated for each core design and for each nuclear unit but shall not be less than 1950 ppm.

Since the refueling boron concentration will keep the core subcritical by 10%  $\Delta k/k$  the safety of the plant operation will not be compromised.

TABLE - 1  
RCS BORON CONCENTRATIONS

	FSAR (1ST CYCLE)	CYCLE - 8 (UNIT - 3)	
		<u>0 MTC</u>	<u>+ MTC *</u>
Refueling Shutdown; Rods in (k = .90)	1950	2000	2200
(k = .95)		1520	1700
Shutdown (k = .99) with Rods Inserted, Clean, Cold	780	1180	1350
Shutdown (k = .99) with Rods Inserted, Clean, Hot	510	750	1080
Shutdown (k = .99) with No Rods Inserted, Clean, Cold	1250	1570	1720
Shutdown (k = .99) with No Rods Inserted, Clean, Hot	1210	1610	1890

NOTES:

- \* Cycle 8 for Turkey Point Unit 3 is designed with an alternate Positive Moderator Temperature Coefficient (+ MTC) core.

### III. Environmental Consideration

We have determined that the amendments do not authorize a change in effluent types or total amounts nor an increase in power level and will not result in any significant environmental impact. Having made this determination, we have further concluded that the amendments involve an action which is insignificant from the standpoint of environmental impact and, pursuant to 10 CFR 51.5(d)(4), that an environmental impact statement or negative declaration and environmental impact appraisal need not be prepared in connection with the issuance of these amendments.

### IV. Conclusion

We have concluded, based on the considerations discussed above, that: (1) because the amendments do not involve a significant increase in the probability or consequences of accidents previously considered and do not involve a significant decrease in a safety margin, the amendments do not involve a significant hazards consideration, (2) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and (3) such activities will be conducted in compliance with the Commission's regulations and the issuance of these amendments will not be inimical to the common defense and security or to the health and safety of the public.

Date: February 18, 1982

UNITED STATES NUCLEAR REGULATORY COMMISSIONDOCKET NOS. 50-250 AND 50-251FLORIDA POWER AND LIGHT COMPANYNOTICE OF ISSUANCE OF AMENDMENT TO FACILITY  
OPERATING LICENSES

The U. S. Nuclear Regulatory Commission (the Commission) has issued Amendment No. 77 to Facility Operating License No. DPR-31, and Amendment No. 71 to Facility Operating License No. DPR-41 issued to Florida Power and Light Company (the licensee), which revised Technical Specifications for operation of Turkey Point Plant, Unit Nos. 3 and 4 (the facilities) located in Dade County, Florida. The amendments are effective as of the date of issuance.

The amendments clarify the boron concentration required during the refueling operation by including the  $\Delta k/k$  requirement in the Technical Specifications as well as the boron concentration.

The application for amendments complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR Chapter I, which are set forth in the license amendments. Prior public notice of these amendments was not required since the amendments do not involve a significant hazards consideration.


The Commission has determined that the issuance of these amendments will not result in any significant environmental impact and that pursuant to 10 CFR §51.5(d)(4) an environmental impact statement or negative declaration and environmental impact appraisal need not be prepared in connection with issuance of these amendments.

- 2 -

For further details with respect to this action, see (1) the application for amendments dated January 13, 1982, (2) Amendment Nos. 77 and 71 to License Nos. DPR-31 and DPR-41, and (3) the Commission's related Safety Evaluation. All of these items are available for public inspection at the Commission's Public Document Room, 1717 H Street, N.W., Washington, D.C. and at the Environmental and Urban Affairs Library, Florida International University, Miami, Florida 33199. A copy of items (2) and (3) may be obtained upon request addressed to the U. S. Nuclear Regulatory Commission, Washington, D.C. 20555, Attention: Director, Division of Licensing.

Dated at Bethesda, Maryland, this 18th day of February, 1982.

FOR THE NUCLEAR REGULATORY COMMISSION

  
Steven A. Varga, Chief  
Operating Reactors Branch #1  
Division of Licensing