

NOV 4 1981

Docket Nos. 50-250  
and 50-251

Dr. Robert E. Uhrig, Vice President  
Advanced Systems and Technology  
Florida Power and Light Company  
Post Office Box 529100  
Miami, Florida 33152

Dear Dr. Uhrig:

We have completed our review of your request for an exemption from the requirements of Appendix J, for the Turkey Point Plant Unit Nos. 3 and 4. The request for exemption was with respect to testing frequency and method of testing as outlined in your letters dated September 12, 1975, and July 27, 1977. We have also evaluated your most recent submittal dated November 26, 1980 and find the alternative you proposed acceptable. Furthermore, no exemption from the requirements of Appendix J is necessary because your proposed alternative is within the revised version of Appendix J to 10 CFR Part 50 Section III.D.2 (effective October 22, 1980).

The Commission has issued the enclosed Amendment No. 73 to Facility Operating License No. DPR-31 and Amendment No. 67 to Facility Operating License No. DPR-41 for the Turkey Point Plant Unit Nos. 3 and 4, respectively. The amendments consist of changes to the Technical Specifications in response to your application transmitted by letter dated September 20, 1974, as supplemented on July 27, 1977.

These amendments revise the Technical Specifications to: (1) include the air lock testing according to Appendix J to 10 CFR Part 50; (2) make certain corrections in terminology to be consistent with Appendix J; and (3) make certain administrative corrections.

Copies of the Safety Evaluation and the Notice of Issuance are also enclosed.

Sincerely,

Original Signed By:

Marshall Grotenhuis, Project Manager  
Operating Reactors Branch No. 1  
Division of Licensing

Enclosures:

1. Amendment No. 73 to DPR-31
2. Amendment No. 67 to DPR-41
3. Safety Evaluation
4. Notice of Issuance

SEE PREVIOUS 318 FOR CONCURRENCES\*

OFFICE	cc: See next page	ORB 1*	ORB 1	ORB 1*	AD:OR*	OELD*
SURNAME		CParrish	MGrotenhuis	rsSVarga	INovak	
DATE		10/20/81	11/4/81	10/29/81	10/29/81	11/2/81

OFFICIAL RECORD COPY

DISTRIBUTION  
Docket File  
NRC PDR  
Local PDR  
NSIC  
TERA  
ORB 1 File  
D. Eisenhut  
C. Parrish  
M. Grotenhuis  
OELD  
OI&E (4)  
G. Deegan (8)  
B. Scharf (10)  
J. Wetmore  
ACRS (10)  
R. Diggs

LICENSE AUTHORITY FILE COPY

DO NOT REMOVE

Posted  
Amdt 67  
to DPR-41

Robert E. Uhrig  
Florida Power and Light Company

NOV 4 1981

cc: Mr. Robert Lowenstein, Esquire  
Lowenstein, Newman, Reis and Axelrad  
1025 Connecticut Avenue, N.W.  
Suite 1214  
Washington, D. C. 20036

Environmental and Urban Affairs Library  
Florida International University  
Miami, Florida 33199

Mr. Norman A. Coll, Esquire  
Steel, Hector and Davis  
1400 Southeast First National  
Bank Building  
Miami, Florida 33131

Mr. Henry Yaeger, Plant Manager  
Turkey Point Plant  
Florida Power and Light Company  
P. O. Box 013100  
Miami, Florida 33101

Honorable Dewey Knight  
County Manager of Metropolitan  
Dade County  
Miami, Florida 33130

Bureau of Intergovernmental Relations  
660 Apalachee Parkway  
Tallahassee, Florida 32304

Resident Inspector  
Turkey Point Nuclear Generating Station  
U. S. Nuclear Regulatory Commission  
Post Office Box 1207  
Homestead, Florida 33030

Regional Radiation Representative  
EPA Region IV  
345 Courtland Street, N.W.  
Atlanta, Georgia 30308

Mr. Jack Shreve  
Office of the Public Counsel  
Room 4, Holland Building  
Tallahassee, Florida 32304

Administrator  
Department of Environmental  
Regulation  
Power Plant Siting Section  
State of Florida  
2600 Blair Stone Road  
Tallahassee, Florida 32301



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

FLORIDA POWER AND LIGHT COMPANY

DOCKET NO. 50-251

TURKEY POINT PLANT UNIT NO. 4

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 67  
License No. DPR-41

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Florida Power and Light Company (the licensee) dated September 20, 1974, as supplemented on July 27, 1977, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and applicable requirements have been satisfied.


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 3.B of Facility Operating License No. DPR-41 is hereby amended to read as follows:

(B) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 67, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

  
Steven A. Larga, Chief  
Operating Reactors Branch #1  
Division of Licensing

Attachment:  
Changes to the Technical  
Specifications

Date of Issuance: November 4, 1981

ATTACHMENT TO LICENSE AMENDMENTS

AMENDMENT NO. 73 TO FACILITY OPERATING LICENSE NO. DPR-31

AMENDMENT NO. 67 TO FACILITY OPERATING LICENSE NO. DPR-41

DOCKET NOS. 50-250 AND 50-251

Revise Appendix A as follows:

Remove Pages

1-3  
1-6  
2.1-1  
T3.5-2  
3.6-1  
3.6-2  
3.10-2  
4.4-1  
4.4-2  
4.4-3  
4.4-4  
4.4-5  
4.4-6  
4.4-7  
4.7-1  
4.8-1  
4.8-2  
4.10-1  
B.2.3-2

Insert Pages

1-3  
1-6  
2.1-1  
T3.5-2  
3.6-1  
3.6-2  
3.10-2  
4.4-1  
4.4-2  
4.4-3  
4.4-4  
4.4-5  
4.4-6  
4.4-7  
4.7-1  
4.8-1  
4.8-2  
4.10-1  
B.2.3-2