

LICENSE AUTHORITY FILE COPY **DO NOT REMOVE**

July 22, 1985

*Posted
Correction to
Amends 106 & 108
for DPR-41*

Docket Nos. 50-250
and 50-251

Mr. J. W. Williams, Jr., Group Vice President
Nuclear Energy Department
Florida Power and Light Company
Post Office Box 14000
Juno Beach, Florida 33408

| Distribution | |
|---------------|---------------|
| Docket file | NRC PDR |
| ORB#1 RDG | L PDR |
| Gray file (4) | HThompson |
| CParrish | DMcDonald |
| OELD | LHarmon |
| EJordan | BGrimes |
| JPartlow | TBarnhart (8) |
| WJones | MVirgilio |
| ACRS (10) | OPA, CMiles |
| RDiggs | |

Dear Mr. Williams:

On April 22, 1985, the Commission issued Amendment Nos. 112 and 106 to Operating License Nos. DPR-31 and DPR-41 for the Turkey Point Plant Units 3 and 4, respectively. The amendments modified your Reactor Materials Surveillance Program. On June 27, 1985, the Commission issued Amendment Nos. 114 and 108 to the above referenced Operating Licenses. These amendments addressed containment integrity and surveillance testing during plant operation.

Your staff has brought to our attention administrative errors in conjunction with issuance of the amendments on Technical Specifications page iv (Amendment Nos. 112 and 106) and page 3.12-1 (Amendment Nos. 114 and 108). Reference to Section B3.17 was inadvertently left off of the Table of Contents, page iv. Specification 3.12-1 incorrectly had a decay time of 1000 hours due to a typographical error and a footnote was inadvertently omitted on the page.

Enclosed are the correct pages iv and 3.12-1. We have verified that the errors do not affect the amendments, the supporting Safety Evaluations and the corrections are consistent with the amendments. Please use the enclosed instruction sheet and replace the pages identified in Appendix A of Facility Operating License Nos. DPR-31 and DPR-41 with the corrected pages.

Please accept our apologies for any inconveniences these errors may have caused.

Sincerely,

/s/DGMcDonald

Daniel G. McDonald, Project Manager
Operating Reactors Branch #1
Division of Licensing

Enclosure:
As stated

cc w/enclosure:
See next page

*SEE PREVIOUS WHITE FOR CONCURRENCE

ORB#1:DL*
CParrish
07/17/85

ORB#1:DL
DMcDonald/ts
07/16/85

BE ORB#1:DL
SKarga
07/16/85

Docket Nos. 50-250
and 50-251

| Distribution | |
|---------------|---------------|
| Docket file | NRC PDR |
| ORB#1 RDG | L PDR |
| Gray file (4) | HThompson |
| CParrish | DMcDonald |
| OELD | LHarmon |
| EJordan | BGrimes |
| JPartlow | TBarnhart (8) |
| WJones | MVirgilio |
| ACRS (10) | OPA, CMiles |
| RDiggs | |

Mr. J. W. Williams, Jr., Group Vice President
Nuclear Energy Department
Florida Power and Light Company
Post Office Box 14000
Juno Beach, Florida 33408

Dear Mr. Williams:

On April 22, 1985, the Commission issued Amendment Nos. 112 and 106 to Operating License Nos. DPR-31 and DPR-41 for the Turkey Point Plant Units 3 and 4, respectively. The amendments modified your Reactor Materials Surveillance Program. On June 27, 1985, the Commission issued Amendment Nos. 114 and 108 to the above referenced Operating Licenses. These amendments addressed containment integrity and surveillance testing during plant operation.

Your staff has brought to our attention administrative errors in conjunction with issuance of the amendments on Technical Specifications page iv (Amendment Nos. 112 and 106) and page 3.12-1 (Amendment Nos. 114 and 108). Reference to Section B3.17 was inadvertently left off of the Table of Contents, page iv. Specification 3.12-1 incorrectly had a decay time of 1000 hours due to a typographical error and a footnote was inadvertently omitted the page.

Enclosed are the correct pages iv and 3.12-1. We have verified that the errors do not affect the amendments, the supporting Safety Evaluations and the corrections are consistent with the amendments. Please use the enclosed instruction sheet and replace the pages identified in Appendix A of Facility Operating License Nos. DPR-31 and DPR-41 with the corrected pages.

Please accept our apologies for any inconveniences these errors may have caused.

Sincerely,

Daniel G. McDonald, Project Manager
Operating Reactors Branch #1
Division of Licensing

Enclosure:
As stated

cc w/enclosure:
See next page

ORB#1:DL
CParrish
07/11/85

ORB#1:DL
DMcDonald/ts
07/ /85

BC-ORB#1:DL
SVarga
07/ /85

J. W. Williams, Jr.
Florida Power and Light Company

Turkey Point Plant

cc:

Harold F. Reis, Esquire
Newman and Holtzinger, P.C.
1615 L Street, N.W.
Washington, DC 20036

Mr. Jack Shreve
Office of the Public Counsel
Room 4, Holland Building
Tallahassee, Florida 32304

Norman A. Coll, Esquire
Steel, Hector and Davis
4000 Southeast Financial
Center
Miami, Florida 33131-2398

Mr. C. M. Wethy, Vice President
Turkey Point Nuclear Plant
Florida Power and Light Company
P.O. Box 029100
Miami, Florida 33102

Mr. M. R. Stierheim
County Manager of Metropolitan
Dade County
Miami, Florida 33130

Resident Inspector
U.S. Nuclear Regulatory Commission
Turkey Point Nuclear Generating Station
Post Office Box 57-1185
Miami, Florida 33257-1185

Mr. Allan Schubert, Manager
Public Health Physicist
Department of Health and
Rehabilitative Services
1323 Winewood Blvd.
Tallahassee, Florida 32301

Intergovernmental Coordination
and Review
Office of Planning & Budget
Executive Office of the Governor
The Capitol Building
Tallahassee, Florida 32301

Administrator
Department of Environmental
Regulation
Power Plant Siting Section
State of Florida
2600 Blair Stone Road
Tallahassee, Florida 32301

Regional Administrator, Region II
U.S. Nuclear Regulatory Commission
Suite 2900
101 Marietta Street
Atlanta, Georgia 30323

Martin H. Hodder, Esquire
1131 NE, 86th Street
Miami, Florida 33138

Joette Lorion
7269 SW, 54 Avenue
Miami, Florida 33143

Mr. Chris J. Baker, Plant Manager
Turkey Point Nuclear Plant
Florida Power and Light Company
P.O. Box 029100
Miami, Florida 33102

Attorney General
Department of Legal Affairs
The Capitol
Tallahassee, Florida 32304

Corrections

Amendment Nos. 112 and 114 to Facility Operating License DPR-31

Amendment Nos. 106 and 108 to Facility Operating License DPR-41

Docket Nos. 50-250 and 50-251

Revise Appendix A as follows:

Remove Pages

iv
3.12-1

Insert Pages

iv
3.12-1

TABLE OF CONTENTS (Continued)

| <u>Section</u> | <u>Title</u> | <u>Page</u> |
|----------------|--|-------------|
| B3.5 | Bases for Limiting Conditions for Operation, Instrumentation | B3.5-1 |
| B3.6 | Bases for Limiting Conditions for Operation, Chemical and Volume Control System | B3.6-1 |
| B3.7 | Bases for Limiting Conditions for Operation, Electrical Systems | B3.7-1 |
| B3.8 | Bases for Limiting Conditions for Operation, Steam and Power Conversion Systems | B3.8-1 |
| B3.9 | Bases for Limiting Conditions for Operation, Radioactive Materials Release | B3.9-1 |
| B3.10 | Bases for Limiting Conditions for Operation, Refueling | B3.10-1 |
| B3.11 | Bases for Limiting Conditions for Operation, Miscellaneous Radioactive Material Sources | B3.11-1 |
| B3.12 | Bases for Limiting Conditions for Operation, Cask Handling | B3.12-1 |
| B3.13 | Bases for Limiting Conditions for Operation, Snubbers | B3.13-1 |
| B3.14 | Bases for Fire Protection System | B3.14-1 |
| B3.15 | Bases for Limiting Conditions of Operation, Overpressure Mitigating System | B3.15-1 |
| B3.17 | Bases for Limiting Conditions for Operation, Spent Fuel Storage | B3.17-1 |
| B4.1 | Bases for Operational Safety Review | B4.1-1 |
| B4.2 | Bases for Reactor Coolant System In-Service Inspection | B4.2-1 |
| B4.3 | Bases for Reactor Coolant System Integrity | B4.3-1 |
| B4.4 | Bases for Containment Tests | B4.4-1 |
| B4.5 | Bases for Safety Injection Tests | B4.5-1 |
| B4.6 | Bases for Emergency Containment Cooling System Tests | B4.6-1 |
| B4.7 | Bases for Emergency Containment Filtering and Post Accident Containment Venting Systems Tests | B4.7-1 |
| B4.8 | Bases for Emergency Power System Periodic Tests | B4.8-1 |
| B4.9 | Bases for Main Steam Isolation Valve Tests | B4.9-1 |
| B4.10 | Bases for Auxiliary Feedwater System Tests | B4.10-1 |
| B4.11 | Bases for Reactivity Anomalies | B4.11-1 |
| B4.12 | Bases for Environmental Radiation Survey | B4.12-1 |
| B4.13 | Bases for Fire Protection Systems | B4.13-1 |
| B4.14 | Bases for Snubbers | B4.14-1 |
| B4.15 | Bases for Surveillance Requirements, Overpressure Mitigating System | B4.15-1 |
| B4.18 | Bases for System Flow Path Verifications | B4.18-1 |
| B4.19 | Bases for Reactor Coolant Vent System | B4.19-1 |
| B4.20 | Bases for Reactor Materials Surveillance Program | B4.20-1 |

3.12 CASK HANDLING

Applicability: Applies to limitations during cask handling.

Objective: To minimize the possibility of an accident during cask handling operations that would affect the health and safety of the public.

Specifications: During cask handling operations:

- (1) The spent fuel cask shall not be moved into the spent fuel pit until all the spent fuel in the pit has decayed for a minimum of one thousand (1,000) hours.
- (2) Only a single element cask may be moved into the spent fuel pit.
- (3) A fuel assembly shall not be removed from the spent fuel pit in a shipping cask until it has decayed for a minimum of one hundred and twenty (120) days.*
- (4) HEAVY LOADS shall be prohibited from travel over irradiated fuel assemblies in the spent fuel pool. (Refer to T.S. 3.10.9)

* The Region 10 fuel which was in the Unit 3 reactor during the period of April 19, 1981 through April 24, 1981 may be removed from the Unit 3 spent fuel pit in a shipping cask after a minimum decay period of ninety-five (95) days.

*Superseded by Correction
Letter of 7/22/85*