VERMONT YANKEE NUCLEAR POWER CORPORATION

185 OLD FERRY ROAD, PO BOX 7002, BRATTLEBORO, VT 05302-7002 (802) 257-5271

> December 4, 2001 BVY 01-91

U.S. Nuclear Regulatory Commission ATTN: Document Control Desk Washington, DC 20555

References:	(a)	The GESTR-LOCA and SAFER Models for the Evaluation of the Loss-						
	, ,	of-Coolant	Accident,	Volume	III,	SAFER/GE	ESTR	Application
		Methodology, NEDE-23785-1-P-A, General Electric Company, Revision						
		1, October 1984.						
						0 11 (00	N ((A	

- (b) Letter, C.O. Thomas (USNRC) to J.F. Quirk (GE), "Acceptance for Referencing of Licensing Topical Report NEDE-23785, Revision 1, Volume III (P), The GESTR-LOCA and SAFER models for the Evaluation of the Loss-of-Coolant Accident," June 1, 1984.
- (c) NEDC-32814P, "Vermont Yankee Nuclear Power Station SAFER/GESTR-LOCA Loss-of-Coolant Accident Analysis," dated March 1998.
- (d) 10CFR50.46 Notification Letter 2001-01, G.A.Watford (GE), "Impact of SAFER Condensation Error on the Peak Clad Temperature (PCT)," dated May 14, 2001.
- (e) 10CFR50.46 Notification Letter 2001-02, G.A. Watford (GE), "Impact of SAFER Pressure Rate Inconsistency Error on the Peak Clad Temperature (PCT)," dated May 10, 2001.

Subject: Vermont Yankee Nuclear Power Station License No. DPR-28 (Docket No. 50-271) Annual 10CFR50.46(a)(3)(ii) Report for 2001

The purpose of this letter is to report, in accordance with 10CFR50.46(a)(3)(ii), changes in peak cladding temperature (PCT) for Vermont Yankee's (VY) Emergency Core Cooling System (ECCS) Loss of Coolant Accident (LOCA) analysis. This annual report covers Cycle 22 from January to December 2001.

For Cycle 22, VY has used the General Electric (GE) SAFER/GESTR model for evaluation of the ECCS/LOCA (Reference a). This model has been approved by the USNRC in Reference (b) and is currently being utilized at the majority of operating Boiling Water Reactors. A plant specific analysis for VY was performed using SAFER/GESTR-LOCA methodology. The analysis was documented in Reference (c).

BVY 01-91 / Page 2

In Reference (d), GE assessed the impact of an error in the condensation model of the SAFER computer code. The condensation error had no impact on calculated PCT for VY.

In Reference (e), GE assessed the impact of the condensation error reported in Reference (d) on the SAFER pressure rate equation. The error resulted in an increase of 10 degrees F. in the calculated PCT for VY.

The above changes did not constitute "significant changes" as described in 10CFR50.46(a)(3)(i) and therefore, were not previously reported.

As a result of the use of the approved SAFER/GESTR model, including fuel changes and incorporation of methodology errors or changes, the limiting licensing basis fuel rod PCT for Cycle 22 remains less than 1860°F.

If you have any questions concerning this report, please contact Mr. Jim DeVincentis at (802) 258-4236.

Sincerely,

VERMONT YANKEE NUCLEAR POWER CORPORATION

Gautam Sen Licensing Manager

cc: USNRC Region 1 Administrator USNRC Resident Inspector – VYNPS USNRC Project Manager – VYNPS Vermont Department of Public Service

SUMMARY OF VERMONT YANKEE COMMITMENTS

BVY NO.: 01-91 "Annual 10CFR50.46(a)(3)(ii) Report for 2001"

•

The following table identifies commitments made in this document by Vermont Yankee. Any other actions discussed in the submittal represent intended or planned actions by Vermont Yankee. They are described to the NRC for the NRC's information and are not regulatory commitments. Please notify the Licensing Manager of any questions regarding this document or any associated commitments.

COMMITMENT	COMMITTED DATE OR "OUTAGE"
None	N/A

VYAPF 0058.04 AP 0058 Rev. 1 Page 1 of 1