

December 7, 2001

Mr. David A. Christian  
Senior Vice President and  
Chief Nuclear Officer  
Virginia Electric and Power Company  
Innsbrook Technical Center-2SW  
5000 Dominion Blvd.  
Glen Allen, Virginia 23060-6711

SUBJECT: NORTH ANNA POWER STATION, UNITS 1 AND 2: REQUEST FOR  
ADDITIONAL INFORMATION REGARDING SECTION 3.3.1, FUNCTION 6,  
DISCUSSION OF CHANGE L.21 OF THE IMPROVED TECHNICAL  
SPECIFICATIONS (ITS) (TAC NOS. MB1437 AND MB1432)

Dear Mr. Christian:

The NRC staff reviewed your application dated December 11, 2000, to change the format and content of the Current Technical Specifications to be consistent with NUREG-1431, "Standard Technical Specifications - Westinghouse Plants," Revision 1, and certain generic changes to the NUREG. On the basis of our review of the proposed changes for ITS Section 3.3.1, "Reactor Trip System (RTS) Instrumentation," we find that additional information identified in the paragraph below is required in order for the staff to complete this review.

Please describe in detail how the allowable value for the OT delta T was derived. Include in this description what assumptions were made (including the values that were omitted, and those that were included) and how the values that are included in the calculation are statistically combined.

This inquiry was discussed with Ms. Regina Borsh of your staff on November 20, 2001, who agreed to provide the staff with a response within 45 days of the date of this letter.

Sincerely,  
*/RA/*

Stephen R. Monarque, Project Manager, Section 1  
Project Directorate II  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket Nos. 50-338 and 50-339

cc: See next page

December 7, 2001

Mr. David A. Christian  
Senior Vice President and  
Chief Nuclear Officer  
Innsbrook Technical Center-2SW  
5000 Dominion Blvd.  
Glen Allen, Virginia 23060-6711

SUBJECT: NORTH ANNA POWER STATION, UNITS 1 AND 2: REQUEST FOR  
ADDITIONAL INFORMATION REGARDING SECTION 3.3.1, FUNCTION 6,  
DISCUSSION OF CHANGE L.21 OF THE IMPROVED TECHNICAL  
SPECIFICATIONS (ITS) (TAC NOS. MB1437 AND MB1432)

Dear Mr. Christian:

The NRC staff reviewed your application dated December 11, 2000, to change the format and content of the Current Technical Specifications to be consistent with NUREG-1431, "Standard Technical Specifications - Westinghouse Plants," Revision 1, and certain generic changes to the NUREG. On the basis of our review of the proposed changes for ITS Section 3.3.1, "Reactor Trip System (RTS) Instrumentation," we find that additional information identified in the paragraph below is required in order for the staff to complete this review.

Please describe in detail how the allowable value for the OT delta T was derived. Include in this description what assumptions were made (including the values that were omitted, and those that were included) and how the values that are included in the calculation are statistically combined.

This inquiry was discussed with Ms. Regina Borsh of your staff on November 20, 2001, who agreed to provide the staff with a response within 45 days of the date of this letter.

Sincerely,

*/RA/*

Stephen R. Monarque, Project Manager, Section 1  
Project Directorate II  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket Nos. 50-338 and 50-339

cc: See next page

DISTRIBUTION:

PUBLIC  
PDII-1 Rdg. (paper copy)  
ACRS  
SMonarque  
Accession No. ML013410504

NLe  
OGC  
EDunnington (paper copy)  
UShoop

TMarsh  
CSchulten

RLaufer  
KLandis

OFFICE	PM:PDII/S1	LA :PDII/S2	SC(A):PDII-1
NAME	SMonarque	EDunnington	RLaufer
DATE	11/28/01	11/27/01	11/28/01

OFFICIAL RECORD COPY

Mr. David A. Christian  
Virginia Electric and Power Company

North Anna Power Station  
Units 1 and 2

cc:

Mr. C. Lee Lintecum  
County Administrator  
Louisa County  
P.O. Box 160  
Louisa, Virginia 23093

Mr. David A. Heacock  
Site Vice President  
North Anna Power Station  
P.O. Box 402  
Mineral, Virginia 23117-0402

Mr. Donald P. Irwin, Esquire  
Hunton and Williams  
Riverfront Plaza, East Tower  
951 E. Byrd Street  
Richmond, Virginia 23219

Mr. Richard H. Blount, II  
Site Vice President  
Surry Power Station  
Virginia Electric and Power Company  
5570 Hog Island Road  
Surry, Virginia 23883-0315

Dr. W. T. Lough  
Virginia State Corporation  
Commission  
Division of Energy Regulation  
P.O. Box 1197  
Richmond, Virginia 23209

Robert B. Strobe, M.D., M.P.H.  
State Health Commissioner  
Office of the Commissioner  
Virginia Department of Health  
P. O. Box 2448  
Richmond, Virginia 23218

Old Dominion Electric Cooperative  
4201 Dominion Blvd.  
Glen Allen, Virginia 23060

Mr. William R. Matthews  
Vice President - Nuclear Operations  
Virginia Electric and Power Company  
Innsbrook Technical Center  
5000 Dominion Boulevard  
Glen Allen, Virginia 23060-6711

Mr. Stephen P. Sarver, Director  
Nuclear Licensing & Operations Support  
Virginia Electric and Power Company  
Innsbrook Technical Center  
5000 Dominion Blvd.  
Glen Allen, Virginia 23060-6711

Office of the Attorney General  
Commonwealth of Virginia  
900 East Main Street  
Richmond, Virginia 23219

Senior Resident Inspector  
North Anna Power Station  
U.S. Nuclear Regulatory Commission  
1024 Haley Drive  
Mineral, Virginia 23117