

September 14, 1990

Docket Nos. 50-250
and 50-251

*Posted
Collection to
Amdt. 132 to DPR-41*

Mr. J. H. Goldberg
Executive Vice President
Florida Power and Light Company
P.O. Box 14000
Juno Beach, Florida 33408-0420

Dear Mr. Goldberg:

SUBJECT: TURKEY POINT UNITS 3 AND 4 CORRECTIONS TO AMENDMENT
NOS. 137 AND 132

On August 28, 1990, the staff issued Amendment Nos. 137 and 132 for Turkey Point, Units 3 and 4, respectively. These amendments replaced the entire current custom Technical Specifications (TS) with a set of revised Technical Specifications which are based on the Standard Technical Specifications for Westinghouse-designed plants.

Through an administrative error, the wrong pages were included in Amendments 137 and 132 for pages 3/4 3-26 and 3/4 3-27. Enclosed are the corrected pages to be included in the Turkey Point TS.

Sincerely,

Original signed by

Gordon E. Edison, Sr. Project Manager
Project Directorate II-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Enclosures:
As stated

cc w/enclosures:
See next page

OFC	: LA:PD22	: PM:PD22	: D:PD22	:	:	:
NAME	: <i>[Signature]</i>	: GEdison: kdj	: HBenlow	:	:	:
DATE	: 9/14/90	: 9/14/90	: 9/14/90	:	:	:

OFFICIAL RECORD COPY
Document Name: TP 3/4 NO. 137/132

Mr. J. H. Goldberg
Florida Power and Light Company

Turkey Point Plant

cc:

Harold F. Reis, Esquire
Newman and Holtzinger, P.C.
1615 L Street, N.W.
Washington, DC 20036

Mr. Jack Shreve
Office of the Public Counsel
Room 4, Holland Building
Tallahassee, Florida 32304

John T. Butler, Esquire
Steel, Hector and Davis
4000 Southeast Financial
Center
Miami, Florida 33131-2398

Mr. K. N. Harris, Vice President
Turkey Point Nuclear Plant
Florida Power and Light Company
P.O. Box 029100
Miami, Florida 33102

County Manager of Metropolitan
Dade County
111 NW 1st Street, 29th Floor
Miami, Florida 33128

Senior Resident Inspector
Turkey Point Nuclear Generating Station
U.S. Nuclear Regulatory Commission
Post Office Box 57-1185
Miami, Florida 33257-1185

Mr. Jacob Daniel Nash
Office of Radiation Control
Department of Health and
Rehabilitative Services
1317 Winewood Blvd.
Tallahassee, Florida 32399-0700

Intergovernmental Coordination
and Review
Office of Planning & Budget
Executive Office of the Governor
The Capitol Building
Tallahassee, Florida 32301

Administrator
Department of Environmental
Regulation
Power Plant Siting Section
State of Florida
2600 Blair Stone Road
Tallahassee, Florida 32301

Regional Administrator, Region II
U.S. Nuclear Regulatory Commission
101 Marietta Street, N.W. Suite 2900
Atlanta, Georgia 30323

Attorney General
Department of Legal Affairs
The Capitol
Tallahassee, Florida 32304

Plant Manager
Turkey Point Nuclear Plant
Florida Power and Light Company
P.O. Box 029100
Miami, Florida 33102

DATED: September 14, 1990

CORRECTION TO:

AMENDMENT NO. 137 TO FACILITY OPERATING LICENSE NO. DPR-31-TURKEY POINT UNIT 3
AMENDMENT NO. 132 TO FACILITY OPERATING LICENSE NO. DPR-41-TURKEY POINT UNIT 4

Docket File

NRC & Local PDRs

PDII-2 Reading

S. Varga, 14/E/4

G. Lainas, 14/H/3

H. Berkow

D. Miller

G. Edison

OGC-WF

D. Hagan, 3302 MNBB

E. Jordan, 3302 MNBB

B. Grimes, 9/A/2

G. Hill (8), P-137

Wanda Jones, P-130A

J. Calvo, 11/F/23

E. Rossi, 11/E/4

OTSB

ACRS (10)

GPA/PA

OC/LFMB

A. Toalston 7/F/11

C. Moon 11/F/23

C. Hoxie 11/F/23

R. Butcher RII

R. Crljenjak RII

M. Sinkule, R-II

Others as required

cc: Plant Service list

TABLE 3.3-3 (Continued)

ENGINEERED SAFETY FEATURES ACTUATION SYSTEM
INSTRUMENTATION TRIP SETPOINTS

<u>FUNCTIONAL UNIT</u>	<u>TRIP SETPOINT</u>	<u>ALLOWABLE VALUE#</u>
6. Auxiliary Feedwater (Continued)		
d. Bus Stripping	See Item 7. below for all Bus Stripping Setpoints and Allowable Values.	
e. Trip of All Main Feedwater Pump Breakers.	N.A.	N.A.
7. Loss of Power		
a. 4.16 kV Busses A and B (Loss of Voltage)	N.A.	N.A.
b. 480V Load Centers (Instantaneous Relays) Degraded Voltage		
<u>Load Center</u>		
3A	418V±5V (10 sec ± 1 sec delay)	[]
3B	423V±5V (10 sec ± 1 sec delay)	[]
3C	429V±5V (10 sec ± 1 sec delay)	[]
3D	429V±5V (10 sec ± 1 sec delay)	[]
4A	407V±5V (10 sec ± 1 sec delay)	[]
4B	423V±5V (10 sec ± 1 sec delay)	[]
4C	419V±5V (10 sec ± 1 sec delay)	[]
4D	404V±5V (10 sec ± 1 sec delay)	[]
Coincident with: Safety Injection and	See Item 1. above for all Safety Injection Trip Setpoints and Allowable Values.	
Diesel Generator Breaker Open	N.A.	N.A.

TABLE 3.3-3 (Continued)

ENGINEERED SAFETY FEATURES ACTUATION SYSTEM
INSTRUMENTATION TRIP SETPOINTS

<u>FUNCTIONAL UNIT</u>	<u>TRIP SETPOINT</u>	<u>ALLOWABLE VALUE#</u>
7. Loss of Power (Continued)		
c. 480V Load Centers (Inverse Time Relays) Degraded Voltage		
<u>Load Center</u>		
3A	416V±5V(60 sec ±30 sec delay)	[]
3B	426V±5V(60 sec ±30 sec delay)	[]
3C	436V±5V(60 sec ±30 sec delay)	[]
3D	437V±5V(60 sec ±30 sec delay)	[]
4A	424V±5V(60 sec ±30 sec delay)	[]
4B	422V±5V(60 sec ±30 sec delay)	[]
4C	433V±5V(60 sec ±30 sec delay)	[]
4D	432V±5V(60 sec ±30 sec delay)	[]
Coincident with: Diesel Generator Breaker Open	N.A.	N.A.
8. Engineering Safety Features Actuation System Interlocks		
a. Pressurizer Pressure	≤2000 psig	≤[] psig
b. T_{avg} --Low	≥531°F	[]
9. Control Room Ventilation Isolation		
a. Automatic Actuation Logic and Actuation Relays	N.A.	N.A.
b. Safety Injection	See Item 1. above for all Safety Injection Trip Setpoints and Allowable Values.	