

MAR 28 1988

Docket Nos. 50-338
and 50-339

Mr. W. L. Stewart
Vice President- Nuclear Operations
Virginia Electric and Power Company
Post Office Box 26666
Richmond, Virginia 23261

Dear Mr. Stewart:

SUBJECT: NORTH ANNA UNITS 1 AND 2 - CORRECTION TO
AMENDMENT NOS. 87 and 73

On November 10, 1986, the Commission issued Amendment Nos. 87 and 73 to Facility Operating Licenses NPF-4 and NPF-7 respectively, for the North Anna Power Station, Units No. 1 and No. 2 (NA-1 & 2). The amendment revised Section 6 of the NA-1&2 Technical Specifications (TS).

Due to an administrative error, TS page 6-11 for NA-1 and TS page 6-12 for NA-2 did not incorporate a change previously approved by the staff. In Amendment Nos. 79 and 68, issued on May 19, 1986, the staff revised the audit of the process and control program and implementing procedures for processing and packaging of radioactive wastes from at least once per 24 months to at least once per 12 months. However, in Amendment Nos. 87 and 73, subsequently issued by the staff, the TS pages did not contain this change. Enclosed are the correct TS pages for NA-1&2; as well as the corresponding overleaf pages.

Please accept our apologies for any inconvenience this error may caused.

Sincerely,

Leon B. Engle, Project Manager
Project Directorate II-2
Division of Reactor Projects-I/II
Office of Nuclear Reactor Regulation

Enclosure:
As stated

cc: w/enclosure:
See next page

DISTRIBUTION

| | |
|------------------------|--------------|
| Docket File | JPartlow |
| NRC & Local PDRs | TBarnhart(8) |
| PD#22 Reading | Wanda Jones |
| SVarga | ACRS(10) |
| GLainas | GPA/PA |
| DMiller | ARM/LFMB |
| LEngle | EButcher |
| OGC-WF | Gray File |
| DHagan | |
| EJordan | |

*See Previous Concurrence

*LA:PD 22
DMiller
03/25/88

*PM:PD22
LEngle
03/25/88

D:PD 22
HBerkow
03/28/88

8803310259 880328
PDR ADOCK 05000338
P PDR

Mr. W. L. Stewart
Virginia Electric & Power Company

North Anna Power Station
Units 1 and 2

cc:

Mr. William C. Porter, Jr.
County Administrator
Louisa County
P.O. Box 160
Louisa, Virginia 23093

Michael W. Maupin, Esq.
Hunton and Williams
P. O. Box 1535
Richmond, Virginia 23212

Mr. W. T. Lough
Virginia Corporation Commission
Division of Energy Regulation
P. O. Box 1197
Richmond, Virginia 23209

Ellyn R. Weiss, Esq.
Harmon, Weiss and Jordan
2001 S Street NW
Washington, DC 20009

Mr. J. T. Rhodes
Senior Vice President - Power Ops.
Virginia Electric and Power Co.
Post Office Box 26666
Richmond, Virginia 23261

Mr. Patrick A. O'Hare
Office of the Attorney General
Supreme Court Building
101 North 8th Street
Richmond, Virginia 23219

Resident Inspector/North Anna
c/o U.S. NRC
Senior Resident Inspector
Route 2, Box 78
Mineral, Virginia 23117

Atomic Safety and Licensing Appeal
Board Panel
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Regional Administrator, Region II
U.S. Nuclear Regulatory Commission
Office of Executive Director
for Operations
101 Marietta Street N.W., Suite 2900
Atlanta, Georgia 30323

Mr. E. W. Harrell
P. O. Box 402
Mineral, Virginia 23117

Old Dominion Electric Cooperative
c/o Executive Vice President
Innsbrook Corporate Center
4222 Cox Road, Suite 102
Glen Allen, Virginia 23060

James B. Kenley, M.D., Commissioner
Department of Health
109 Governor Street
Richmond, Virginia 23219

ADMINISTRATIVE CONTROLS

- m. The PROCESS CONTROL PROGRAM and implementing procedures for processing and packaging of radioactive wastes at least once per 12 months.

AUTHORITY

6.5.3.2 The Quality Assurance Department shall report to and advise the Executive Manager - Quality Assurance, who shall advise the Senior Vice President - Engineering and Construction on those areas of responsibility specified in Section 6.5.3.1.

RECORDS

6.5.3.3 Records of the Quality Assurance Department audits shall be prepared and maintained in the department files. Audit reports shall be disseminated as indicated below:

1. Vice President-Nuclear Operations
2. Nuclear Power Station Manager
3. Manager-Nuclear Operations Support
4. Manager-Nuclear Programs and Licensing
5. Executive Manager-Quality Assurance
6. Director-Safety Evaluation and Control
7. Nuclear Power Station Manager Quality Assurance
8. Supervisor(s) of Area Audited

ADMINISTRATIVE CONTROLS

6.6 REPORTABLE EVENT ACTION

6.6.1 The following actions shall be taken for REPORTABLE EVENTS:

- a. The Commission shall be notified and a report submitted pursuant to the requirements of Section 50.73 to 10 CFR Part 50, and
- b. Each REPORTABLE EVENT shall be reviewed by the SNSOC and the results of this review shall be submitted to the Director-Safety Evaluation and Control and the Vice President-Nuclear Operations.

6.7 SAFETY LIMIT VIOLATION

6.7.1 The following actions shall be taken in the event a Safety Limit is violated:

- a. The facility shall be placed in at least HOT STANDBY within one hour.
- b. The NRC Operations Center shall be notified by telephone as soon as possible and in all cases within one hour. The Vice President-Nuclear Operations, and the Director-Safety Evaluation and Control shall be notified within 24 hours.
- c. A Safety Limit Violation Report shall be prepared. The report shall be reviewed by the SNSOC. This report shall describe (1) applicable circumstances preceding the violation, (2) effects of the violation upon facility components, systems or structures, and (3) corrective action taken to prevent recurrence.
- d. The Safety Limit Violation Report shall be submitted to the Commission, the Director-Safety Evaluation and Control and the Vice President-Nuclear Operations within 14 days of the violation.

6.8 PROCEDURES AND PROGRAMS

6.8.1 Written procedures shall be established, implemented and maintained covering the activities referenced below:

- a. The applicable procedures recommended in Appendix "A" of Regulatory Guide 1.33, Revision 2, February 1978.
- b. Refueling operations.

ADMINISTRATIVE CONTROLS

- k. The radiological environmental monitoring program and the results thereof at least once per 12 months.
- l. The OFFSITE DOSE CALCULATION MANUAL and implementing procedures at least once per 24 months.
- m. The PROCESS CONTROL PROGRAM and implementing procedures for processing and packaging of radioactive wastes at least once per 12 months.

AUTHORITY

6.5.3.2 The Quality Assurance Department shall report to and advise the Executive Manager-Quality Assurance, who shall advise the Senior Vice President-Engineering and Construction on those areas of responsibility specified in Section 6.5.3.1.

RECORDS

6.5.3.3 Records of the Quality Assurance Department audits shall be prepared and maintained in the department files. Audit reports shall be disseminated as indicated below:

- 1. Vice President-Nuclear Operations
- 2. Nuclear Power Station Manager
- 3. Manager-Nuclear Operations Support
- 4. Manager-Nuclear Programs & Licensing
- 5. Executive Manager-Quality Assurance
- 6. Director-Safety Evaluation and Control
- 7. Nuclear Power Station Manager-Quality Assurance
- 8. Supervisor(s) of Area Audited

ADMINISTRATIVE CONTROLS

RECORDS (Cont'd)

4. Manager-Nuclear Programs and Licensing
5. Executive Manager-Quality Assurance
6. Others that the Director-Safety Evaluation and Control may designate.

6.5.3 QUALITY ASSURANCE DEPARTMENT

FUNCTION

6.5.3.1 The Quality Assurance Department shall function to audit station activities. These audits shall encompass:

- a. The conformance of facility operation to provisions contained within the Technical Specifications and applicable license conditions at least once per 12 months.
- b. The performance, training and qualifications of the entire facility staff at least once per 12 months.
- c. The results of actions taken to correct deficiencies occurring in facility equipment, structures, systems or method of operation that affect nuclear safety at least once per 6 months.
- d. The performance of activities required by the Operational Quality Assurance Program to meet the criteria of Appendix "B", 10 CFR 50, at least once per 24 months.
- e. The Station Emergency Plan and implementing procedures at least once per 12 months.
- f. The Station Security Plan and implementing procedures at least once per 12 months.
- g. Any other area of facility operation considered appropriate by the Executive Manager-Quality Assurance or the Senior Vice President-Power Operations.
- h. The Station Fire Protection Program and implementing procedures at least once per 24 months.
- i. An independent fire protection and loss prevention program inspection and audit shall be performed at least once per 12 months utilizing either qualified offsite licensee personnel or an outside fire protection firm.
- j. An inspection and audit of the fire protection and loss prevention program shall be performed by a qualified outside fire consultant at least once per 36 months.