

July 18, 1989

Docket Nos. 50-338
and 50-339

DISTRIBUTION
See attached sheet

Mr. W. R. Cartwright
Vice President - Nuclear
Virginia Electric and Power Company
5000 Dominion Blvd.
Glen Allen, Virginia 23060

Dear Mr. Cartwright:

SUBJECT: NORTH ANNA UNITS 1 AND 2 - ISSUANCE OF AMENDMENTS RE: DIRECT REACTOR
TRIP ON TURBINE TRIP BLOCKED BELOW 30% OF RATED THERMAL POWER
(TAC NOS. 69800 AND 69801)

The Commission has issued the enclosed Amendment Nos. 119 and 103 to Facility
Operating License Nos. NPF-4 and NPF-7 for the North Anna Power Station,
Units No. 1 and No. 2 (NA-1&2). The amendments revise the Technical Speci-
fications (TS) in response to your letter dated September 30, 1988.

The amendments allow direct reactor trip on turbine trip to be blocked below
30% of rated thermal power. Implementation of the amendments shall take place
no later than the end of the next refueling outages for NA-1&2.

A copy of the Safety Evaluation is also enclosed. The Notice of Issuance will
be included in the Commission's biweekly Federal Register notice.

Sincerely,

Original signed by

Leon B. Engle, Project Manager
Project Directorate II-2
Division of Reactor Projects-I/II
Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No. 119 to NPF-4
2. Amendment No. 103 to NPF-7
3. Safety Evaluation

cc w/enclosures:
See next page

8907280306 890718
PDR ADOCK 05000338
PDC

[NA-1&2 AMEND 69800/69801]

LA: PD II-2
DMP/mer
07/14/89

PM: PD II-2
LEK/8-bd
07/14/89

D: PD II-2
HBer kow
07/14/89

OGC
R. Bachmann
07/14/89

CP
DFO
1/1

DATED: July 18, 1989

AMENDMENT NO. 119 TO FACILITY OPERATING LICENSE NO. NPF-4-NORTH ANNA UNIT 1
AMENDMENT NO. 103 TO FACILITY OPERATING LICENSE NO. NPF-7-NORTH ANNA UNIT 2

Docket File

NRC & Local PDRs

PDII-2 Reading

S. Varga, 14/E/4

G. Lainas, 14/H/3

H. Berkow

D. Miller

L. Engle

OGC-WF

D. Hagan, 3302 MNBB

E. Jordan, 3302 MNBB

B. Grimes, 9/A/2

T. Meek (8), P1-137

Wanda Jones, P-130A

J. Calvo, 11/F/23

ACRS (10)

GPA/PA

OC/LFMB

B. Sinkule, R-II

M. Chatterton

OFoI
1/1

cc: Plant Service list

Mr. W. R. Cartwright
Virginia Electric & Power Company

North Anna Power Station
Units 1 and 2

CC:

Mr. William C. Porter, Jr.
County Administrator
Louisa County
P.O. Box 160
Louisa, Virginia 23093

C. M. G. Buttery, M.D., M.P.H.
Department of Health
109 Governor Street
Richmond, Virginia 23219

Michael W. Maupin, Esq.
Hunton and Williams
P. O. Box 1535
Richmond, Virginia 23212

Regional Administrator, Region II
U.S. Nuclear Regulatory Commission
101 Marietta Street N.W., Suite 2900
Atlanta, Georgia 30323

Mr. W. T. Lough
Virginia Corporation Commission
Division of Energy Regulation
P. O. Box 1197
Richmond, Virginia 23209

Mr. G. E. Kane
P. O. Box 402
Mineral, Virginia 23117

Old Dominion Electric Cooperative
c/o Executive Vice President
Innsbrook Corporate Center
4222 Cox Road, Suite 102
Glen Allen, Virginia 23060

Mr. W. L. Stewart
Senior Vice President - Power
Virginia Electric and Power Co.
Post Office Box 26666
Richmond, Virginia 23261

Mr. Patrick A. O'Hare
Office of the Attorney General
Supreme Court Building
101 North 8th Street
Richmond, Virginia 23219

Resident Inspector/North Anna
c/o U.S. NRC
Senior Resident Inspector
Route 2, Box 78
Mineral, Virginia 23117



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

VIRGINIA ELECTRIC AND POWER COMPANY

OLD DOMINION ELECTRIC COOPERATIVE

DOCKET NO. 50-338

NORTH ANNA POWER STATION, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 119
License No. NPF-4

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Virginia Electric and Power Company et al., (the licensee) dated September 30, 1988, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.D.(2) of Facility Operating License No. NPF-4 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 119, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance and shall be implemented no later than the end of the next refueling outage.

FOR THE NUCLEAR REGULATORY COMMISSION



Herbert N. Berkow, Director
Project Directorate II-2
Division of Reactor Projects-I/II
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: July 18, 1989

ATTACHMENT TO LICENSE AMENDMENT NO. 119

TO FACILITY OPERATING LICENSE NO. NPF-4

DOCKET NO. 50-338

Replace the following pages of the Appendix "A" Technical Specifications with the enclosed pages as indicated. The revised pages are identified by amendment number and contain vertical lines indicating the area of change. The corresponding overleaf pages are also provided to maintain document completeness.

Page

B2-7

3/4 3-8

3/4 3-9

LIMITING SAFETY SYSTEM SETTINGS

BASES

of the Reactor Protection System. This trip is redundant to the Steam Generator Water Level Low-Low trip. The Steam/Feedwater Flow Mismatch portion of this trip is activated when the steam flow exceeds the feedwater flow by $\geq 1.616 \times 10^6$ lbs/hour of full steam flow at RATED THERMAL POWER. The Steam Generator Low Water level portion of the trip is activated when the water level drops below 25 percent, as indicated by the narrow range instrument. These trip values include sufficient allowance in excess of normal operating values to preclude spurious trips but will initiate a reactor trip before the steam generators are dry. Therefore, the required capacity and starting time requirements of the auxiliary feedwater pumps are reduced and the resulting thermal transient on the Reactor Coolant System and steam generators is minimized.

Undervoltage and Underfrequency - Reactor Coolant Pump Busses

The reactor trip due to the Undervoltage and Underfrequency on the Reactor Coolant Pump busses provide reactor core protection against DNB as a result of loss of voltage or underfrequency to more than one reactor coolant pump. The specified set points assure a reactor trip signal is generated before the low flow trip set point is reached. Time delays are incorporated in the underfrequency and undervoltage trips to prevent spurious reactor trips from momentary electrical power transients. For undervoltage, the delay is set so that the time required for a signal to reach the reactor trip breakers following the simultaneous trip of two or more reactor coolant pump bus circuit breakers shall not exceed 0.5 seconds. For underfrequency, the delay is set so that the time required for a signal to reach the reactor trip breakers after the underfrequency trip set point is reached shall not exceed 0.1 seconds. The undervoltage and underfrequency trips are automatically blocked when reactor power is below the P-7 setpoint.

Turbine Trip

A Turbine Trip causes a direct reactor trip when operating above P-8. Each of the turbine trips provide turbine protection and reduce the severity of the ensuing transient. No credit was taken in the accident analyses for operation of these trips. Their functional capability at the specified trip settings is required to enhance the overall reliability of the Reactor Protection System.

LIMITING SAFETY SYSTEM SETTINGS

BASES

Safety Injection Input from ESF

If a reactor trip has not already been generated by the reactor protective instrumentation, the ESF automatic actuation logic channels will initiate a reactor trip upon any signal which initiates a safety injection. This trip is provided to protect the core in the event of a LOCA. The ESF instrumentation channels which initiate a safety injection signal are shown in Table 3.3-3.

Reactor Coolant Pump Breaker Position Trip

The Reactor Coolant Pump Breaker Position Trips are anticipatory trips which provide reactor core protection against DNB resulting from the opening of any one pump breaker above P-8 or the opening of two or more pump breakers below P-8. These trips are blocked below P-7. The open/close position trips assure a reactor trip signal is generated before the low flow trip set point is reached. No credit was taken in the accident analyses for operation of these trips. Their functional capability at the open/close position settings is required to enhance the overall reliability of the Reactor Protection System.

TABLE 3.3-1 (Continued)

- ACTION 9 - With a channel associated with an operating loop inoperable, restore the inoperable channel to OPERABLE status within 2 hours or be in HOT STANDBY within the next 6 hours; however, one channel associated with an operating loop may be bypassed for up to 2 hours for surveillance testing per Specification 4.3.1.1.1.
- ACTION 10 - With one channel inoperable, restore the inoperable channel to OPERABLE status within 2 hours or reduce THERMAL POWER to below P-8 within the next 2 hours. Operation below P-8 may continue pursuant to ACTION 11.
- ACTION 11 - With less than the Minimum Number of Channels OPERABLE, operation may continue provided the inoperable channel is placed in the tripped condition within 1 hour.
- ACTION 12 - With the number of channels OPERABLE one less than required by the Minimum Channels OPERABLE requirement, restore the inoperable channel to OPERABLE status within 48 hours or be in HOT STANDBY within the next 6 hours and/or open the reactor trip breakers.
- ACTION 13 - With the number of channels OPERABLE one less than required by the Minimum Channels OPERABLE requirement, restore the inoperable channel to OPERABLE status within (1) hour or terminate testing of the Reactor Trip Breaker and open the Reactor Trip Bypass Breaker.
- ACTION 14 - With one of the diverse trip features (undervoltage or shunt trip device) inoperable, restore it to OPERABLE status within 48 hours or declare the breaker inoperable and apply Action 1. The breaker shall not be bypassed while one of the diverse trip features is inoperable except for the time required for performing maintenance to restore the breaker to OPERABLE status.
- ACTION 15 - With the number of channels OPERABLE one less than required by the Minimum Channels OPERABLE requirement restore the inoperable channel to OPERABLE status within 48 hours or open the reactor trip breakers within the next hour.

TABLE 3.3-1 (Continued)
REACTOR TRIP SYSTEM INTERLOCKS

<u>DESIGNATION</u>	<u>CONDITION</u>	<u>SETPOINT</u>	<u>ALLOWABLE VALUES</u>	<u>FUNCTION</u>
P-6	1 of 2 Intermediate range above setpoint (increasing power level)	1×10^{-10}	$< 3 \times 10^{-10}$	Allows manual block of source range reactor trip
	2 of 2 Intermediate range below setpoint (decreasing power level)	5×10^{-11}	$> 3 \times 10^{-11}$	Defeats the block of source range reactor trip
P-10	2 of 4 Power range above setpoint (increasing power level)	10%	<11%	Allows manual block of power range (low setpoint) and intermediate range reactor trips and intermediate range rod stop. Blocks source range reactor trip.
	3 of 4 Power range below setpoint (decreasing power level)	8%	>7%	Defeats the block of power range (low setpoint) and intermediate range reactor trips and intermediate range rod stop.
P-7	2 of 4 Power range above setpoint	10%	<11%	Input to P-7. Allows reactor trip when any of the following occur in more than one loop: low flow, reactor coolant pump breaker open, undervoltage (RCP busses) or underfrequency (RCP busses). Also allows reactor trip on: pressurizer low pressure or pressurizer high level.
	or 1 of 2 Turbine Impulse chamber pressure above setpoint	Pressure equivalent to 10% rated turbine power	<11%	
	(Power level increasing)			

TABLE 3.3-1 (Continued)
REACTOR TRIP SYSTEM INTERLOCKS

<u>DESIGNATION</u>	<u>CONDITION</u>	<u>SETPOINT</u>	<u>ALLOWABLE VALUES</u>	<u>FUNCTION</u>
P-7 (Cont'd)	3 of 4 Power range below setpoint	8%	>7%	Prevents reactor trip when any of the following occur: low flow, reactor coolant pump breakers open, under-voltage (RCP busses), under-frequency (RCP busses), pressurizer low pressure or pressurizer high level.
	and 2 of 2 Turbine Impulse chamber pressure below setpoint (Power level decreasing)	8%	>7%	
P-8	2 of 4 Power range above setpoint	30%	<31%	Allows reactor trip when any of the following occur: low flow in a single loop, a single reactor coolant pump breaker open, or a turbine trip.
	(Power level increasing)			
	3 of 4 Power range below setpoint	28%	>27%	Prevents reactor trip when any of the following occur: low flow in a single loop, a single reactor coolant pump breaker open, or a turbine trip.
	(Power level decreasing)			

TABLE 3.3-2

REACTOR TRIP SYSTEM INSTRUMENTATION RESPONSE TIMES

<u>FUNCTIONAL UNIT</u>	<u>RESPONSE TIME</u>
1. Manual Reactor Trip	NOT APPLICABLE
2. Power Range, Neutron Flux	≤ 0.5 seconds*
3. Power Range, Neutron Flux, High Positive Rate	NOT APPLICABLE
4. Power Range, Neutron Flux, High Negative Rate	≤ 0.5 seconds*
5. Intermediate Range, Neutron Flux	NOT APPLICABLE
6. Source Range, Neutron Flux	≤ 0.5 seconds*
7. Overtemperature ΔT	≤ 4.0 seconds*
8. Overpower ΔT	NOT APPLICABLE
9. Pressurizer Pressure--Low	≤ 2.0 seconds
10. Pressurizer Pressure--High	≤ 2.0 seconds
11. Pressurizer Water Level--High	≤ 2.0 seconds

* Neutron detectors are exempt from response time testing. Response of the neutron flux signal portion of the channel time shall be measured from detector output or input of first electronic component in channel.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

VIRGINIA ELECTRIC AND POWER COMPANY

OLD DOMINION ELECTRIC COOPERATIVE

DOCKET NO. 50-339

NORTH ANNA POWER STATION, UNIT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 103
License No. NPF-7

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Virginia Electric and Power Company, et al., (the licensee) dated September 30, 1988, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. NPF-7 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No.103 , are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance and shall be implemented no later than the end of the next refueling outage.

FOR THE NUCLEAR REGULATORY COMMISSION


Herbert N. Berkow, Director
Project Directorate II-2
Division of Reactor Projects-I/II
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: July 18, 1989

ATTACHMENT TO LICENSE AMENDMENT NO. 103

TO FACILITY OPERATING LICENSE NO. NPF-7

DOCKET NO. 50-339

Replace the following pages of the Appendix "A" Technical Specifications with the enclosed pages as indicated. The revised pages are identified by amendment number and contain vertical lines indicating the area of change. The corresponding overleaf pages are also provided to maintain document completeness.

Page

B2-7

3/4 3-8

3/4 3-9

LIMITING SAFETY SYSTEM SETTINGS

BASES

Undervoltage and Underfrequency - Reactor Coolant Pump Busses

The reactor trip due to the Undervoltage and Underfrequency on the Reactor Coolant Pump Busses provide reactor core protection against DNB as a result of loss of voltage or underfrequency to more than one reactor coolant pump. The specified set points assure a reactor trip signal is generated before the low flow trip set point is reached. Time delays are incorporated in the underfrequency and undervoltage trips to prevent spurious reactor trips from momentary electrical power transients. For undervoltage, the delay is set so that the time required for a signal to reach the reactor trip breakers following the simultaneous trip of two or more reactor coolant pump bus circuit breakers shall not exceed 0.5 seconds. For underfrequency, the delay is set so that the time required for a signal to reach the reactor trip breakers after the underfrequency trip set point is reached shall not exceed 0.1 seconds." The undervoltage and underfrequency trips are automatically blocked when reactor power is below the P-7 setpoint.

Turbine Trip

A Turbine Trip causes a direct reactor trip when operating above P-8. Each of the turbine trips provide turbine protection and reduce the severity of the ensuing transient. No credit was taken in the accident analyses for operation of these trips. Their functional capability at the specified trip settings is required to enhance the overall reliability of the Reactor Protection System.

Safety Injection Input from ESF

If a reactor trip has not already been generated by the reactor protective instrumentation, the ESF automatic actuation logic channels will initiate a reactor trip upon any signal which initiates a safety injection. This trip is provided to protect the core in the event of a LOCA. The ESF instrumentation channels which initiate a safety injection signal are shown in Table 3.3-3.

Reactor Coolant Pump Breaker Position Trip

The Reactor Coolant Pump Breaker Position Trips are anticipatory trips which provide reactor core protection against DNB resulting from the opening of any one pump breaker above P-8 or the opening of two or more pump breakers below P-8. These trips are blocked below P-7. The open/close position trips assure a reactor trip signal is generated before the low flow trip set point

LIMITING SAFETY SYSTEM SETTINGS

BASES

is reached. No credit was taken in the accident analyses for operation of these trips. Their functional capability at the open/close position settings is required to enhance the overall reliability of the Reactor Protection System.

TABLE 3.3-1 (Continued)

- ACTION 9 - With a channel associated with an operating loop inoperable, restore the inoperable channel to OPERABLE status within 2 hours or be in HOT STANDBY within the next 6 hours; however, one channel associated with an operating loop may be bypassed for up to 2 hours for surveillance testing per Specification 4.3.1.1.1.
- ACTION 10 - With one channel inoperable, restore the inoperable channel to OPERABLE status within 2 hours or reduce THERMAL POWER to below the P-8, (Block of Low Reactor Coolant Pump Flow and Reactor Coolant Pump Breaker Position) setpoint, within the next 2 hours. Operation below the P-8, (Block of Low Reactor Coolant Pump Flow and Reactor Coolant Pump Breaker Position) setpoint, may continue pursuant to ACTION 11.
- ACTION 11 - With less than the Minimum Number of Channels OPERABLE, operation may continue provided the inoperable channel is placed in the tripped condition within 1 hour.
- ACTION 12 - With the number of channels OPERABLE one less than required by the Minimum Channels OPERABLE requirement, restore the inoperable channel to OPERABLE status within 48 hours or be in HOT STANDBY within the next 6 hours and/or open the reactor trip breakers.
- ACTION 13 - With the number of channels OPERABLE one less than required by the Minimum Channels OPERABLE requirement, restore the inoperable channel to OPERABLE status within (1) hour or terminate testing of the Reactor Trip Breaker and open the Reactor Trip Bypass Breaker.
- ACTION 14 - With one of the diverse trip features (undervoltage or shunt trip device) inoperable, restore it to OPERABLE status within 48 hours or declare the breaker inoperable and apply Action 1. The breaker shall not be bypassed while one of the diverse trip features is inoperable except for the time required for performing maintenance to restore the breaker to OPERABLE status.
- ACTION 15 - With the number of channels OPERABLE one less than required by the Minimum Channels OPERABLE requirement restore the inoperable channel to OPERABLE status within 48 hours or open the reactor trip breakers within the next hour.

TABLE 3.3-1 (Continued)
REACTOR TRIP SYSTEM INTERLOCKS

<u>DESIGNATION</u>	<u>CONDITION</u>	<u>SETPOINT</u>	<u>ALLOWABLE VALUES</u>	<u>FUNCTION</u>
P-6	1 of 2 Intermediate range above setpoint (increasing power level)	1×10^{-10}	$< 3 \times 10^{-10}$	Allows manual block of source range reactor trip
	2 of 2 Intermediate range below setpoint (decreasing power level)	5×10^{-11}	$> 3 \times 10^{-11}$	Defeats the block of source range reactor trip
P-10	2 of 4 Power range above setpoint (increasing power level)	10%	<11%	Allows manual block of power range (low setpoint) and intermediate range reactor trips and intermediate range rod stop. Blocks source range reactor trip.
	3 of 4 Power range below setpoint (decreasing power level)	8%	>7%	Defeats the block of power range (low setpoint) and intermediate range reactor trips and intermediate range rod stop.
P-7	2 of 4 Power range above setpoint	10%	<11%	Input to P-7. Allows reactor trip when any of the following occur in more than one loop: low flow, reactor coolant pump breaker open, undervoltage (RCP busses) or underfrequency (RCP busses). Also allows reactor trip on: pressurizer low pressure or pressurizer high level.
	or 1 of 2 Turbine Impulse chamber pressure above setpoint	Pressure equivalent to 10% rated turbine power	<11%	
	(Power level increasing)			

TABLE 3.3-1 (Continued)
REACTOR TRIP SYSTEM INTERLOCKS

<u>DESIGNATION</u>	<u>CONDITION</u>	<u>SETPOINT</u>	<u>ALLOWABLE VALUES</u>	<u>FUNCTION</u>
P-7 (Cont'd)	3 of 4 Power range below setpoint	8%	>7%	Prevents reactor trip when any of the following occur: low flow, reactor coolant pump breakers open, undervoltage (RCP busses), underfrequency (RCP busses), pressurizer low pressure or pressurizer high level.
	and 2 of 2 Turbine Impulse chamber pressure below setpoint (Power level decreasing)	8%	>7%	
P-8	2 of 4 Power range above setpoint (Power level increasing)	30%	<31%	Allows reactor trip when any of the following occur: low flow in a single loop, a single reactor coolant pump breaker open, or a turbine trip.
	3 of 4 Power range below setpoint (Power level decreasing)	28%	>27%	

TABLE 3.3-2

REACTOR TRIP SYSTEM INSTRUMENTATION RESPONSE TIMES

<u>FUNCTIONAL UNIT</u>	<u>RESPONSE TIME</u>
1. Manual Reactor Trip	NOT APPLICABLE
2. Power Range, Neutron Flux	≤ 0.5 seconds*
3. Power Range, Neutron Flux, High Positive Rate	NOT APPLICABLE
4. Power Range, Neutron Flux, High Negative Rate	≤ 0.5 seconds*
5. Intermediate Range, Neutron Flux	NOT APPLICABLE
6. Source Range, Neutron Flux	≤ 0.5 seconds*
7. Overtemperature ΔT	≤ 4.0 seconds*
8. Overpower ΔT	NOT APPLICABLE
9. Pressurizer Pressure--Low	≤ 2.0 seconds
10. Pressurizer Pressure--High	≤ 2.0 seconds
11. Pressurizer Water Level--High	≤ 2.0 seconds

* Neutron detectors are exempt from response time testing. Response of the neutron flux signal portion of the channel time shall be measured from detector output or input of first electronic component in channel.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION

RELATED TO AMENDMENT NOS. 119 AND 103 TO

FACILITY OPERATING LICENSE NOS. NPF-4 AND NPF-7

VIRGINIA ELECTRIC AND POWER COMPANY

OLD DOMINION ELECTRIC COOPERATIVE

NORTH ANNA POWER STATION, UNITS NO. 1 AND NO. 2

DOCKET NOS. 50-338 AND 50-339

1.0 INTRODUCTION

By letter dated September 30, 1988, Virginia Electric and Power Company (the licensee) requested changes to the Technical Specifications (TS) for the North Anna Power Station, Units No. 1 and 2 (NA-1&2). The changes would allow the direct reactor trip on turbine trip to be blocked below 30% of the rated thermal power (RTP). The present TS allows the direct reactor trip on turbine trip to be blocked below 10% of the rated thermal power. A review of historic data has shown that there have been a large number of direct reactor trips caused by turbine trips below the 30% power level. These reactor trips stress plant systems and increase down time. The design load rejection capability for these plants is 50%. The licensee has proposed changing the TS to allow direct reactor trip to be blocked on turbine trip below 30% power.

2.0 DISCUSSION

For power levels above 10% of RTP, the NA-1&2 reactors are tripped directly on turbine trip from a signal derived from the turbine autostop oil pressure or turbine stop valve position. To evaluate the impact of blocking the direct reactor trip on turbine trip for power levels below 30%, the licensee addressed the loss of external load accident, the loss of flow event during a loss of load and whether the turbine trip without reactor trip will challenge the pressurizer Power Operated Relief Valves (PORVs).

The loss of load/turbine trip event was analyzed at 100% power where it is limiting. The previous analysis showed acceptable results for a complete load rejection from 100% power without taking credit for the direct reactor trip on turbine trip. Even though this analysis bounds the 30% case, the licensee performed an explicit analysis at 30% power. Cases were analyzed for beginning of cycle (BOC) and end of cycle (EOC) with minimum feedback with and without pressurizer control. In all cases, the minimum Departure from Nucleate Boiling Ratio (DNBR) is above the design limit value and the peak pressure remains well within the design limit.

The licensee analyzed the transient response for a total loss of load with subsequent loss of flow from 30% power. Four cases, two at BOC and two at EOC, were analyzed. The minimum DNBR remains well above the limit and is bounded by the loss of load analysis in the Updated Final Safety Analysis Report (UFSAR).

The licensee's response to NUREG-0737 post-TMI requirements committed to a program of reducing the probability of a small-break LOCA due to a stuck open PORV such that it is not a significant contributor to the probability of a small-break LOCA due to all causes. Therefore, the licensee performed an analysis to demonstrate on a best estimate basis that a turbine trip without direct reactor trip at reduced power will not challenge the PORVs. The results of this analysis showed that the pressurizer PORVs are not challenged during this transient. Thus, the proposed changes will not have a significant impact on the frequency of a small-break LOCA caused by a stuck-open PORV.

3.0 EVALUATION

Based on our review of the licensee's September 30, 1988 submittal, we conclude that the requested TS changes are acceptable. The changes would increase the direct reactor trip on turbine trip to be blocked from the present value of 10% power to 30% power. As discussed above, the staff finds the proposed changes meet the applicable NRC requirements and are therefore acceptable.

The proposed changes will require the rewiring of the NA-1&2 Solid State Protection System so that the Permissive P-8 bistable can be used to block reactor trip on turbine trip below 30% power. This requires that NA-1&2 be in cold shutdown (Mode 5) in order to implement the above changes. Therefore, implementation of the above changes shall take place no later than the end of the next refueling outages for NA-1&2.

4.0 ENVIRONMENTAL CONSIDERATION

These amendments involve a change in the installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20. The staff has determined that the amendments involve no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously published a proposed finding that the amendments involve no significant hazards consideration and there has been no public comment on such finding. Accordingly, the amendments meet the eligibility criteria for categorical exclusion set forth in 10 CFR §51.22(c)(9). Pursuant to 10 CFR §51.22(b), no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendments.

5.0 CONCLUSION

We have concluded, based on the considerations discussed above, that (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and (2) such activities will be conducted in compliance with the Commission's regulations, and the issuance of the amendments will not be inimical to the common defense and security or to the health and safety of the public.

Date: July 18, 1989

Principal Contributor:

M. Chatterton