Docket Nos. 50-338 and 50-339

> Mr. W. L. Stewart Senior Vice President - Nuclear Virginia Electric and Power Company 5000 Dominion Blvd. Glen Allen, Virginia 23060

Dear Mr. Stewart:

SUBJECT: NORTH ANNA UNITS 1 AND 2 - CORRECTION TO AMENDMENT NOS. 146 AND 130 (TAC NOS. 77066 AND 77067)

On June 7, 1991, we issued Amendment Nos. 146 and 130 for the North Anna Power Station, Units 1 and 2 (NA-1&2). The amendments modified the Technical Specifications (TS) by referencing the cycle-specific parameter limits in a Core Operating Limits Report (COLR). In addition, we denied your request to include boron concentration in the COLR, since we are currently sponsoring a research effort to determine if the floor value of the boron concentration should be retained or eliminated.

You have subsequently informed us of errors on TS page 6-17 for both NA-1&2. Some of your requested changes regarding boron concentration were not removed prior to issuance of the amendments. Enclosed are the correct pages 6-17 for both NA-1&2.

Sincerely,

(Original Signed By)

Leon B. Engle, Project Manager Project Directorate II-2 Division of Reactor Projects - I/II Office of Nuclear Reactor Regulation

Enclosure: As stated

cc w/enclosures: See next page

OFC	: LA:PD22	PM:PD22	: D:PD22		:	
NAME	an Ner	LENgle	HERE HERE HERE	:		
DATE	6 125/91	6 /25/91	: 6 /25/91	•		
	OFFICIAL RECORD Document Name:	COPY North Anna Cori		Capital Commence		Oral
910 PDR P	7010117 910625 ADOCK 0500033 PDF	88	ing the		COPY	UTI

CORE OPERATING LIMITS REPORT

- 6.9.1.7.a Core operating limits shall be established and documented in the CORE OPERATING LIMITS REPORT before each reload cycle or any remaining part of a reload cycle for the following:
 - 1. Moderator Temperature Coefficient BOC and EOC limits, and 300 ppm and 60 ppm surveillance limits for Specification 3/4.1.1.4,
 - 2. Shutdown Bank Insertion Limit for Specification 3/4.1.3.5,
 - 3. Control Bank Insertion Limits for Specification 3/4.1.3.6,
 - 4. Axial Flux Difference limits for Specification 3/4.2.1,
 - 5. Heat Flux Hot Channel Factor, K(Z), N(Z) for Specification 3/4.2.2, and
 - 6. Nuclear Enthalpy Rise Hot Channel Factor, and Power Factor Multiplier, for Specification 3/4.2.3.
- 6.9.1.7.b The analytical methods used to determine the core operating limits shall be those previously reviewed and approved by the NRC as identified in 6.9.1.7.e.
- 6.9.1.7.c The core operating limits shall be determined so that all applicable limits (e.g., fuel thermal-mechanical limits, core thermal-hydraulic limits, ECCS limits, nuclear limits such as shutdown margin, and transient and accident analysis limits) of the safety analysis are met.
- 6.9.1.7.d The CORE OPERATING LIMITS REPORT, including any mid-cycle revisions or supplements thereto, shall be provided upon issuance, for each reload cycle, to the NRC Document Control Desk with copies to the Regional Administrator and Resident Inspector.

6.9.1.7.e <u>REFERENCES</u>

1. VEP-FRD-42, Rev. 1-A, "Reload Nuclear Design Methodology," September 1986.

(Methodology for LCO 3.1.1.4 - Moderator Temperature Coefficient, LCO 3.1.3.5 - Shutdown Bank Insertion Limit, LCO 3.1.3.6 - Control Bank Insertion Limits, LCO 3.2.2 - Heat Flux Hot Channel Factor, LCO 3.2.3 - Nuclear Enthalpy Rise Hot Channel Factor).

9107010122 910625

ADOCK

PDR

000338

PDR

ÿ

CORE OPERATING LIMITS REPORT

- 6.9.1.7.a Core operating limits shall be established and documented in the CORE OPERATING LIMITS REPORT before each reload cycle or any remaining part of a reload cycle for the following:
 - 1. Moderator Temperature Coefficient BOC and EOC limits, and 300 ppm and 60 ppm surveillance limits for Specification 3/4.1.1.4,
 - 2. Shutdown Bank Insertion Limit for Specification 3/4.1.3.5,
 - 3. Control Bank Insertion Limits for Specification 3/4.1.3.6,
 - 4. Axial Flux Difference limits for Specification 3/4.2.1,
 - 5. Heat Flux Hot Channel Factor, K(Z), N(Z) for Specification 3/4.2.2, and
 - 6. Nuclear Enthalpy Rise Hot Channel Factor, and Power Factor Multiplier, for Specification 3/4.2.3.
- 6.9.1.7.b The analytical methods used to determine the core operating limits shall be those previously reviewed and approved by the NRC as identified in 6.9.1.7.e.
- 6.9.1.7.c The core operating limits shall be determined so that all applicable limits (e.g., fuel thermal-mechanical limits, core thermal-hydraulic limits, ECCS limits, nuclear limits such as shutdown margin, and transient and accident analysis limits) of the safety analysis are met.
- 6.9.1.7.d The CORE OPERATING LIMITS REPORT, including any mid-cycle revisions or supplements thereto, shall be provided upon issuance, for each reload cycle, to the NRC Document Control Desk with copies to the Regional Administrator and Resident Inspector.

6.9.1.7.e <u>REFERENCES</u>

1. VEP-FRD-42, Rev. 1-A, "Reload Nuclear Design Methodology," September 1986.

(Methodology for LCO 3.1.1.4 - Moderator Temperature Coefficient, LCO 3.1.3.5 - Shutdown Bank Insertion Limit, LCO 3.1.3.6 - Control Bank Insertion Limits, LCO 3.2.2 - Heat Flux Hot Channel Factor, LCO 3.2.3 - Nuclear Enthalpy Rise Hot Channel Factor).

NORTH ANNA - UNIT 2

6-17 Amendment No. 47, 130,

DATED: June 25, 1991

•. •

CORRECTION TO: AMENDMENT NO. 146 TO FACILITY OPERATING LICENSE NO. NPF-4-NORTH ANNA UNIT 1 AMENDMENT NO. 130 TO FACILITY OPERATING LICENSE NO. NPF-7-NORTH ANNA UNIT 2 Docket File NRC & Local PDRs PDII-2 Reading S. Varga, 14/Ĕ/4 G. Lainas, 14/H/3 H. Berkow D. Miller L. Engle OGC-WF D. Hagan, 3302 MNBB E. Jordan, 3302 MNBB B. Grimes, 9/A/2 G. Hill (8), P-137 Wanda Jones, P-130A C. Grimes, 11/F/23 T. Huang, 8-E-23 ACRS (10) GPA/PA OC/LFMB M. Sinkule, R-II cc: Plant Service list