April 30, 195-

Docket Nos. 50-338 and 50-339

DISTRIBUTION:

NRC & Local PDRs Docket File P122 PDII-2 RDG File SVarga HBerkow GLainas DMiller LEngle DHagan OGC WJones GHill (4) ACRS(10) CGrimes OC/LFMB OPA MSinkule.RII

5000 Dominion Blvd. Glen Allen, Virginia 23060

Senior Vice President - Nuclear

Virginia Electric and Power Company

Dear Mr. Stewart:

Mr. W. L. Stewart

SUBJECT: NORTH ANNA UNITS 1 AND 2 - CORRECTION TO AMENDMENT NOS. 156 AND 138 (TAC NOS. M81862 AND M81863)

On April 21, 1992, we issued Amendment Nos. 156 and 138 for the North Anna Power Station, Units 1 and 2 (NA-1&2). The amendments clarified the emergency power supplies which must be operable in modes 5 and 6 and added to the applicability sections the case of moving irradiated fuel assemblies or any loads over irradiated fuel assemblies with the reactor defueled.

You have subsequently informed us of an error on TS page 3/4 8-11 for NA-2. Due to an administrative error, an incorrect overleaf page was issued. Enclosed is the correct page 3/4 8-11 for NA-2, as well as the overleaf page.

Sincerely,

/s/

Leon B. Engle, Project Manager Project Directorate II-2 Division of Reactor Projects - I/II Office of Nuclear Reactor Regulation

Enclosure: As stated

cc w/enclosure: See next page

NRC FILE CENTER COPY

 (χ)

OFFICE	LA:PDII-2	PM:PDL1-2	D:PDIA-2			- P-
NAME	D. Mikiver	L. The le	H. Berkow			
DATE	4 /30/92	4 130 /92	4/30/92	11	1 1	
OFFICIA FILENAN	AL RECORD COPY ME: NA81862.LTF	2				
9205120215 920430 PDR ADOCK 05000338 PDR ADOCK 05000338						JOI 1.

Mr. W. L. Stewart Virginia Electric & Power Company

cc: Mr. William C. Porter, Jr. County Administrator Louisa County P.O. Box 160 Louisa, Virginia 23093

.

Michael W. Maupin, Esq. Hunton and Williams P.O. Box 1535 Richmond, Virginia 23212

Dr. W. T. Lough Virginia State Corporation Commission Division of Energy Regulation P.O. Box 1197 Richmond, Virginia 23209

Old Dominion Electric Cooperative 4201 Dominion Blvd. Glen Allen, Virginia 23060

Mr. E. Wayne Harrell Vice President - Nuclear Services Virginia Electric and Power Co. 5000 Dominion Blvd. Glen Allen, Virginia 23060

Office of the Attorney General Supreme Court Building 101 North 8th Street Richmond, Virginia 23219

Senior Resident Inspector North Anna Power Station U.S. Nuclear Regulatory Commission Route 2, Box 78 Mineral, Virginia 231172 North Anna Power Station Units 1 and 2

C.M.G. Buttery, M.D., M.P.H. State Health Commissioner Office of the Commissioner Virginia Department of Health P.O. Box 2448 Richmond, Virginia 23218

Regional Administrator, RII U.S. Nuclear Regulatory Commission 101 Marietta Street, N.W., Suite 2900 Atlanta, Georgia 30323

Mr. G. E. Kane, Manager North Anna Power Station P.O. Box 402 Mineral, Virginia 23117

Mr. J. P. O'Hanlon Vice President - Nuclear Operations Virginia Electric and Power Company 5000 Dominion Blvd. Glen Allen, Virginia 23060

Mr. Martin Bowling Manager - Nuclear Licensing Virginia Electric and Power Co. 5000 Dominion Blvd. Glen Allen, Virginia 23060

Į

ELECTRICAL POWER SYSTEMS

ĩ

3/4.8.2 ONSITE POWER DISTRIBUTION SYSTEMS

A.C. DISTRIBUTION - OPERATING

LIMITING CONDITION FOR OPERATION

3.8.2.1 The following A.C. electrical busses shall be OPERABLE and energized with the breakers open between redundant busses:

- a. H A.C. Emergency Busses consisting of:
 - 1. 4160 volt Emergency Bus # 2H
 - 2. 480 volt Emergency Busses # 2H, 2H1
- b. J A.C. Emergency Busses consisting of:
 - 1. 4160 volt Emergency Bus # 2J
 - 2. 480 volt Emergency Busses # 2J, 2J1
- c. 120 volt A.C. Vital Bus # 2-I energized from its associated inverter connected to D.C. Bus # 2-I*
- d. 120 volt A.C. Vital Bus # 2-II energized from its associated inverter connected to D.C. Bus # 2-II*
- e. 120 volt A.C. Vital Bus # 2-III energized from its associated inverter connected to D.C. Bus # 2-III*
- f. 120 volt A.C. Vital Bus # 2-IV energized from its associated inverter connected to D.C. Bus # 2-IV*

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTION:

- a. With one of the required A.C. Emergency busses not fully energized, re-energize within 8 hours or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.
- b. With one A.C. Vital Bus not energized, re-energize the A.C. Vital Bus within 2 hours or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.
- c. With one A.C. Vital Bus either not energized from its associated inverter, or with the inverter not connected to its associated D.C. Bus, re-energize the A.C. Vital Bus from its associated inverter connected to its associated D.C. Bus within 24 hours or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

*Two inverters may be disconnected from their D.C. Busses for up to 24 hours as necessary, for the purpose of performing an equalizing charge on their associated battery banks provided (1) their vital busses are energized, and (2) the remaining vital busses are energized from their associated inverters and connected to their associated D.C. Busses.

NORTH ANNA - UNIT 2

3/4 8-11

Amendment No. 137

9205120230 920430 PDR ADBCK 05000338 P PDR

ELECTRICAL POWER SYSTEMS

A.C. and D.C. DISTRIBUTION - SHUTDOWN

LIMITING CONDITION FOR OPERATION

3.8.2.2 As a minimum, one of the following trains of A.C. and D.C. busses shall be OPERABLE and energized in the specified manner:

- a. "H" Train (Orange) consisting of the following:
 - 1. 4160-volt Emergency Bus 2H
 - 2. 480-volt Emergency Busses 2H and 2H1
 - 3. 120-volt A.C. Vital Bus 2-1 energized from its associated inverter connected to D.C. bus 2-1, and
 - 4. 120-volt A.C. Vital Bus 2-2 energized from its associated inverter connected to D.C. bus 2-2.
 - 5. 125-volt D.C. Busses No. 2-1& 2-2, and
 - 6. 125-volt D.C. Battery Banks 2-I & 2-II and Chargers 2-I & 2-II D.C. Battery Charger 2C-I may be used in place of either of the above Chargers.
- b. "J" Train (Purple) consisting of the following:
 - 1. 4160-volt Emergency Bus 2J
 - 2. 480-volt Emergency Busses 2J and 2J1
 - 3. 120-volt A.C. Vital Bus 2-3 energized from its associated inverter connected to D.C. bus 2-3, and
 - 4. 120-volt A.C. Vital Bus 2-4 energized from its associated inverter connected to D.C. bus 2-4.
 - 5. 125-volt D.C. Busses No. 2-3 & 2-4, and
 - 6. 125-volt D.C. Battery Banks 2-III & 2-IV and Chargers 2-III & 2-IV D.C. Battery Charger 2C-II may be used in place of either of the above Chargers.

APPLICABILITY: a. Modes 5 and 6

b. During movement of irradiated fuel assemblies or loads over irradiated fuel assemblies when no fuel assemblies are in the reactor vessel.

Amendment No. 138