RC=CEL:[55.100]FORMATS.CEL AC=E7749

FROM S.G. E24-1 MAIN STM.LINE ISID2-007A (B-8)

FROM S.G. E24-2 MAIN STM.LINE ISID2-007A (B-6)

FROM AUX. STEAM SYS. M-020 (B-9)

AUX. FEED PUMP TURBINE 1-1

AUX. FEED PUMP TURBINE 1-2

AUX. FEED PUMP TURBINE K3-1 DRAINS & COOLING WATER

AUX. FEED PUMP TURBINE K3-2 DRAINS & COOLING WATER

INFO. NOTE:
(REMOVE AT NEXT UPDATE)
REVISION CHANGE IN THE CLOUDED AREA WAS FOR COLORIZING THE LINE CLASS CODES

LEGEND

- ASME SECTION XI CLASS 1 PIPING (RED)
- ASME SECTION XI CLASS 2 PIPING (BLUE)
- ASME SECTION XI CLASS 3 PIPING (GREEN)
- REFERENCE & CONTINUITY
- D—D— HVAC DUCT

[ISIM2- ] REFERENCE TO THE PIPING ISOMETRIC DRAWING FOR DETAILS ON THE PIPING CONFIGURATION, AND THE LOCATION AND IDENTIFICATION OF WELDS AND SUPPORTS.

[ ] RESERVED FOR SPECIAL ISI REQUIREMENTS. (MAY BE) ACCOMPANIED BY SPECIFIC NOTES.

⇨ REFERENCE TO THE ISI ITEM NUMBER DESIGNATION USED IN THE FIRST 10 YEAR INSERVICE INSPECTION INTERVAL.

◇1/2◇ ASME SECTION XI CLASS CHANGE

◆2◆ ISI PROGRAM BOUNDARY

NOTES:

1. DELETED
2. FOR ISI BOUNDARY DIAGRAM INDEX SHEET AND GENERAL NOTES, SEE ISID2-001.
3. FOR PIPING SYMBOLS AND P & ID INDEX, SEE DRAWING M-001.
4. UNLESS OTHERWISE NOTED, ALL VENT CONNECTIONS ARE ¾" AND DRAIN CONNECTIONS ARE 1". LINE IDENTIFICATION IS THE SAME AS THE HEADER.

| NO. | DATE | REVISIONS | BY | CH'K | ENGR. | ENGR. SUPV. | ENGR. MGR. |
|---|---|---|---|---|---|---|---|
| 5 | 05/31/96 | INC. DCN ISID2-003C-5 PER DCR 94-0010 B DCN'S ISID2-003C-8 8 9 PER MOD 95-0060 SUP. 0 | *INITIALS ON FILE* | | | | |
| 4 | 02/16/94 | INC. DCN ISID2-003C-4 FOR RFA 93-0452 | *INITIALS ON FILE* | | | | |
| 3 | 10/09/92 | INC. DCN ISID2-003C-3 FOR ECR 85-0143 SUPP. 0 | *INITIALS ON FILE* | | | | |
| 7 | / / | INC. DCN ISID2-003C-12 PER DDR 00-1768 | SBW | | | | |
| 6 | 07/18/88 | INC. DCN ISID2-003C-11 PER MOD 95-0060 SUP. 01 | *INITIALS ON FILE* | | | | |
| 0 | 7/23/89 | ISSUED FOR SECOND 10 YEAR ISI PROGRAM | CB | MTF JBG | JDE | MGP | ECC |

SCALE N.T.S. DESIGNED DRAWN CB DATE 7-12-89

DAVIS-BESSE NUCLEAR POWER STATION UNIT NO.1 Q
THE TOLEDO EDISON COMPANY

INSERVICE INSPECTION DIAGRAM
MAIN STEAM AND REHEAT SYSTEM SHEET 3

DRAWING NO. ISID2-003C REV. 7

D-003

DB 08-21-00 DFN= I:/ISID/2SID003C.DGN LEVELS 1 2 3 4 5 6 7 8 9 10 11 12 13 14 34X44 "E" SIZE PSC=