



LEGEND

- ASME SECTION XI CLASS 1 PIPING (RED)
- ASME SECTION XI CLASS 2 PIPING (BLUE)
- ASME SECTION XI CLASS 3 PIPING (GREEN)
- - - REFERENCE & CONTINUITY
- D - D - HVAC DUCT

INFO. NOTE:
(REMOVE AT NEXT UPDATE)
REVISION CHANGE IN THE CLOUDED
AREA WAS FOR COLORIZING THE
LINE CLASS CODES

- ISIM2- REFERENCE TO THE PIPING ISOMETRIC DRAWING FOR DETAILS ON THE PIPING CONFIGURATION, AND THE LOCATION AND IDENTIFICATION OF WELDS AND SUPPORTS.
- RESERVED FOR SPECIAL ISI REQUIREMENTS. (MAY BE) ACCOMPANIED BY SPECIFIC NOTES.
- REFERENCE TO THE ISI ITEM NUMBER DESIGNATION USED IN THE FIRST 10 YEAR INSERVICE INSPECTION INTERVAL.
- ◊ ASME SECTION XI CLASS CHANGE
- ◊ ISI PROGRAM BOUNDARY

- NOTES:**
1. DELETED
 2. FOR ISI BOUNDARY DIAGRAM INDEX SHEET AND GENERAL NOTES, SEE ISID2-001.
 3. FOR PIPING SYMBOLS AND P & ID INDEX, SEE DRAWING M-001.
 4. UNLESS OTHERWISE NOTED, ALL VENT CONNECTIONS ARE 3/4" AND DRAIN CONNECTIONS ARE 1". LINE IDENTIFICATION IS THE SAME AS THE HEADER.
 5. WHERE NOTED THE TANK CAPACITY IS NOMINAL, WHERE APPLICABLE, SEE DB-PF-06705 (TANK LEVEL CALIBRATION CURVES) FOR INDICATED LEVEL VS. VOLUME RELATIONSHIP. (REF. PCAOR 96-0976).

D-010

1/1	INC. DCN ISID2-017A-3 PER DDR 00-1766	SBW		
2/1	INC. DCN ISID2-017A-2 PER DCR 99-0001			"INITIALS ON FILE"
3/1	INC. DCN ISID2-017A-1 FOR DCR 91-0011			"INITIALS ON FILE"
4/1	ISSUED FOR SECOND 10 YEAR ISI PROGRAM	DJR	TRN	TWB MGP ECC
NO.	DATE	REVISIONS	BY	CHK'D ENGR. ENGR. SUPV. ENGR. MGR.
SCALE: N.T.S.		DESIGNED	DRAWN	CB
DAVIS-BESSE NUCLEAR POWER STATION UNIT NO. 1				
THE TOLSON EDISON COMPANY				
INSERVICE INSPECTION DIAGRAM DIESEL GENERATORS				
DRAWING NO.				REV.
ISID2-017A				3