



D-011

LEGEND

- ASME SECTION XI CLASS 1 PIPING (RED)
- ASME SECTION XI CLASS 2 PIPING (BLUE)
- ASME SECTION XI CLASS 3 PIPING (GREEN)
- REFERENCE & CONTINUITY
- D-D- HVAC DUCT

- [SIM2] REFERENCE TO THE PIPING ISOMETRIC DRAWING FOR DETAILS ON THE PIPING CONFIGURATION, AND THE LOCATION AND IDENTIFICATION OF WELDS AND SUPPORTS.
- [] RESERVED FOR SPECIAL ISI REQUIREMENTS. (MAY BE) ACCOMPANIED BY SPECIFIC NOTES.
- [] REFERENCE TO THE ISI ITEM NUMBER DESIGNATION USED IN THE FIRST 10 YEAR INSERVICE INSPECTION INTERVAL.
- [] ASME SECTION XI CLASS CHANGE
- [] ISI PROGRAM BOUNDARY

NOTES:

1. DELETED
2. FOR ISI BOUNDARY DIAGRAM INDEX SHEET AND GENERAL NOTES, SEE ISID2-001.
3. FOR PIPING SYMBOLS AND P & ID INDEX, SEE DRAWING M-001.
4. UNLESS OTHERWISE NOTED, ALL VENT CONNECTIONS ARE 3/4" AND DRAIN CONNECTIONS ARE 1". LINE IDENTIFICATION IS THE SAME AS THE HEADERS.
5. WHERE NOTED THE TANK CAPACITY IS NOMINAL, WHERE APPLICABLE, SEE DB-PF-06705 (TANK LEVEL CALIBRATION CURVES) FOR INDICATED LEVEL VS. VOLUME RELATIONSHIP. (REF. PCAOR 96-0976).

1	INC. DCN ISID2-017B-17 PER DCR 93-0001, ISID2-017B-20 PER ERR 60-0003-046; DCN ISID2-017B-21 PER ERR 60-0003-047 AND DCN ISID2-017B-22 PER DCR 02-1766	INITIALS ON FILE*
2	INC. DCN ISID2-017B-12 & 15 PER FPR 93-1228-301 & ISID2-017B-16 PER RFA 94-0108	INITIALS ON FILE*
3	INC. DCN ISID2-017B-13 & 14 FOR FPR 93-1228-301	INITIALS ON FILE*
4	INC. DCN S1 ISID2-017B-10 FOR RFA 93-0472 AND ISID2-017B-11 FOR RFA 93-0452	INITIALS ON FILE*
5	INC. DCN S1 ISID2-017B-3 THRU 6 FOR MOD 92-0013 SUPP.0	INITIALS ON FILE*
6	INC. DCN ISID2-017B-2 FOR DCR 90-0008	INITIALS ON FILE*
7	INC. DCN ISID2-017B-23 PER ERR 60-0003-116 & DCN ISID2-017B-24 PER ERR 60-0003-115	INITIALS ON FILE*
8	ISSUED FOR SECOND 10 YEAR ISI PROGRAM	TRN RJC TWB MGP ECC
NO.	DATE	BY
REVISIONS		
SCALE: N.T.S.		
DESIGNED: []		
CHECKED: []		
DATE		

DAVIS-BESSE NUCLEAR POWER STATION
UNIT NO. 1
INSERVICE INSPECTION DIAGRAM
DIESEL GENERATORS AIR START
ISID2-017B
8