



- ISIM2- REFERENCE TO THE PIPING ISOMETRIC DRAWING FOR DETAILS ON THE PIPING CONFIGURATION, AND THE LOCATION AND IDENTIFICATION OF WELDS AND SUPPORTS.
- RESERVED FOR SPECIAL ISI REQUIREMENTS. (MAY BE ACCOMPANIED BY SPECIFIC NOTES.)
- REFERENCE TO THE ISI ITEM NUMBER DESIGNATION USED IN THE FIRST YEAR INSERVICE INSPECTION INTERVAL.
- ASME SECTION XI CLASS CHANGE
- ISI PROGRAM BOUNDARY

- NOTES:**
- DELETED
  - FOR ISI BOUNDARY DIAGRAM INDEX SHEET AND GENERAL NOTES: SEE ISID2-001.
  - FOR PIPING SYMBOLS AND P & ID INDEX, SEE DRAWING M-001.
  - UNLESS OTHERWISE NOTED, ALL VENT CONNECTIONS ARE 1/2" AND DRAIN CONNECTIONS ARE 1". LINE IDENTIFICATION IS THE SAME AS THE HEADER.
  - FIRST NORMALLY CLOSED SAMPLING SYSTEM VALVE (1/2" GRINDEL DIAPHRAM VALVES) ARE SHOWN FOR ISI PROGRAM USES. SAMPLING SYSTEM DETAILS INCLUDING SAMPLE VALVE STATION NUMBERING ARE SHOWN ON P&ID M-042B.
  - WHERE NOTED, TANK CAPACITY IS NOMINAL. WHERE APPLICABLE, SEE DB-PP-06705 (TANK LEVEL CALIBRATION CURVES) FOR INDICATED LEVEL VS. VOLUME RELATIONSHIP (REF: PCA9R 96-0976).

INFO. NOTE:  
(REMOVE AT NEXT UPDATE)  
REVISION CHANGE IN THE CLOUDED AREA WAS FOR COLORIZING THE LINE CLASS CODES

D-026

NO.	DATE	REVISIONS	BY	CHKD	ENGR.	ENGR.	ENGR.	NO.
1	05/31/96	INC. DCN'S ISID2-036A-5 B 6 PER DCR 96-0425						"INITIALS ON FILE"
2	07/16/96	INC. DCN ISID2-036A-11 PER DCR 96-1766						SBW
3	06/24/96	INC. DCN'S ISID2-036A-7 PER DCR 96-0052 & ISID2-036A-10 PER DCR 97-0054						"INITIALS ON FILE"
4	07/16/97	INC. DCN ISID2-036A-9 PER DCR 97-0187						"INITIALS ON FILE"
5	07/16/99	ISSUED FOR SECOND TO YEAR ISI PROGRAM						CB EFB TWB MGF ECC

SCALE: N.T.S.    DESIGNED:    DRAWN: CB    DATE:

**DAVIS-BESSE NUCLEAR POWER STATION**  
UNIT NO. 1

INSERVICE INSPECTION DIAGRAM  
COMPONENT COOLING WATER SYSTEM

DRAWING NO.    REV.

**ISID2-036A**    7