

IP-2

4/3/97

Cycle 12

1993 - 1995 Cycle 12 598 EFP Days

↓ ~~1~~ Cold shutdown

16 DAYS in cold shutdown 1993

Cycle 13

May 95

603 EFP DAY

May 2 97

end-to-end

100% tubes - first support plate in all four SGs 1995 bobbin/Cecco
Cold leg

Sampling -

SG 21	2010
SG 22	1475
SG 23	2103
SG 24	2991

Using bobbin for full length

Sampling 200 Cecco in ~~SG~~ SG 21

first use of Cecco in

SG 21	end of 1995 end	279	tube Plug
22		344	Plugs
23		256	Plugs
24		273	plugs

Denting at TSP

Scatter everywhere

CoCo
Westinghouse qualified CoCo ^{in dents} use EDM Notches

Denting	270
Cold leg pitting	"
A/B wear	Play 3 tubes
re-roll	579 (541 in SG23)

Plugs

48

Plug 1150 tubes