INFO. NOTE:
(REMOVE AT NEXT UPDATE)
REVISION CHANGE IN THE CLOUDED AREA WAS FOR COLORIZING THE LINE CLASS CODES

INFO. NOTE:
(REMOVE AT NEXT UPDATE)
REVISION CHANGE IN THE CLOUDED AREA WAS FOR COLORIZING THE LINE CLASS CODES(REF. DCN 3)

LEGEND △3

- ASME SECTION XI CLASS 1 PIPING (RED)
- ASME SECTION XI CLASS 2 PIPING (BLUE)
- ASME SECTION XI CLASS 3 PIPING (GREEN)
- REFERENCE & CONTINUITY
- HVAC DUCT

[ISIM2-] REFERENCE TO THE PIPING ISOMETRIC DRAWING FOR DETAILS ON THE PIPING CONFIGURATION, AND THE LOCATION AND IDENTIFICATION OF WELDS AND SUPPORTS.

[ ] RESERVED FOR SPECIAL ISI REQUIREMENTS. (MAY BE) ACCOMPANIED BY SPECIFIC NOTES.

REFERENCE TO THE ISI ITEM NUMBER DESIGNATION USED IN THE FIRST 10 YEAR INSERVICE INSPECTION INTERVAL.

△1/2 ASME SECTION XI CLASS CHANGE

◆2 ISI PROGRAM BOUNDARY

NOTES: △3

1. DELETED
2. FOR ISI BOUNDARY DIAGRAM INDEX SHEET AND GENERAL NOTES, SEE ISID2-001.
3. FOR PIPING SYMBOLS AND P & ID INDEX, SEE DRAWING M-001.
4. UNLESS OTHERWISE NOTED, ALL VENT CONNECTIONS ARE ¾" AND DRAIN CONNECTIONS ARE 1". LINE IDENTIFICATION IS THE SAME AS THE HEADER.

D-031

NO.	DATE	REVISIONS	BY	CH'K	ENGR.	ENGR. SUPV.	GEN. SUPV.
△3	//	INC. DCN ISID2-041A-3 PER DDR 00-1766 & DCN ISID2-041A-4 PER DDR 00-1860	SBW				
△2	02/23/98	INC. DCN ISID2-041A-2 PER DDR 95-2486	INITIALS ON FILE				
△1	12/19/91	INC. DCN ISID2-041A-1 FOR DCR 91-0011	INITIALS ON FILE				
△0	4/23/90	ISSUED FOR SECOND 10 YEAR ISI PROGRAM	BLN	MTF JBG	JDE	MGP	ECC

SCALE N.T.S. DESIGNED Drawn BLN DATE

DAVIS-BESSE NUCLEAR POWER STATION UNIT NO.1 Q
THE TOLEDO EDISON COMPANY

INSERVICE INSPECTION DIAGRAM

SERVICE WATER PUMPS AND SECONDARY SERVICE WATER SYSTEM

DRAWING NO. ISID2-041A REV. 3

DB 08-10-00 DFN= #/ISID /25ISD041A.DGN
LEVELS 1111111111222222223333333334444444455555555556666 12345678901234567890123456789012345678901234567890123456789012

14 34X44 SIZE PSC= 1 1