- 7/06

JP2 Cont Call

SG 22 CL pit - ECT data <28% t/w

Leak rates 0gpm to 1750 psi

0.0035 @ 1750 psi

0.0055 @ 2700 psi

Checking today to determine if test apparatus leaks

Then retest tube.

J/26