

September 23, 1997

Mr. J.P. O'Hanlon
Senior Vice President - Nuclear
Virginia Electric and Power Company
5000 Dominion Blvd.
Glen Allen, Virginia 23060

SUBJECT: NORTH ANNA POWER STATION, UNITS 1 AND 2 - EXEMPTION FROM
10 CFR 70.24(a), CRITICALITY ACCIDENT MONITORING REQUIREMENTS
(TAC NOS. M97906 AND M97907)

Dear Mr. O'Hanlon:

By letter dated January 28, 1997, as supplemented March 24, 1997, Virginia Power and Electric Company (VEPCO) requested an exemption from criticality monitoring requirements specified in 10 CFR 70.24(a).

The NRC staff has reviewed the information provided in support of your request for the exemption. On the basis of the information provided and as discussed in the enclosed exemption, the NRC staff has concluded that reasonable and satisfactory precautions exist to preclude a nuclear criticality accident, as required by General Design Criteria (GDC) 62, and furthermore, the units have radiation monitors in fuel storage and handling areas, as required by GDC 63.

Thus the low probability of an inadvertant criticality together with your adherence to GDC 63 constitute good cause for granting an exemption to the requirements of 10 CFR 70.24(a). This exemption applies to both Unit 1 and Unit 2.

A copy of the exemption has been forwarded to the Office of the Federal Register for publication.

Sincerely,
Original signed by:
N. Kalyanam, Project Manager
Project Directorate II-1
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket Nos. 50-338 and 50-339 Distribution - See next page

Enclosure: As stated cc w/enclosure: See next page

FILENAME - G:\NOANNA\M97906-7.EX1

OFFICE	PM:PDII-1	LA:PDII-1	AD:PDII-1	BC:SRXB	OGC
NAME	NKalyanam	Dunnington	GEdison	JLyons	APH
	7/23/97	7/23/97	7/31/97	04/08/97	9/02/97
COPY	Yes/No	Yes/No	Yes/No	Yes/No	Yes/No

OFFICE	D:DRPE	ADP	D:NRR		
NAME	BBoger	RZimmerman	Stevens		
DATE	8/12/97	8/12/97	9/12/97		
COPY	Yes/No	Yes/No	Yes/No		

9710020127 970923
PDR ADOCK 05000338
PDR



NRC FILE CENTER COPY

Handwritten initials and marks on the right side of the page.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

September 23, 1997

Mr. J.P. O'Hanlon
Senior Vice President - Nuclear
Virginia Electric and Power Company
5000 Dominion Blvd.
Glen Allen, Virginia 23060

SUBJECT: NORTH ANNA POWER STATION, UNITS 1 AND 2 - EXEMPTION FROM
10 CFR 70.24(a), CRITICALITY ACCIDENT MONITORING REQUIREMENTS
(TAC NOS. M97906 AND M97907)

Dear Mr. O'Hanlon:

By letter dated January 28, 1997, as supplemented March 24, 1997, Virginia Power and Electric Company (VEPCO) requested an exemption from criticality monitoring requirements specified in 10 CFR 70.24(a).

The NRC staff has reviewed the information provided in support of your request for the exemption. On the basis of the information provided and as discussed in the enclosed exemption, the NRC staff has concluded that reasonable and satisfactory precautions exist to preclude a nuclear criticality accident, as required by General Design Criteria (GDC) 62, and furthermore, the units have radiation monitors in fuel storage and handling areas, as required by GDC 63.

Thus the low probability of an inadvertant criticality together with your adherence to GDC 63 constitute good cause for granting an exemption to the requirements of 10 CFR 70.24(a). This exemption applies to both Unit 1 and Unit 2.

A copy of the exemption has been forwarded to the Office of the Federal Register for publication.

Sincerely,

A handwritten signature in black ink, appearing to read "N. Kalyanam", written over a horizontal line.

N. Kalyanam, Project Manager
Project Directorate II-1
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket Nos. 50-338
and 50-339

Enclosure:
As stated

cc w/enclosure: See next page

Letter Dated September 23, 1997

Distribution

~~Public File~~

PUBLIC

PDII-1 RF

S. Collins/F. Miraglia

R. Zimmerman

B. Boger

M. Malloy

OGC

G. Hill (2)

ACRS

G. Tracy

J. Johnson, RII

Mr. J. P. O'Hanlon
Virginia Electric & Power Company

North Anna Power Station
Units 1 and 2

cc:

Mr. J. Jeffrey Lunsford
County Administrator
Louisa County
P.O. Box 160
Louisa, Virginia 23093

Regional Administrator, Region II
U.S. Nuclear Regulatory Commission
Atlanta Federal Center
61 Forsyth St., SW, Suite 23T85
Atlanta, Georgia 30303

Michael W. Maupin, Esquire
Hunton and Williams
Riverfront Plaza, East Tower
951 E. Byrd Street
Richmond, Virginia 23219

Mr. W. R. Matthews, Manager
North Anna Power Station
P. O. Box 402
Mineral, Virginia 23117

Dr. W. T. Lough
Virginia State Corporation
Commission
Division of Energy Regulation
P. O. Box 1197
Richmond, Virginia 23209

Mr. Al Belisle
U.S. Nuclear Regulatory Commission
Atlanta Federal Center
61 Forsyth St., SW, Suite 23T85
Atlanta, Georgia 30303

Old Dominion Electric Cooperative
4201 Dominion Blvd.
Glen Allen, Virginia 23060

Mr. David Christian, Manager
Surry Power Station
Virginia Electric and Power Company
5570 Hog Island Road
Surry, Virginia 23883

Mr. M. L. Bowling, Manager
Nuclear Licensing & Operations
Support
Virginia Electric and Power Company
Innsbrook Technical Center
5000 Dominion Blvd.
Glen Allen, Virginia 23060

Office of the Attorney General
Commonwealth of Virginia
900 East Main Street
Richmond, Virginia 23219

Senior Resident Inspector
North Anna Power Station
U.S. Nuclear Regulatory Commission
1024 Haley Drive
Mineral, Virginia 23117

Robert B. Strobe, M.D., M.P.H.
State Health Commissioner
Office of the Commissioner
Virginia Department of Health
P.O. Box 2448
Richmond, Virginia 23218

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

In the Matter of)	
)	
Virginia Electric and Power Company)	Docket Nos. 50-338
)	and 50-339
North Anna Power Station, Unit Nos. 1 and 2)	

EXEMPTION

I

The Virginia Electric and Power Company (the licensee) is the holder of Facility Operating License Nos. NPF-4 and NPF-7, which authorize operation of the North Anna Power Station (NAPS), Unit Nos. 1 and 2. The licenses provide, among other things, that the licensee be subject to all rules, regulations, and Orders of the Nuclear Regulatory Commission (the Commission) now or hereafter in effect.

The facility consists of two pressurized-water reactors at the licensee's site located in Louisa County, Virginia.

II

The Code of Federal Regulations at 10 CFR 70.24, "Criticality Accident Requirements," requires that each licensee authorized to possess special nuclear material (SNM) shall maintain a criticality accident monitoring system in each area where such material is handled, used, or stored. Subsections (a)(1) and (a)(2) of 10 CFR 70.24 specify detection, sensitivity and coverage capabilities of the monitors required by 10 CFR 70.24(a). Subsection (a)(3) requires licensees to maintain emergency procedures for each area in which this licensed SNM is handled, used, or stored.

Subsection (d) of 10 CFR 70.24 states that any licensee who believes that there is good cause why it should be granted an exemption from all or

part of 10 CFR 70.24 may apply to the Commission for such an exemption and shall specify the reasons for the relief requested.

III

By letter dated January 28, 1997, as supplemented March 24, 1997, Virginia Electric and Power Company requested an exemption from 10 CFR 70.24(a). The Commission technical staff has reviewed the licensee's submittal and has determined that inadvertent criticality is not likely to occur in SNM handling or storage areas at NAPS, Units 1 and 2.

At North Anna, SNM is present principally as nuclear fuel. Other small quantities of SNM are used on site. However, the total amount used in non-fuel applications is significantly less than the quantity specified in 10 CFR 70.24(a). The small quantity of non-fuel SNM present, and the form in which it is stored and used, precludes an inadvertant criticality. Therefore, SNM used as nuclear fuel is the only material on site subject to the requirements of 10 CFR 70.24(a).

Nuclear fuel is stored in the new fuel storage area and the spent fuel pool. New fuel is stored dry (in air) in the new fuel storage area. The spent fuel pool is used to store irradiated fuel under water after its discharge from the reactor, and new fuel prior to loading into the reactor.

The new fuel storage area is used to receive and store new fuel in a dry condition upon arrival on site and prior to loading in the reactor or spent fuel pool. The spacing between new fuel assemblies in the storage racks is sufficient to maintain the array in a subcritical condition even under accident conditions assuming the presence of moderator. The maximum nominal enrichment of 4.3 wt% U-235 for the new fuel assemblies results in a maximum k_{eff} of less than 0.95 under conditions of accidental flooding by unborated water and k_{eff} less than 0.98 under conditions of low-density optimum

moderation. The staff has found the design of the licensee's new fuel storage racks to be adequate to store fuel enriched to 4.3 wt% U-235.

Consistent with Technical Specification Section 5.6.1.1, the spent fuel pool is designed to store the fuel in a geometric array that precludes criticality. The spent fuel racks are designed such that the effective neutron multiplication factor, k_{eff} , will remain less than or equal to 0.95 under all normal and accident conditions for fuel of maximum nominal enrichment of 4.3 wt% U-235.

Nuclear fuel is moved between the shipping container, the new fuel storage racks, the reactor vessel, and the spent fuel pool to accommodate refueling operations. In all cases, fuel movements are procedurally controlled and designed to preclude conditions involving criticality concerns.

The purpose of the criticality monitors required by 10 CFR 70.24 is to ensure that if a criticality were to occur during the handling of nuclear material, personnel would be alerted to that fact and would take appropriate action. Although the staff has determined that such an accident is not likely to occur, the licensee has radiation monitors, as required by General Design Criterion 63, in fuel storage and handling areas. These monitors have associated area alarms and control room annunciators and would detect excessive radiation levels and will alert personnel to allow them to initiate appropriate emergency procedures and safety actions. The low probability of an inadvertent criticality together with the licensee's adherence to General Design Criterion 63 constitute good cause for granting an exemption to the requirements of 10 CFR 70.24(a).

IV


The Commission has determined that, pursuant to 10 CFR 70.14, this exemption is authorized by law, will not endanger life or property or the common defense and security, and is otherwise in the public interest; therefore, the Commission hereby grants Virginia Electric and Power Company the exemption from the requirements of 10 CFR 70.24(a) for North Anna Power Station, Unit Nos. 1 and 2, relating to criticality accident monitoring requirements.

V

Pursuant to 10 CFR 51.32, the Commission has determined that the granting of this exemption will not result in any significant adverse environmental impact (62 FR 49540).

This exemption is effective upon issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Frank J. Miraglia, Acting Director
Office of Nuclear Reactor Regulation

Dated at Rockville, Maryland,
this 23rd day of September 1997