



- LEGEND**
- ASME SECTION XI CLASS 1 PIPING
 - - - ASME SECTION XI CLASS 2 PIPING
 - · · ASME SECTION XI CLASS 3 PIPING
 - · — · — · NON-151 NON-CLASS AND HSC CLASS
 - · — · — · PRESSURE BOUNDARY EXTENSION
 - - - - - REFERENCE & CONTINUITY
 - 0 - 0 - HVAC DUCT
 - A ANCHOR
 - CS CONSTANT SPRING HANGER
 - VS VARIABLE SPRING HANGER
 - HS HYDRAULIC SNUBBER
 - MS MECHANICAL SNUBBER
 - N NON-WELDED SUPPORT ATTACHMENT
 - W WELDED INTEGRAL SUPPORT ATTACHMENT
 - R RIGID SUPPORT
 - T SWAY STRUT
 - SW SHOP WELD
 - FW FIELD WELD
 - LW LONGITUDINAL WELD
 - WOL WELDOLET
 - 151 ITEM NUMBER DESIGNATION USED IN THE FIRST 10 YEAR INSERVICE INSPECTION INTERVAL.

- NOTES:**
1. MULTIPLE SWAY STRUTS, SPRING SUPPORTS OR SNUBBERS IN A SINGLE PIPING SUPPORT ARE SHOWN BY A NUMBER BEFORE THE SUPPORT TYPE. (EXAMPLE: 2HS - TWO HYDRAULIC TYPE SNUBBERS THAT ARE NOT WELDED INTEGRAL TO THE PIPE).
 2. THERE ARE NO PIPE SPOOL NUMBERS FOR THIS DRAWING.
 3. SUPPORT NUMBERS AND LOCATIONS FOR THIS DRAWING ARE DERIVED FROM DRAWING 1502-HL-1114, SHEET 2 OF 4.
 4. THE SUPPORTS ON THE AUXILIARY FEED PUMP EXHAUST LINES 8\"/>

GENERAL NOTE
 DIMENSIONS SHOWN ON THIS DRAWING ARE TO BE USED FOR APPROXIMATE LOCATION ONLY. USE DESIGN DRAWINGS FOR DIMENSIONAL VERIFICATION.

REFERENCE DRAWINGS:
 15102-003C MAIN STEAM AND REHEAT SYSTEM SHEET 3

D-043

NO.	DATE	REVISIONS	BY	CHKD.
1	10/1/81	ISSUED FOR SECOND 10 YEAR ISI	LPM	WSP
2	10/1/81	ISSUED FOR SECOND 10 YEAR ISI	LPM	WSP
3	10/1/81	ISSUED FOR SECOND 10 YEAR ISI	LPM	WSP
4	10/1/81	ISSUED FOR SECOND 10 YEAR ISI	LPM	WSP
5	10/1/81	ISSUED FOR SECOND 10 YEAR ISI	LPM	WSP
6	10/1/81	ISSUED FOR SECOND 10 YEAR ISI	LPM	WSP
7	10/1/81	ISSUED FOR SECOND 10 YEAR ISI	LPM	WSP
8	10/1/81	ISSUED FOR SECOND 10 YEAR ISI	LPM	WSP
9	10/1/81	ISSUED FOR SECOND 10 YEAR ISI	LPM	WSP
10	10/1/81	ISSUED FOR SECOND 10 YEAR ISI	LPM	WSP
11	10/1/81	ISSUED FOR SECOND 10 YEAR ISI	LPM	WSP
12	10/1/81	ISSUED FOR SECOND 10 YEAR ISI	LPM	WSP
13	10/1/81	ISSUED FOR SECOND 10 YEAR ISI	LPM	WSP
14	10/1/81	ISSUED FOR SECOND 10 YEAR ISI	LPM	WSP

SCALE: N.T.S. REVISIONS: DESIGNED BY: CB

DAVIS-BESSE NUCLEAR POWER STATION
 UNIT NO. 1

INSERVICE INSPECTION ISOMETRIC
 MAIN STEAM SYSTEM
 AUX. FEED PUMP TURBINE EXHAUST

151M2-203K