

November 3, 1998

Mr. J. P. O'Hanlon
Senior Vice President - Nuclear
Virginia Electric and Power Company
5000 Dominion Blvd.
Glen Allen, Virginia 23060

SUBJECT: NORTH ANNA UNITS 1 AND 2 - SAFETY INJECTION (SI) ACCUMULATOR
BORON CONCENTRATION VERIFICATION - TECHNICAL SPECIFICATION
BASES CHANGE (TAC NOS. MA3752 AND MA3753)

Dear Mr. O'Hanlon:

By letter dated September 24, 1998, you submitted for our information your proposed Technical Specifications (TS) Bases change for "SI Accumulator Boron Concentration Verification." You stated that the proposed changes are being made to clarify that, although the run of piping between the two Safety Injection Accumulator (SIA) discharge valves is credited in demonstrating compliance with the Technical Specification Limiting Condition for Operation (LCO) 3.5.1 minimum SIA volume requirement, the minimum boron requirement does not apply to this run of piping. You also stated that the TS Bases for the accumulators are being changed.

Title 10 of the Code of Federal Regulations, Part 50 (10 CFR 50), Section 59, permits licensees to make changes in the facility as described in the safety analysis report, without prior Commission approval, unless the proposed change involves a change in the TS incorporated in the license or an unreviewed safety question. Your letter stated that it has been determined that these proposed changes do not involve an unreviewed safety question, as defined in 10 CFR 50.59. Accordingly, the regulations authorize you to make the proposed TS Bases changes without our review. Your changes to the Bases may be subject to our future inspections or audits.

This completes our effort under the technical assignment control (TAC) numbers MA3752 and MA3753 and the TACs are closed.

If you have any questions, please write or call me at (301) 415-1480.

Sincerely,

ORIGINAL SIGNED BY:
N. Kalyanam, Project Manager
Project Directorate II-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

9811090052 981103
PDR ADOCK 05000338
P PDR

Docket Nos. 50-338 and 50-339

cc: See next page

Distribution:

Docket File

PUBLIC

J. Zwolinski

G. Hill (4), TWFN 5/C/3

PDII-2 RF

C. Grimes, 11/F/23

ACRS

FILENAME:g\noanna\ma3752-3.bss

NRC FILE CENTER COPY

DF01/0

OFFICE	PM:PDII-2	LA:PDII-2	D:PDII-2
NAME	NKalyanam <i>WAG</i>	EDunnington <i>ED</i>	HBerkow <i>[Signature]</i>
DATE	11/3/98	11/3/98	11/3/98

000002



**UNITED STATES
NUCLEAR REGULATORY COMMISSION**

WASHINGTON, D.C. 20555-0001

November 3, 1998

Mr. J. P. O'Hanlon
Senior Vice President - Nuclear
Virginia Electric and Power Company
5000 Dominion Blvd.
Glen Allen, Virginia 23060

**SUBJECT: NORTH ANNA UNITS 1 AND 2 - SAFETY INJECTION (SI) ACCUMULATOR
BORON CONCENTRATION VERIFICATION - TECHNICAL SPECIFICATION
BASES CHANGE (TAC NOS. MA3752 AND MA3753)**

Dear Mr. O'Hanlon:

By letter dated September 24, 1998, you submitted for our information your proposed Technical Specifications (TS) Bases change for "SI Accumulator Boron Concentration Verification." You stated that the proposed changes are being made to clarify that, although the run of piping between the two Safety Injection Accumulator (SIA) discharge valves is credited in demonstrating compliance with the Technical Specification Limiting Condition for Operation (LCO) 3.5.1 minimum SIA volume requirement, the minimum boron requirement does not apply to this run of piping. You also stated that the TS Bases for the accumulators are being changed.

Title 10 of the Code of Federal Regulations, Part 50 (10 CFR 50), Section 59, permits licensees to make changes in the facility as described in the safety analysis report, without prior Commission approval, unless the proposed change involves a change in the TS incorporated in the license or an unreviewed safety question. Your letter stated that it has been determined that these proposed changes do not involve an unreviewed safety question, as defined in 10 CFR 50.59. Accordingly, the regulations authorize you to make the proposed TS Bases changes without our review. Your changes to the Bases may be subject to our future inspections or audits.

This completes our effort under the technical assignment control (TAC) numbers MA3752 and MA3753 and the TACs are closed.

If you have any questions, please write or call me at (301) 415-1480.

Sincerely,

A handwritten signature in black ink, appearing to read "N. Kalyanam", with a horizontal line underneath.

N. Kalyanam, Project Manager
Project Directorate II-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket Nos. 50-338 and 50-339

cc: See next page

Mr. J. P. O'Hanlon
Virginia Electric & Power Company

North Anna Power Station
Units 1 and 2

cc:

Mr. J. Jeffrey Lunsford
County Administrator
Louisa County
P.O. Box 160
Louisa, Virginia 23093

Regional Administrator, Region II
U.S. Nuclear Regulatory Commission
Atlanta Federal Center
61 Forsyth St., SW, Suite 23T85
Atlanta, Georgia 30303

Mr. Donald P. Irwin, Esquire
Hunton and Williams
Riverfront Plaza, East Tower
951 E. Byrd Street
Richmond, Virginia 23219

Mr. W. R. Matthews
Site Vice President
North Anna Power Station
P. O. Box 402
Mineral, Virginia 23117

Dr. W. T. Lough
Virginia State Corporation
Commission
Division of Energy Regulation
P. O. Box 1197
Richmond, Virginia 23209

Mr. R. C. Haag
U.S. Nuclear Regulatory Commission
Atlanta Federal Center
61 Forsyth St., SW, Suite 23T85
Atlanta, Georgia 30303

Old Dominion Electric Cooperative
4201 Dominion Blvd.
Glen Allen, Virginia 23060

Mr. E. S. Grecheck
Site Vice President
Surry Power Station
Virginia Electric and Power Company
5570 Hog Island Road
Surry, Virginia 23883

Mr. J. H. McCarthy, Manager
Nuclear Licensing & Operations
Support
Virginia Electric and Power Company
Innsbrook Technical Center
5000 Dominion Blvd.
Glen Allen, Virginia 23060

Robert B. Strobe, M.D., M.P.H.
State Health Commissioner
Office of the Commissioner
Virginia Department of Health
P.O. Box 2448
Richmond, Virginia 23218

Office of the Attorney General
Commonwealth of Virginia
900 East Main Street
Richmond, Virginia 23219

Senior Resident Inspector
North Anna Power Station
U.S. Nuclear Regulatory Commission
1024 Haley Drive
Mineral, Virginia 23117