Mr. J. P. O'Hanlon Senior Vice President - Nuclear Virginia Electric and Power Company 5000 Dominion Blvd. Glen Allen, Virginia 23060

#### SUBJECT: NORTH ANNA POWER STATION, UNITS 1 AND 2 - ISSUANCE OF AMENDMENTS REGARDING A PROPOSED TECHNICAL SPECIFICATION CHANGE ON TURBINE THROTTLE AND GOVERNOR VALVES SURVEILLANCE FREQUENCY (TAC NOS. MA0172 AND MA0173)

Dear Mr. O'Hanlon:

On April 16, 1998, the Commission issued Amendment Nos. 210 and 191 to Facility Operating License Nos. NPF-4 and NPF-7 for the North Anna Power Station, Units No. 1 and No. 2, relating to a Technical Specification change on turbine throttle and governor valves surveillance frequency. Due to an administrative oversight, your letter of April 1, 1998, which provided certain supplemental information, was not referenced in our April 16 letter and associated Enclosures.

Enclosed are the appropriate corrected pages of the amendments and the Safety Evaluation. Please replace the affected sheets accordingly.

If you have any questions, please call me at (301) 415 1480.

Sincerely, (Original Signed By) N. Kalyanam, Project Manager Project Directorate II-1 Division of Reactor Projects - I/II Office of Nuclear Reactor Regulation

Docket Nos. 50-338 and 50-339 Enclosures:

- 1. Page 1 of Amendment No. 210 to NPF-4
- 2. Page 1 of Amendment No. 191 to NPF-7
- 3. Page 1 of the Safety Evaluation

cc w/enclosures: See next page

806040074 980

1070

| FILENAME - G:\NOANNA\MA0172-3.AM1 |           |             |          |           |
|-----------------------------------|-----------|-------------|----------|-----------|
| OFFICE                            | PM:PDII-1 | LA:PDII-1   | D:PDII-1 |           |
| NAME                              | NKalyanam | EDunnington | GEEdison |           |
| DATE                              | \$ 12798  | 5127198     | 5 198    |           |
| COPY                              | (Yes/No   | Tes/No      | Yes No   | . <u></u> |



Mr. J. P. O'Hanlon Virginia Electric & Power Company

cc: Mr. J. Jeffrey Lunsford County Administrator Louisa County P.O. Box 160 Louisa, Virginia 23093

Michael W. Maupin, Esquire Hunton and Williams Riverfront Plaza, East Tower 951 E. Byrd Street Richmond, Virginia 23219

Dr. W. T. Lough Virginia State Corporation Commission Division of Energy Regulation P. O. Box 1197 Richmond, Virginia 23209

Old Dominion Electric Cooperative 4201 Dominion Blvd. Glen Allen, Virginia 23060

Mr. J. H. McCarthy, Manager Nuclear Licensing & Operations Support Virginia Electric and Power Company Innsbrook Technical Center 5000 Dominion Blvd. Glen Allen, Virginia 23060

Office of the Attorney General Commonwealth of Virginia 900 East Main Street Richmond, Virginia 23219

Senior Resident Inspector North Anna Power Station U.S. Nuclear Regulatory Commission 1024 Haley Drive Mineral, Virginia 23117 North Anna Power Station Units 1 and 2

Regional Administrator, Region II U.S. Nuclear Regulatory Commission Atlanta Federal Center 61 Forsyth St., SW, Suite 23T85 Atlanta, Georgia 30303

Mr. W. R. Matthews, Manager North Anna Power Station P. O. Box 402 Mineral, Virginia 23117

Mr. R. C. Haag U.S. Nuclear Regulatory Commission Atlanta Federal Center 61 Forsyth St., SW, Suite 23T85 Atlanta, Georgia 30303

Mr. J. P. O'Hanlon Senior Vice President - Nuclear Virginia Electric and Power Company Innsbrook Technical Center 5000 Dominion Blvd. Glen Allen, Virginia 23060

Mr. David Christian, Manager Surry Power Station Virginia Electric and Power Company 5570 Hog Island Road Surry, Virginia 23883

Robert B. Strobe, M.D., M.P.H. State Health Commissioner Office of the Commissioner Virginia Department of Health P.O. Box 2448 Richmond, Virginia 23218



UNITED STATES NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

# VIRGINIA ELECTRIC AND POWER COMPANY

# OLD DOMINION ELECTRIC COOPERATIVE

# DOCKET NO. 50-338

## NORTH ANNA POWER STATION. UNIT NO. 1

#### AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 210 License No. NPF-4

- 1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Virginia Electric and Power Company et al., (the licensee) dated November 18, 1997, as supplemented April 1, 1998, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (I) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

9806040078 980528 PDR ADDCK 05000338 P PDR



UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D.C. 20555-0001

# VIRGINIA ELECTRIC AND POWER COMPANY

## OLD DOMINION ELECTRIC COOPERATIVE

# DOCKET NO. 50-339

# NORTH ANNA POWER STATION. UNIT NO. 2

### AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 191 License No. NPF-7

- 1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Virginia Electric and Power Company et al., (the licensee) dated November 18, 1997, as supplemented April 1, 1998, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (I) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.



# UNITED STATES NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION RELATED TO AMENDMENT NOS. 210 AND 191 TO FACILITY OPERATING LICENSE NOS. NPF-4 AND NPE-7 VIRGINIA ELECTRIC AND POWER COMPANY OLD DOMINION ELECTRIC COOPERATIVE NORTH ANNA POWER STATION. UNITS NO. 1 AND NO. 2 DOCKET NOS. 50-338 AND 50-339


## 1.0 INTRODUCTION

By application dated November 18, 1997, as supplemented April 1, 1998, Virginia Electric and Power Company (the licensee) submitted a request for changes to the North Anna Power Station, Units 1 and 2, Technical Specifications (TS). The proposed amendment revises surveillance requirement (SR) 4.7.1.7.2.a.1 and 4.7.1.7.2.a.2 for the overspeed protection system. On the basis of past operational experience, Westinghouse's recommendations for inspection intervals, and the results of the Westinghouse evaluation proprietary report WCAP-14732 (nonproprietary version WCAP-14733), dated June 1997, the licensee proposes to increase the surveillance test interval for the turbine governor and throttle valves from "at least once per 31 days" to "at least once per 92 days." The disassembly inspection intervals for these valves will continue to be in accordance with the current TS SRs.

#### 2.0 BACKGROUND

North Anna Units 1 and 2 are each equipped with a Westinghouse turbine generator. The Westinghouse turbine is a conventional 1800-rpm, tandem-compound unit consisting of one double-flow, high-pressure cylinder and two double-flow, low-pressure cylinders. The turbine is provided with four moisture separator reheaters located between the high-pressure and the low-pressure cylinders.

Each high-pressure steamline to the high-pressure cylinder contains a stoptrip (throttle) valve and a governor control valve. A reheat stop valve and an intercept valve are provided in the crossover piping between each moisture



DATED: <u>5/28/98</u>

AMENDMENT NO. TO FACILITY OPERATING LICENSE NO. NPF-4-NORTH ANNA UNIT 1 AMENDMENT NO. TO FACILITY OPERATING LICENSE NO. NPF-7-NORTH ANNA UNIT 2

Docket File PUBLIC PDII-1 RF J. Zwolinski, 14/E/4 G. Hill (4), TWFN 5/C/3 W. Beckner ACRS L. Plisco, RII