



- LEGEND**
- ASME SECTION XI CLASS 1 PIPING
 - ASME SECTION XI CLASS 2 PIPING
 - ASME SECTION XI CLASS 3 PIPING
 - NON-151 NUCLEAR CLASS AND HSC CLASS
 - PRESSURE BOUNDARY EXTENSION
 - REFERENCE & CONTINUITY
 - D-D-HVAC DUCT
 - A ANCHOR
 - CS CONSTANT SPRING HANGER
 - VS VARIABLE SPRING HANGER
 - HS HYDRAULIC SNUBBER
 - MS MECHANICAL SNUBBER
 - N NON-WELDED SUPPORT ATTACHMENT
 - W WELDED INTEGRAL SUPPORT ATTACHMENT
 - R RIGID SUPPORT
 - T SWAY STRUT
 - SW SHOP WELD
 - FW FIELD WELD
 - LW LONGITUDINAL WELD
 - 151 ITEM NUMBER DESIGNATION USED IN THE FIRST 10 YEAR INSERVICE INSPECTION INTERVAL.

- NOTES:**
1. MULTIPLE SWAY STRUTS, SPRING SUPPORTS OR SNUBBERS IN A SINGLE PIPING SUPPORT ARE SHOWN BY A NUMBER BEFORE THE SUPPORT TYPE. (EXAMPLE: 2MS - TWO HYDRAULIC TYPE SNUBBERS THAT ARE NOT WELDED INTEGRAL TO THE PIPE).
 2. THERE ARE NO SPOOL NUMBERS FOR THIS DRAWING.
 3. MAKE-UP LINE 2 1/2\"-CCB-3, DOWNSTREAM OF MV B00, IS PART OF THE WPI SYSTEM.
 4. THE MAKE-UP LINE 2 1/2\"-CCB-3 WELDS AND SUPPORTS UPSTREAM OF VALVE MV B00 ARE EXEMPT FROM INSERVICE EXAMINATION REQUIREMENTS PER 10C 1520. THE WELDS AND SUPPORTS SHOWN MAY NOT REPRESENT THE ACTUAL AS-BUILT CONDITION.
 5. PIPING SYSTEMS ON THIS DRAWING WHICH ARE OUTSIDE OF THE 151 BOUNDARY ARE SHOWN FOR REFERENCE AND CONTINUITY PURPOSES ONLY. THE CONFIGURATION SHOWN MAY NOT REPRESENT THE ACTUAL AS-BUILT CONDITION.

GENERAL NOTE
 DIMENSIONS SHOWN ON THIS DRAWING ARE TO BE USED FOR APPROXIMATE LOCATION ONLY. USE DESIGN DRAWINGS FOR DIMENSIONAL VERIFICATION.

REFERENCE DRAWINGS:
 15102-031C MAKEUP AND PURIFICATION SYSTEM
 15102-033A HIGH PRESSURE INJECTION

D-077

1. I certify that the info contained on this page was made in the normal and regular course of business, and the date shown below and that it is an accurate reproduction of the records.
 DATE: 4.18.92 OFFICER: [Signature]

INC. DCN 15102-031E-1 FOR	DATE: 4.18.92
ISSUED FOR SECOND YEAR ISI	PROGRAM
DAVIS-BESSE NUCLEAR POWER STATION UNIT NO. 1	
INSERVICE INSPECTION ISOMETRIC MAKE-UP AND PURIFICATION SYSTEM AUXILIARY BUILDING-SHEET 8	
ISIM2-231E	