

DCS MS-016

MAR 3 1982

Docket No. 50-339


Mr. R. H. Leasburg
Vice President - Nuclear Operations
Virginia Electric and Power Company
Post Office Box 26666
Richmond, Virginia 23261

Dear Mr. Leasburg:

Distribution:

- Docket File
- NRC PDR
- L PDR
- ORB #3 Rdg
- D. Eisenhut
- P. Kreutzer
- L. Engle
- OELD
- SECY
- OI&E (2)
- T. Barnhart
- L. Schneider
- D. Brinkman

- ACRS (10)
- OPA
- R. Diggs
- NSIC
- ASLAB



This confirms our telephone authorization given today, March 3, 1982, for a change to the Technical Specifications for the North Anna Power Station, Unit No. 2 as requested in your telecopy dated March 2, 1982. Facility Operating License No. NPF-7 is amended on this date, March 3, 1982 by making the following technical specification change.

Add footnote to Specification 3.4.1.2 on page 3/4 4-2 to read:

The requirement to have one coolant loop in operation is exempted during the performance of the boron mixing tests as stipulated in License Conditions 2.C(15)(f) and 2.C(20)(b).

Copies of the license amendment, our evaluation and Federal Register Notice for this technical specification change will be sent to you when completed.

Sincerely,

Original signed by:

Thomas M. Novak, Assistant Director
for Operating Reactors
Division of Licensing

CP
3

cc: See next page

8203160043 820303
PDR ADDCK 05000339
P PDR

OFFICE	DL:ORB#3	DL:ORB#3	DL:ORB#3	DL:OR			
SURNAME	PKreutzer	LEngle:ms	RA Clark	TNovak			
DATE	3/3/82	3/3/82	3/3/82	3/3/82			



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

MAR 3 1982

Docket No. 50-339

Mr. R. H. Leasburg
Vice President - Nuclear Operations
Virginia Electric and Power Company
Post Office Box 26666
Richmond, Virginia 23261

Dear Mr. Leasburg:

This confirms our telephone authorization given today, March 3, 1982, for a change to the Technical Specifications for the North Anna Power Station, Unit No. 2 as requested in your teletype dated March 2, 1982. Facility Operating License No. NPF-7 is amended on this date, March 3, 1982 by making the following technical specification change.

Add footnote to Specification 3.4.1.2 on page 3/4 4-2 to read:

The requirement to have one coolant loop in operation is exempted during the performance of the boron mixing tests as stipulated in License Conditions 2.C(15)(f) and 2.C(20)(b).

Copies of the license amendment, our evaluation and Federal Register Notice for this technical specification change will be sent to you when completed.

Sincerely,

A handwritten signature in dark ink, appearing to read "Tom Novak", written over a horizontal line.

Thomas M. Novak, Assistant Director
for Operating Reactors
Division of Licensing

cc: See next page

Virginia Electric and Power Company

cc:

Richard M. Foster, Esquire
Musick, Williamson, Schwartz,
Leavenworth & Cope, P.C.
P. O. Box 4579
Boulder, Colorado 80306

Michael W. Maupin, Esquire
Hunton, Williams, Gay and Gibson
P. O. Box 1535
Richmond, Virginia 23212

Alderman Library
Manuscripts Department
University of Virginia
Charlottesville, Virginia 22901

Mr. Edward Kube
Board of Supervisors
Louisa County Courthouse
P. O. Box 27
Louisa, Virginia 23093

Ellyn R. Weiss, Esquire
Sheldon, Harman, Roisman and Weiss
1725 I Street, N.W. Suite 506
Washington, D. C. 20006

Mr. W. R. Cartwright, Station Manager
P. O. Box 402
Mineral, Virginia 23117

Mr. Anthony Gambardella
Office of the Attorney General
11 South 12th Street - Room 308
Richmond, Virginia 23219

Resident Inspector/North Anna
c/o U.S.N.R.C.
Route 2, Box 78A
Mineral, Virginia 23117

Mr. J. H. Ferguson
Executive Vice President - Power
Virginia Electric and Power Company
Post Office Box 26666
Richmond, Virginia 23261

Mr. James Torson
501 Leroy
Socorro, New Mexico 87891

Mrs. Margaret Dietrich
Route 2, Box 568
Gordonsville, Virginia 22042

Mr. James C. Dunstance
State Corporation Commission
Commonwealth of Virginia
Blandon Building
Richmond, Virginia 23209

Mrs. June Allen
North Anna Environmental Coalition
8720 Lockmoor Circle
Wichita, Kansas 67207

U.S. Environmental Protection Agency
Region III Office
ATTN: Regional Radiation Representative
Curtis Building
6th and Walnut Streets
Philadelphia, Pennsylvania 19106

Mr. Paul W. Purdom
Environmental Studies Institute
Drexel University
32nd and Chestnut Streets
Philadelphia, Pennsylvania 19104

Atomic Safety and Licensing
Appeal Board Panel
U.S. Nuclear Regulatory Commission
Washington, D. C. 20555

Regional Administrator
Nuclear Regulatory Commission, Region II
Office of Executive Director for Operations
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303.